



GPU Nuclear Corporation
Post Office Box 480
Route 441 South
Middletown, Pennsylvania 17057-0191
717 944-7621
TELEX 84-2386
Writer's Direct Dial Number:

July 22, 1988
C311-88-2079

U. S. Nuclear Regulatory Commission
Attn: Document Control Desk
Washington, D.C. 20555

Dear Sir:

Three Mile Island Nuclear Station Unit (TMI-1)
Operating License No. DPR-50
Docket No. 50-289
Post Eddy Current Inspection Report for Cycle 7R

Following the completion of the eddy current inspection of TMI-1 A and B steam generator tubes, Technical Specification 4.19.5a requires a report to be submitted on the number of tubes repaired or removed from service.

During the Outage 7R eddy current inspection, no tubes were repaired in either generator. A total of 21 tubes were removed from service by plugging: 13 tubes in steam generator A and 8 tubes in steam generator B. Tube plugging was completed on July 9, 1988.

A total of 1260 tubes have been removed from service in steam generator A since fabrication. In steam generator B, a total of 367 have been removed from service.

This letter fulfills the requirement of Technical Specification 4.19.5a.

Sincerely,

H. D. Hukill
Vice President & Director, TMI-1

HDH/SMK:fg

cc: R. Conte
R. Hernan
W. Russell

8808020162 880822
PDR ADOCK 05000289
Q PNU

A047
1/0