



Tennessee Valley Authority, Post Office Box 2000, Spring City, Tennessee 37381-2000

April 29, 2011

10 CFR 70.22(a)

U.S. Nuclear Regulatory Commission
ATTN: Document Control Desk
Washington, D.C. 20555-0001

Watts Bar Nuclear Plant, Unit 2
NRC Docket No. 50-391

Subject: Watts Bar Nuclear Plant (WBN) Unit 2 – New Fuel Receipt – Response to Request for Additional Information

Reference: TVA Letter - Application for a Special Nuclear Material License for Watts Bar Nuclear Plant Unit 2 in Accordance with 10 CFR 70, "Domestic Licensing of Special Nuclear Material," dated November 12, 2009

This letter responds to an NRC verbal request for additional information (RAI) regarding the receipt and storage of new fuel for Unit 2. This RAI was discussed during an April 27, 2011, phone call.

The NRC noted that during their review of the 10 CFR 70 License application that the new fuel storage vault does not include sufficient space to store the total number of fuel assemblies required for the initial Unit 2 core load. Clarification was requested as to where the fuel would be stored if not in the new fuel vault. The fuel for the initial Unit 2 core load will be stored in either the new fuel vault and the spent fuel pool, or completely in the spent fuel pool. This was stated in the second paragraph of Section 1.1.2 Facility Description of Enclosure 1 to the referenced Application request. The application request and FSAR Section 9.1 describe features of the new fuel storage vault and the spent fuel pool that establish that criticality safety of the new fuel is assured in both storage locations.

DOB30
NRC

U.S. Nuclear Regulatory Commission
Page 2
April 29, 2011

There are no new commitments made in this letter. If you have any questions, please contact Bill Crouch at (423) 365-2004.

I declare under penalty of perjury that the foregoing is true and correct. Executed on the 29th day of April, 2011.

Respectfully,

A handwritten signature in black ink, appearing to read 'David Stinson', with a stylized flourish at the end.

David Stinson
Watts Bar Unit 2 Vice President

cc: U. S. Nuclear Regulatory Commission
Region II
Marquis One Tower
245 Peachtree Center Ave., NE Suite 1200
Atlanta, Georgia 30303-1257

NRC Resident Inspector Unit 2
Watts Bar Nuclear Plant
1260 Nuclear Plant Road
Spring City, Tennessee 37381