



- NOTES:**
1. FOR GENERAL NOTES SEE DRAWING N-0100
  2. CURBING FOR DELETED EMER. REGEN. ACID FEED PUMP 1-1. (REFERENCE FOR 85-072, SUPP. 57)
  3. FOR CHEMISTRY COMPUTER DATA ACQUISITION AND MANAGEMENT SYSTEM (CCAMS) REFER TO DWG. E326.
  4. MANY PNEUMATIC ACTIVATED VALVES DO NOT DEPICT THEIR ASSOCIATED INSTRUMENTATION AND CONTROL LOGIC. FOR THIS INFORMATION SEE WATOR DRAWINGS 7749-N-182-85, 81, 87, 98, 121, 130, 131, 132.
  5. THE PIPING FROM THE WATER TREATMENT BUILDING PUMP HAS BEEN ABANDONED IN PLACE. REFERENCE FOR 86-0404 SUPP. 00 AND 01.
  6. WHERE NOTED THE TANK CAPACITY IS NOMINAL. WHERE APPLICABLE, SEE DB-PF-06705 (TANK LEVEL CALIBRATION CURVES) FOR INDICATED LEVEL VS. VOLUME RELATIONSHIP. (REF. PCAR 96-0976)
  7. ELBOW HAS FAILED AND IS OPEN TO ATMOSPHERE. WT232, WT472 AND WT474 MUST REMAIN CLOSED. (REF. 07-0002-00)

**LR NOTES:**

A. FOR GENERAL LICENSE RENEWAL NOTES REFER TO LR-M010-01

---

**LICENSE RENEWAL BOUNDARY DRAWING**

**LR-M010C REV. 1**

---

SYSTEMS SHOWN ON THIS DRAWING ARE:  
 13: COMPONENT COOLING & DEMINERALIZED WATER STORAGE  
 18: REACTOR COOLANT SYSTEM

**DAVIS-BESSE NUCLEAR POWER STATION**  
 UNIT NO. 1  
 THE TOLEDO EDISON COMPANY

---

**PIPING & INSTRUMENT DIAGRAM**  
**MAKE-UP WATER TREATMENT SYSTEM**

JOB NO.	DRAWING NO.	REV.
12501	M-010C	42

THIS DRAWING REV. 0 SUPERSEDES IN PART DWG. N-0100 REV. 30. WORK THIS DWG. WITH N-0100.

DATE: 03-03-08 14 34X4 1/2" SIZE

01210