



NOTES:
 1. FOR NOTES SEE Dwg. M-017A.
 2. LSL1264 DE-ENERGIZED BY FCR 77-329.

LR NOTES:
 A. FOR GENERAL LICENSE RENEWAL NOTES REFER TO LR-M017-01.
 B. COMPONENTS HIGHLIGHTED GREEN ON THIS DRAWING ARE IN SCOPE FOR (A)(3)-FIRE PROTECTION. THE MAIN FLOW PATHS REQUIRED TO PERFORM THE (A)(3) FUNCTION, AND BRANCH LINES TO AND INCLUDING THE FIRST VALVE, ARE IN SCOPE. COMPONENTS THAT ARE NOT HIGHLIGHTED ARE NOT LOCATED IN SAFETY-RELATED AREAS WHERE (A)(2)-NSAS CONSIDERATIONS ARE A CONCERN, AND ARE THEREFORE NOT IN SCOPE.
 C. COMPONENTS BEYOND THE HIGHLIGHTING ARE IN-SCOPE STRUCTURAL COMPONENTS.
 D. HIGHLIGHTED COMPONENTS ARE LOCATED INSIDE THE SERVICE WATER PIPE TUNNEL.

LR-M017C REV. 2
 SYSTEMS SHOWN ON THIS DRAWING:
 17: DIESELS

**BECHTEL ASSOCIATES
 PROFESSIONAL CORPORATION (OHIO)
 6011 WILSON AVENUE
 GAITHERSBURG, MARYLAND
 DAVIS-BESSE NUCLEAR POWER STATION
 UNIT NO. 1
 THE TOLEDO EDISON COMPANY
 PIPING & INSTRUMENT DIAGRAM
 FUEL OIL**

JOB NO.	DRAWING NO.	REV.
12501	M-017C	26

DATE: 08-03-05-08 14 34X44 1/2" SIZE

01D19