



DECAY HEAT PUMP AND MOTOR BEARING OIL DRAIN AND WINDING TEMPERATURE INSTRUMENTATION	
P42-1	FUNCTION
TE (1)	(2)
DH5081	368 PUMP BEARING OT.
DH5082	364 PUMP BEARING-MOTOR END OT.
DH5181	366 MOTOR BEARING-PUMP END OT.
DH5182	365 MOTOR BEARING OT.
DH5281	MOTOR STATOR
DH5282	MOTOR STATOR
DH5283	MOTOR STATOR
DH5284	MOTOR STATOR
DH5285	MOTOR STATOR
DH5286	367 MOTOR STATOR

- NOTES:
- FOR NOTES SEE DRAWING M-033A.
 - DELETED

LR NOTES:
 A. FOR GENERAL LICENSE RENEWAL NOTES REFER TO LR-M033-01.
 B. UPDATED SA BOUNDARY IS AT THE INDICATED LOCATION, AS SHOWN ON PAID M-033B REV. 02.

LICENSE RENEWAL BOUNDARY DRAWING
 LR-M033B REV. 1

SYSTEMS SHOWN ON THIS DRAWING:
 03: REACTOR COOLANT
 06: DECAY HEAT REMOVAL & LOW PRESSURE INJECTION
 10: MAKEUP & PURIFICATION
 15: SPENT FUEL POOL COOLING & CLEANUP
 16: CONTAINMENT SPRAY & CORE FLOODING
 18: REACTOR COOLANT VENT & DRAIN
 20: STATION PLUMBING, DRAINS & SUMP
 22: HIGH PRESSURE INJECTION
 25: BORON RECOVERY

BECHTEL ASSOCIATES
 PROFESSIONAL CORPORATION (OHIO)
 GAITHERSBURG, MARYLAND

DAVIS-BESSE NUCLEAR POWER STATION
 UNIT NO. 1

THE TOLEDO EDISON COMPANY

PIPING & INSTRUMENT DIAGRAM
 DECAY HEAT TRAIN 1

JOB NO.	DRAWING NO.	REV.
12501	M-033B	50

012941