



- NOTES:**
1. FOR ADDITIONAL NOTES SEE DRAWING N-041A.
 2. VALVES SW64 THROUGH SW75 HAVE BEEN DELETED (REMOVED) BY EWS 02-0343-00.
 3. AS AN ACCEPTABLE CONDITION, OUTBOARD VACUUM BREAKER VALVES ARE NOT NEEDED TO SUPPORT SERVICE WATER SYSTEM OPERATION, WHEN OUTBOARD VALVE IS REMOVED, A FLANGED PIPE ELBOW SHALL BE INSTALLED TO DIRECT ANY POTENTIAL INBOARD VALVE LEAKAGE TOWARD THE FLOOR. (REF. ECR 05-0086-00 & ECR 05-0086-01)

- LR NOTES:**
- A. FOR GENERAL LICENSE RENEWAL NOTES REFER TO LR-M001-01.
 - B. HIGHLIGHTING CONTINUED ON LR-M029E.
 - C. UPDATED SH BOUNDARY IS AT THE INDICATED LOCATION, AS SHOWN ON P&ID N-041C REV. 40.

LICENSE RENEWAL BOUNDARY DRAWING
LR-M041C REV. 1

SYSTEMS SHOWN ON THIS DRAWING:
 07: SERVICE WATER
 20: STATION PLUMBING, DRAINS & Sumps
 21: CONTAINMENT
 24: NONSAFETY AFFECTING SAFETY

BECHTEL ASSOCIATES
 PROFESSIONAL CORPORATION (OHIO)
 301 THIBERSBURG, MARYLAND
**DAVIS-BESSE NUCLEAR POWER STATION
 UNIT NO. 1**
 THE TOLEDO EDISON COMPANY

JOB NO.	DRAWING NO.	REV.
12501	M-041C	39

THIS DRAWING REV. 0 SUPERSEDES IN PART Dwg. N-041 REV. 51 WORK THIS Dwg. WITH N-041A AND N-041B.

01260