



LR NOTES:

A. FOR GENERAL LICENSE RENEWAL NOTES REFER TO LR-M001-01.
 B. THIS LINE CONTAINS A CHECK VALVE. THE VALVE AND THE PIPING TO THAT VALVE ARE SAFETY-RELATED.
 C. 18 FLOOR DRAINS ARE LOCATED INSIDE THE AUX. BLDG. NEGATIVE PRESSURE AREA AND ARE FITTED WITH SAFETY-RELATED CHECK VALVES (SEE M-172 THRU M-174 FOR LOCATIONS).

GENERAL NOTES

1) NUMBERS SHOWN IN PARENTHESES INDICATE COUNT OF EACH ITEM REPRESENTED BY THAT PARTICULAR SYMBOL.
 2) LIMIT OF PIPING REQUIRING 1/2" SEISMIC I ANALYSIS
 3) FLOOR DRAINS IN THE AUX. BLDG. NEGATIVE PRESSURE AREA SHALL BE FITTED WITH SPRING LOADED WAFFER CHECKS.
 4) SEE DRAWING M-172 FOR COVERED FLOOR DRAINS.

LEGEND

▲ = PLUG
 □ = CAP

BECHTEL COMPANY
 SATHURSBURG, MARYLAND

DAVIS-BESSE NUCLEAR POWER STATION
 THE TOLEDO EDISON COMPANY
 THE CLEVELAND ELECTRIC ILLUMINATING COMPANY

SCHEMATIC DIAGRAM
STATION PLUMBING AND DRAINS

JOB NO.	DRAWING NO.	REV.
7749	M-090	4

DB104-14-99

m090m plotted by rothbecher from BDN to Wttime on Wednesday April 14 1999 - 02:06:15 PM EDT

01264