



NOTES:
 1. ALL VALVES PREFIXED DT UNLESS OTHERWISE SPECIFIED.
 2. COMPONENTS REPLACED VIA MOD 96-0034.

HIGHLIGHTING CONTINUED ON LR-M0398

M-281N-13-3

LR NOTES:
 A. FOR GENERAL LICENSE RENEWAL NOTES REFER TO LR-M001-01.
 B. COMPONENTS BEYOND THE HIGHLIGHTING DO NOT CONTAIN LIQUID OR STEAM NOR ARE ATTACHED TO SAFETY-RELATED COMPONENTS. THEREFORE, THESE COMPONENTS ARE NOT WITHIN THE SCOPE OF LICENSE RENEWAL.
 C. THE SAMPLE SINK DOES NOT FULFILL A LICENSE RENEWAL FUNCTION SINCE IT IS NOT SAFETY-RELATED, DOES NOT CONTAIN LIQUID FOR LONG DURATIONS, IS NOT A LEAKAGE OR SPRAY CONCERN, AND IS THEREFORE NOT IN SCOPE.
 D. COMPONENTS BEYOND THE HIGHLIGHTING ARE TEMPORARILY CONNECTED TO THE SYSTEM AND ARE THEREFORE NOT IN SCOPE.

LICENSE RENEWAL BOUNDARY DRAWING
 LR-M281N13 REV. 2
 SYSTEMS SHOWN ON THIS DRAWING:
 24: NONSAFETY AFFECTING SAFETY

DAVIS-BESSE NUCLEAR POWER STATION
UNIT NO. 1
 THE TOLEDO-EDISON COMPANY

SYSTEM LINE I.D.
FOR RADWASTE DEMINERALIZER SKID

	DRAWING NO.	REV.
	DT-60	T2

THIS DRAWING WAS REDRAWN ON CADD AND SUPERSEDES SUBMITAL 2

012965