

CCNPP3COLA PEmails

From: Steckel, James
Sent: Tuesday, November 30, 2010 3:08 PM
To: Poche, Robert
Cc: Scott, Roger D; Carneal, Jason; Huang, Eugene; Rasmussen, Richard; Jacobson, Jeffrey;
CCNPP3COL Resource
Subject: Draft RAI 282 CQVB 5246
Attachments: Draft RAI 282 CQVB 5246.docx

Rob,

Attached is DRAFT RAI No. 282 (eRAI No. 5246). You have until December 14, 2010, to review this RAI and decide whether you need a conference call to discuss/clarify the question(s) in this RAI before the final issuance of the RAI. After the clarification phone call or on December 14, 2010, the RAI will be finalized and sent to you for a response. You will then have 30 days to provide a technically complete response or an expected response date for the RAI.

Thank you,

Jim Steckel

James Steckel
Project Manager
NRC EPR Projects Branch
301 415-1026
james.steckel@nrc.gov

Hearing Identifier: CalvertCliffs_Unit3Cola_Public_EX
Email Number: 1785

Mail Envelope Properties (AF843158D8D87443918BD3AA953ABF781C3D420F59)

Subject: Draft RAI 282 CQVB 5246
Sent Date: 11/30/2010 3:07:55 PM
Received Date: 11/30/2010 3:07:57 PM
From: Steckel, James

Created By: James.Steckel@nrc.gov

Recipients:

"Scott, Roger D" <roger.scott@unistarnuclear.com>
Tracking Status: None
"Carneal, Jason" <Jason.Carneal@nrc.gov>
Tracking Status: None
"Huang, Eugene" <Eugene.Huang@nrc.gov>
Tracking Status: None
"Rasmussen, Richard" <Richard.Rasmussen@nrc.gov>
Tracking Status: None
"Jacobson, Jeffrey" <Jeffrey.Jacobson@nrc.gov>
Tracking Status: None
"CCNPP3COL Resource" <CCNPP3COL.Resource@nrc.gov>
Tracking Status: None
"Poche, Robert" <Robert.Poche@constellation.com>
Tracking Status: None

Post Office: HQCLSTR02.nrc.gov

Files	Size	Date & Time
MESSAGE	676	11/30/2010 3:07:57 PM
Draft RAI 282 CQVB 5246.docx		19748

Options

Priority: Standard
Return Notification: No
Reply Requested: No
Sensitivity: Normal
Expiration Date:
Recipients Received:

DRAFT

Request for Additional Information No. 282 (eRAI 5246) Revision 6
11/30/2010

Calvert Cliffs Unit 3

UniStar

Docket No. 52-016

SRP Section: 17.5 - Quality Assurance Program Description - Design Certification, Early Site Permit
and New License Applicants
Application Section: Section 17.5

QUESTIONS for Quality and Vendor Branch 2 (ESBWR/ABWR) (CQVB)

17.5-7

Follow-up question to RAI 200, Question 17.5-6:

Topical Report No. UN-TR-06-001-A, "Quality Assurance Program Description", Revision 2 for UniStar Nuclear Energy QAPD is based on NEI 06-14, Rev 9 (NEI 06-14A Rev 7). Consistent with the NRC staff's safety evaluation on NEI 06-14, Rev. 9, applicants that do not wish to include a commitment to RG 1.33, Rev. 2, in their QAPDs, must explicitly address the provisions in Attachment 4 to NEI 06-14, Revision 9, while also including Part V, "Additional Quality Assurance and Administrative Controls for the Plant Operational Phase," in their QAPDs. Accordingly, UniStar needs to submit (on the docket), the information in Attachment 4 to NEI 06-14 as it pertains to the Calvert Cliffs Unit 3 application, or otherwise include an explicit commitment RG 1.33, Rev 2 in Part IV, "Regulatory Commitments" of Topical Report No. UN-TR-06-001-A, Revision 2.