



May 6, 2011

NRC 2011-0051
10 CFR 50.90

U. S. Nuclear Regulatory Commission
ATTN: Document Control Desk
Washington, DC 20555

Point Beach Nuclear Plant, Units 1 and 2
Dockets 50-266 and 50-301
Renewed License Nos. DPR-24 and DPR-27

Regulatory Commitment Change

References: FPL Energy Point Beach, LLC letter to NRC, dated
April 7, 2009, License Amendment Request 261, Extended Power Uprate
(ML091250564)

Via Reference (1), NextEra made the following Regulatory Commitment:

The high pressurizer pressure reactor trip delay time of less than or equal to 1.0 second will be verified by a time delay test prior to operation of that unit at EPU conditions.

An engineering evaluation was performed. The evaluation determined response time testing of the high pressurizer pressure reactor trip instrument loops is not required because the trip will occur in less than 1.0 second, with a margin of 0.61 seconds.

The evaluation provided a basis for the elimination of the response time testing requirement using WCAP 13632, Elimination of Pressure Sensor Response Time Testing Requirements, and EPRI NP-7243, Investigation of Response Time Requirements. Accordingly, NextEra is closing this Regulatory Commitment with no further action.

If you have questions or require additional information, please contact Mr. James Costedio at 920/755-7427.

Very truly yours,

NextEra Energy Point Beach, LLC

A handwritten signature in black ink, appearing to read 'Larry Meyer', is written over a horizontal line.

Larry Meyer
Site Vice President

cc: Administrator, Region III, USNRC
Project Manager, Point Beach Nuclear Plant, USNRC
Resident Inspector, Point Beach Nuclear Plant, USNRC
PSCW