

Assumptions in Model:

| | |
|--|--|
| | Switchables |
| | New unit added to the 2010 list |
| | Private use network generation |
| | RMR |
| | New unit with signed interconnect and air permit |
| | Mothballs |
| | Uncertain on technology type |

All four STP units removed from this case.

Mothballs removed from dispatch.

2009 Actual ERCOT load by hour.

New units with signed interconnect and air permit are not included in dispatch.

Gas price used (fuel index price on next tab) is from 2009 State of the Market report.

Unit fuel cost data is from Section 6.8.2.1 of the Zonal Protocols - Resource Category Generic Costs

Start Up costs are not included.

LaaRs, DC Ties and Block Load Transfers were separated by 0.10 heat rates for purposes of this model.

Renewable availability factors are based on the hourly average of the actual wind capacity factors in 2009 (file ERCOT_2009_Hourly_Wind_Output)

Availability factors for all unit types except wind, LaaRs, DC ties and BLTs are from NERC 2005-2009 Generating Availability Reports (EAF).

Distributed generation given a dispatch rank of 12. They are indicated by mnemonic of DG in unit dispatch list.

PUN plants > 300 MW assumed CC greater than 90 MW, i.e., dispatch rank = 5

PUN plants < 300 MW but > 150 assumed CC less than 90 MW, i.e., dispatch rank = 6

PUN plants < 150 MW but > 90 assumed simple cycle greater than 90 MW, i.e., dispatch rank = 9

PUN plants < 90 MW assumed simple cycle less than 90 MW, i.e., dispatch rank = 11

A proxy Block Load Transfer of 1,500 MWs is included.

| Rank | | Tech Type | In service | MW from CDR | Availability Factor | Corrected MWs | Cumulative MWs |
|------|-----------------------------------|-----------|------------|-------------|---------------------|---------------|----------------|
| 1 | 1 Pyron Wind Farm | Wind | 2007 | 249.0 | 0.245 | 61.0 | 61.0 |
| 2 | 1 Buffalo Gap Wind Farm 2 | Wind | 2006 | 233.0 | 0.245 | 57.1 | 118.0 |
| 3 | 1 Horse Hollow Wind 3 | Wind | 2006 | 220.0 | 0.245 | 53.9 | 171.9 |
| 4 | 1 Horse Hollow Wind 1 | Wind | 2007 | 210.0 | 0.245 | 51.4 | 223.4 |
| 5 | 1 Capricorn Ridge Wind 1 | Wind | 2008 | 200.0 | 0.245 | 49.0 | 272.3 |
| 6 | 1 Mesquite Wind | Wind | 2006 | 200.0 | 0.245 | 49.0 | 321.3 |
| 7 | 1 Panther Creek 3 | Wind | 2009 | 200.0 | 0.245 | 49.0 | 370.3 |
| 8 | 1 Penascal Wind | Wind | 2010 | 200.0 | 0.245 | 49.0 | 419.3 |
| 9 | 1 Roscoe Wind Farm | Wind | 2006 | 200.0 | 0.245 | 49.0 | 468.3 |
| 10 | 1 Inadale Wind | Wind | 2006 | 197.0 | 0.245 | 48.2 | 516.5 |
| 11 | 1 Capricorn Ridge Wind 2 | Wind | 2007 | 186.0 | 0.245 | 45.6 | 562.1 |
| 12 | 1 Horse Hollow Wind 4 | Wind | 2006 | 180.0 | 0.245 | 44.1 | 606.2 |
| 13 | 1 Papalote Creek Wind Farm | Wind | 2010 | 180.0 | 0.245 | 44.1 | 650.3 |
| 14 | 1 Turkey Track Wind Energy Center | Wind | 2008 | 170.0 | 0.245 | 41.6 | 691.9 |
| 15 | 1 Hackberry Wind Farm | Wind | 2008 | 165.0 | 0.245 | 40.4 | 732.3 |
| 16 | 1 Notrees-1 | Wind | 2008 | 153.0 | 0.245 | 37.5 | 769.8 |
| 17 | 1 Buffalo Gap Wind Farm 3 | Wind | 2007 | 150.0 | 0.245 | 36.7 | 806.5 |
| 18 | 1 Goat Wind | Wind | 2008 | 150.0 | 0.245 | 36.7 | 843.2 |
| 19 | 1 Langford Wind Power | Wind | 2010 | 150.0 | 0.245 | 36.7 | 880.0 |
| 20 | 1 McAdoo Wind Farm | Wind | 2008 | 150.0 | 0.245 | 36.7 | 916.7 |
| 21 | 1 Sherbino I | Wind | 2008 | 150.0 | 0.245 | 36.7 | 953.5 |
| 22 | 1 Trent Wind Farm | Wind | 1999 | 150.0 | 0.245 | 36.7 | 990.2 |
| 23 | 1 Gulf Wind I | Wind | 2003 | 143.0 | 0.245 | 35.0 | 1025.2 |
| 24 | 1 Panther Creek 1 | Wind | 2008 | 143.0 | 0.245 | 35.0 | 1060.2 |
| 25 | 1 Capricorn Ridge Wind 3 | Wind | 2008 | 140.0 | 0.245 | 34.3 | 1094.5 |
| 26 | 1 Gulf Wind II | Wind | 2008 | 140.0 | 0.245 | 34.3 | 1128.8 |
| 27 | 1 Desert Sky Wind Farm 2 | Wind | 2002 | 135.0 | 0.245 | 33.1 | 1161.9 |
| 28 | 1 Camp Springs 1 | Wind | 2004 | 130.0 | 0.245 | 31.8 | 1193.7 |
| 29 | 1 Sweetwater Wind 4 | Wind | 2004 | 130.0 | 0.245 | 31.8 | 1225.6 |
| 30 | 1 Lorraine Windpark I | Wind | 2009 | 126.0 | 0.245 | 30.9 | 1256.4 |
| 31 | 1 Lorraine Windpark II | Wind | 2009 | 125.0 | 0.245 | 30.6 | 1287.0 |
| 32 | 1 Forest Creek Wind Farm | Wind | 2008 | 124.0 | 0.245 | 30.4 | 1317.4 |
| 33 | 1 Barton Chapel Wind | Wind | 2007 | 120.0 | 0.245 | 29.4 | 1346.8 |
| 34 | 1 Buffalo Gap Wind Farm 1 | Wind | 2006 | 120.0 | 0.245 | 29.4 | 1376.2 |
| 35 | 1 Camp Springs 2 | Wind | 2007 | 120.0 | 0.245 | 29.4 | 1405.6 |
| 36 | 1 Champion Wind Farm | Wind | 2008 | 120.0 | 0.245 | 29.4 | 1435.0 |
| 37 | 1 Stanton Wind Energy | Wind | 2008 | 120.0 | 0.245 | 29.4 | 1464.4 |
| 38 | 1 Sweetwater Wind 7 | Wind | 2007 | 119.0 | 0.245 | 29.1 | 1493.5 |
| 39 | 1 Elbow Creek Wind Project | Wind | 2008 | 117.0 | 0.245 | 28.7 | 1522.2 |
| 40 | 1 Capricorn Ridge Wind 4 | Wind | 2007 | 115.0 | 0.245 | 28.2 | 1550.3 |
| 41 | 1 Horse Hollow Wind 2 | Wind | 2005 | 115.0 | 0.245 | 28.2 | 1578.5 |
| 42 | 1 Panther Creek 2 | Wind | 2008 | 115.0 | 0.245 | 28.2 | 1606.7 |
| 43 | 1 Callahan Wind | Wind | 2004 | 114.0 | 0.245 | 27.9 | 1634.6 |
| 44 | 1 Wolfe Ridge | Wind | 2008 | 113.0 | 0.245 | 27.7 | 1662.2 |
| 45 | 1 Sweetwater Wind 6 | Wind | 2007 | 105.0 | 0.245 | 25.7 | 1688.0 |
| 46 | 1 Penascal Wind | Wind | 2001 | 101.0 | 0.245 | 24.7 | 1712.7 |
| 47 | 1 Penascal Wind | Wind | 2008 | 101.0 | 0.245 | 24.7 | 1737.4 |
| 48 | 1 Nacogdoches Project | Biomass | | 0.0 | 0.245 | 0.0 | 1737.4 |
| 49 | 1 Post Oak Wind 1 | Wind | 2008 | 100.0 | 0.245 | 24.5 | 1761.9 |
| 50 | 1 Post Oak Wind 2 | Wind | 2007 | 100.0 | 0.245 | 24.5 | 1786.4 |
| 51 | 1 Sweetwater Wind 3 | Wind | 2006 | 100.0 | 0.245 | 24.5 | 1810.9 |

| | | | | | | | | |
|-----|----------------------------------|-------------------|---------|------|------|-------|------|--------|
| 52 | 1 Green Mountain Energy 1 | BRAZ_WND_WND1 | Wind | 2008 | 99.0 | 0.245 | 24.2 | 1835.2 |
| 53 | 1 South Trent Wind Farm | STWF_T1 | Wind | 2007 | 98.0 | 0.245 | 24.0 | 1859.2 |
| 54 | 1 Bull Creek Wind Plant | BULLCRK_WND1 | Wind | 2008 | 91.0 | 0.245 | 22.3 | 1881.4 |
| 55 | 1 Sand Bluff Wind Farm | MCDLD_SBW1 | Wind | 2008 | 90.0 | 0.245 | 22.0 | 1903.5 |
| 56 | 1 Bull Creek Wind Plant | BULLCRK_WND2 | Wind | 2008 | 89.0 | 0.245 | 21.8 | 1925.3 |
| 57 | 1 Red Canyon | RDCANYON_RDCNY1 | Wind | 2008 | 84.0 | 0.245 | 20.6 | 1945.9 |
| 58 | 1 Indian Mesa Wind Farm | INDINNWP_INDINNWP | Wind | 2008 | 80.0 | 0.245 | 19.6 | 1965.5 |
| 59 | 1 King Mountain NE | KING_NE_KINGNE | Wind | 2001 | 80.0 | 0.245 | 19.6 | 1985.0 |
| 60 | 1 King Mountain NW | KING_NW_KINGNW | Wind | 2001 | 80.0 | 0.245 | 19.6 | 2004.6 |
| 61 | 1 King Mountain SW | KING_SW_KINGSW | Wind | 2001 | 80.0 | 0.245 | 19.6 | 2024.2 |
| 62 | 1 Pecos Wind (Woodward 1) | WOODWRD1_WOODWRD1 | Wind | 2008 | 80.0 | 0.245 | 19.6 | 2043.8 |
| 63 | 1 Pecos Wind (Woodward 2) | WOODWRD2_WOODWRD2 | Wind | 2001 | 80.0 | 0.245 | 19.6 | 2063.4 |
| 64 | 1 Sweetwater Wind 5 | SWEETWN4_WND5 | Wind | 2005 | 80.0 | 0.245 | 19.6 | 2083.0 |
| 65 | 1 West Texas Wind Energy | SW_MESA_SW_MESA | Wind | 1999 | 70.0 | 0.245 | 17.1 | 2100.2 |
| 66 | 1 Snyder Wind Farm | ENAS_ENA1 | Wind | 2007 | 63.0 | 0.245 | 15.4 | 2115.6 |
| 67 | 1 Green Mountain Energy 2 | BRAZ_WND_WND2 | Wind | 2003 | 61.0 | 0.245 | 14.9 | 2130.5 |
| 68 | 1 Silver Star | FLTCK_SSI | Wind | 2008 | 60.0 | 0.245 | 14.7 | 2145.2 |
| 69 | 1 Whirlwind Energy | WEC_WECG1 | Wind | 1999 | 60.0 | 0.245 | 14.7 | 2159.9 |
| 70 | 1 Ocotillo Wind Farm | OWF_OW | Wind | 2008 | 59.0 | 0.245 | 14.5 | 2174.4 |
| 71 | 1 Lufkin | 08INR0033 | Biomass | 2001 | 0.0 | 0.245 | 0.0 | 2174.4 |
| 72 | 1 King Mountain SE | KING_SE_KINGSE | Wind | 2001 | 43.0 | 0.245 | 10.5 | 2184.9 |
| 73 | 1 Texas Big Spring | SGMTN_SIGNALMT | Wind | 1999 | 40.0 | 0.245 | 9.8 | 2194.7 |
| 74 | 1 Sweetwater Wind 1 | SWEETWND_WND1 | Wind | 2008 | 37.0 | 0.245 | 9.1 | 2203.8 |
| 75 | 1 Kunitz Wind | KUNITZ_WIND_LGE | Wind | 2001 | 35.0 | 0.245 | 8.6 | 2212.3 |
| 76 | 1 Delaware Mountain Wind Farm | DELAWARE_WIND_NWP | Wind | 2001 | 30.0 | 0.245 | 7.3 | 2219.7 |
| 77 | 1 Desert Sky Wind Farm 1 | INDNENR_INDNENR | Wind | 2001 | 25.0 | 0.245 | 6.1 | 2225.8 |
| 78 | 1 Sweetwater Wind 2 | SWEETWN2_WND24 | Wind | 2003 | 16.0 | 0.245 | 3.9 | 2229.7 |
| 79 | 1 Atascocita 1 | _HB_DG1 | Biomass | 2003 | 10.1 | 0.245 | 2.5 | 2232.2 |
| 80 | 1 Covel Gardens LG Power Station | DG_MEDIN_1UNIT | Other | 2005 | 10.0 | 0.245 | 2.4 | 2234.6 |
| 81 | 1 Tessonman Road 1 | DG_WALZE_4UNITS | Biomass | 2003 | 10.0 | 0.245 | 2.4 | 2237.1 |
| 82 | 1 Wolfe Flats | DG_TURL_UNIT1 | Wind | 2007 | 10.0 | 0.245 | 2.4 | 2239.5 |
| 83 | 1 Coastal Plains RDF | _AV_DG1 | Biomass | 2003 | 6.7 | 0.245 | 1.6 | 2241.2 |
| 84 | 1 Austin Landfill Gas | DG_SPRIN_4UNITS | Other | 1988 | 6.4 | 0.245 | 1.6 | 2242.8 |
| 85 | 1 DFW Gas Recovery | DG_BIO2_4UNITS | Biomass | 1980 | 6.4 | 0.245 | 1.6 | 2244.3 |
| 86 | 1 Skyline Landfill Gas | DG_FERIS_4UNITS | Other | 2007 | 6.4 | 0.245 | 1.6 | 2245.9 |
| 87 | 1 RGV Sugar Mill | DG_S_SNR_UNIT1 | Biomass | 1973 | 4.5 | 0.245 | 1.1 | 2247.0 |
| 88 | 1 Baytown 1 | TRN_DG1 | Biomass | 2003 | 3.9 | 0.245 | 1.0 | 2247.9 |
| 89 | 1 Bluebonnet 1 | _LB_DG1 | Biomass | 2003 | 3.9 | 0.245 | 1.0 | 2248.9 |
| 90 | 1 Nelson Gardens Landfill 1 | DG_PEAR_2UNITS | Other | 1990 | 3.6 | 0.245 | 0.9 | 2249.8 |
| 91 | 1 Trinity Oaks LFG | DG_KLBRG_1UNIT | Biomass | 2009 | 3.2 | 0.245 | 0.8 | 2250.6 |
| 92 | 1 TSTC West Texas Wind | DG_ROSCZ_1UNIT | Wind | 2008 | 2.0 | 0.245 | 0.5 | 2251.1 |
| 93 | 2 Denison Dam 1 | DNDAM_DENISOG1 | Hydro | 1944 | 40.0 | 0.860 | 34.4 | 2285.4 |
| 94 | 2 Denison Dam 2 | DNDAM_DENISOG2 | Hydro | 1944 | 40.0 | 0.860 | 34.4 | 2319.8 |
| 95 | 2 Amistad Hydro 1 | AMISTAD_AMISTAG1 | Hydro | 1983 | 38.0 | 0.860 | 32.7 | 2352.5 |
| 96 | 2 Amistad Hydro 2 | AMISTAD_AMISTAG2 | Hydro | 1983 | 38.0 | 0.860 | 32.7 | 2385.2 |
| 97 | 2 Marshall Ford 1 | MARSHFO_MARSHFOG1 | Hydro | 1941 | 36.0 | 0.860 | 31.0 | 2416.1 |
| 98 | 2 Marshall Ford 2 | MARSHFO_MARSHFOG2 | Hydro | 1941 | 36.0 | 0.860 | 31.0 | 2447.1 |
| 99 | 2 Granite Shoals 1 | WIRTZ_WIRTZ_G1 | Hydro | 1951 | 30.0 | 0.860 | 25.8 | 2477.2 |
| 100 | 2 Granite Shoals 2 | WIRTZ_WIRTZ_G2 | Hydro | 1951 | 30.0 | 0.860 | 25.8 | 2503.0 |
| 101 | 2 Marble Falls 1 | MARBFA_MARBFAG1 | Hydro | 1951 | 21.0 | 0.860 | 18.1 | 2546.8 |
| 102 | 2 Marble Falls 2 | MARBFA_MARBFAG2 | Hydro | 1951 | 21.0 | 0.860 | 18.1 | 2564.9 |
| 103 | 2 Buchanan 1 | BUCHAN_BUCHANG1 | Hydro | 1938 | 18.0 | 0.860 | 15.5 | 2580.4 |

| | | | | | | | | |
|-----|----------------------------|--------------------|---------|------|--------|-------|--------|---------|
| 105 | 2 Buchanan 2 | BUCHAN_BUCHANG2 | Hydro | 1938 | 18.0 | 0.860 | 15.5 | 2595.8 |
| 106 | 2 Buchanan 3 | BUCHAN_BUCHANG3 | Hydro | 1950 | 18.0 | 0.860 | 15.5 | 2611.3 |
| 107 | 2 Whitney 1 | WND_WHITNEY1 | Hydro | 1953 | 15.0 | 0.860 | 12.9 | 2624.2 |
| 108 | 2 Whitney 2 | WND_WHITNEY2 | Hydro | 1953 | 15.0 | 0.860 | 12.9 | 2637.1 |
| 109 | 2 Inks 1 | INKSDA_INKS_G1 | Hydro | 1938 | 14.0 | 0.860 | 12.0 | 2649.1 |
| 110 | 2 Falcon Hydro 1 | FALCON_FALCONG1 | Hydro | 1954 | 12.0 | 0.860 | 10.3 | 2659.5 |
| 111 | 2 Falcon Hydro 2 | FALCON_FALCONG2 | Hydro | 1954 | 12.0 | 0.860 | 10.3 | 2669.8 |
| 112 | 2 Falcon Hydro 3 | FALCON_FALCONG3 | Hydro | 1954 | 12.0 | 0.860 | 10.3 | 2680.1 |
| 113 | 2 Morris Sheppard | MSP_MSP_1 | Hydro | 1942 | 12.0 | 0.860 | 10.3 | 2690.4 |
| 114 | 2 Morris Sheppard | MSP_MSP_2 | Hydro | 1942 | 12.0 | 0.860 | 10.3 | 2700.7 |
| 115 | 2 Austin 2 | AUSTPL_AUSTING2 | Hydro | 1940 | 9.0 | 0.860 | 7.7 | 2708.5 |
| 116 | 2 Austin 1 | AUSTPL_AUSTING1 | Hydro | 1940 | 8.0 | 0.860 | 6.9 | 2715.3 |
| 117 | 2 McQueeney (Abbott) | DG_MCQUE_5UNITS | Hydro | 1927 | 8.0 | 0.860 | 6.9 | 2722.2 |
| 118 | 2 Dunlop (Schumannville) 1 | DG_SCHUM_2UNITS | Hydro | 1927 | 3.6 | 0.860 | 3.1 | 2725.3 |
| 119 | 2 Canyon 1 | CANYHY_CANYHYG1 | Hydro | 1989 | 3.0 | 0.860 | 2.6 | 2727.9 |
| 120 | 2 Canyon 2 | CANYHY_CANYHYG2 | Hydro | 1989 | 3.0 | 0.860 | 2.6 | 2730.5 |
| 121 | 2 Lewisville 1 | DG_LWSVL_1UNIT | Hydro | 1992 | 2.8 | 0.860 | 2.4 | 2732.9 |
| 122 | 2 Eagle Pass 1 | EAGLE_HY_EAGLE_HY1 | Hydro | 1954 | 2.0 | 0.860 | 1.7 | 2734.6 |
| 123 | 2 Eagle Pass 2 | EAGLE_HY_EAGLE_HY2 | Hydro | 1954 | 2.0 | 0.860 | 1.7 | 2736.3 |
| 124 | 2 Eagle Pass 3 | EAGLE_HY_EAGLE_HY3 | Hydro | 1954 | 2.0 | 0.860 | 1.7 | 2738.0 |
| 125 | 2 Small Hydro of Texas 1 | CUECPT_UNIT1 | Hydro | 1992 | 1.0 | 0.860 | 0.9 | 2738.9 |
| 126 | 3 South Texas 1 | STP_STP_G1 | Nuclear | 1988 | 0.0 | 0.885 | 0.0 | 2738.9 |
| 127 | 3 South Texas 2 | STP_STP_G2 | Nuclear | 1989 | 0.0 | 0.885 | 0.0 | 2738.9 |
| 128 | 3 STP 3 | | Nuclear | | 0 | 0.885 | 0.0 | 2738.9 |
| 129 | 3 STP 4 | | Nuclear | | 0 | 0.885 | 0.0 | 2738.9 |
| 130 | 3 Comanche Peak 1 | CPSES_UNIT1 | Nuclear | 1990 | 1209.0 | 0.885 | 1070.4 | 3809.4 |
| 131 | 3 Comanche Peak 2 | CPSES_UNIT2 | Nuclear | 1993 | 1158.0 | 0.885 | 1025.3 | 4834.6 |
| 132 | 4 Sandy Creek 1 | 09INR0001 | Coal | | 0.0 | 0.842 | 0.0 | 4834.6 |
| 133 | 4 Limestone 2 | LEG_LEG_G2 | Coal | 1986 | 858.0 | 0.842 | 722.4 | 5557.0 |
| 134 | 4 Limestone 1 | LEG_LEG_G1 | Coal | 1985 | 831.0 | 0.842 | 699.6 | 6256.6 |
| 135 | 4 Martin Lake 3 | MLSES_UNIT3 | Coal | 1979 | 818.0 | 0.842 | 688.7 | 6945.3 |
| 136 | 4 Martin Lake 1 | MLSES_UNIT1 | Coal | 1977 | 800.0 | 0.842 | 673.5 | 7618.8 |
| 137 | 4 Martin Lake 2 | MLSES_UNIT2 | Coal | 1978 | 800.0 | 0.842 | 673.5 | 8292.3 |
| 138 | 4 Oak Grove SES Unit 2 | OGSES_UNIT2 | Coal | 2009 | 796.0 | 0.842 | 670.2 | 8962.5 |
| 139 | 4 Oak Grove SES Unit 1 | OGSES_UNIT1 | Coal | 2009 | 785.0 | 0.842 | 660.9 | 9623.4 |
| 140 | 4 J K Spruce 2 | CALAVERS_JKS2 | Coal | 2009 | 772.0 | 0.842 | 649.9 | 10273.3 |
| 141 | 4 Monticello 3 | MNSESES_UNIT3 | Coal | 1978 | 765.0 | 0.842 | 644.1 | 10917.4 |
| 142 | 4 Coletto Creek Unit 2 | 14INR0002 | Coal | | 0.0 | 0.842 | 0.0 | 10917.4 |
| 143 | 4 Oklaunion 1 | OKLA_OKLA_G1 | Coal | 1986 | 650.0 | 0.842 | 547.2 | 11464.6 |
| 144 | 4 W A Parish 6 | WAP_WAP_G6 | Coal | 1978 | 650.0 | 0.842 | 547.2 | 12011.8 |
| 145 | 4 W A Parish 5 | WAP_WAP_G5 | Coal | 1977 | 645.0 | 0.842 | 543.0 | 12554.9 |
| 146 | 4 Coletto Creek | COLETO_COLETOG1 | Coal | 1980 | 632.0 | 0.842 | 532.1 | 13086.9 |
| 147 | 4 Big Brown 1 | BBSES_UNIT1 | Coal | 1971 | 617.0 | 0.842 | 519.5 | 13606.4 |
| 148 | 4 Big Brown 2 | BBSES_UNIT2 | Coal | 1972 | 615.0 | 0.842 | 517.8 | 14124.2 |
| 149 | 4 Fayette Power Project 1 | FPYPD1_FPP_G1 | Coal | 1979 | 608.0 | 0.842 | 511.9 | 14636.0 |
| 150 | 4 Fayette Power Project 2 | FPYPD1_FPP_G2 | Coal | 1980 | 608.0 | 0.842 | 511.9 | 15147.9 |
| 151 | 4 W A Parish 8 | WAP_WAP_G8 | Coal | 1982 | 600.0 | 0.842 | 505.1 | 15653.1 |
| 152 | 4 Monticello 1 | MNSESES_UNIT1 | Coal | 1974 | 583.0 | 0.842 | 490.8 | 16143.9 |
| 153 | 4 Monticello 2 | MNSESES_UNIT2 | Coal | 1975 | 583.0 | 0.842 | 490.8 | 16634.7 |
| 154 | 4 W A Parish 7 | WAP_WAP_G7 | Coal | 1980 | 565.0 | 0.842 | 475.7 | 17110.4 |
| 155 | 4 Sandow 5 | SDSES_UNIT5 | Coal | 2009 | 560.0 | 0.842 | 471.5 | 17581.9 |
| 156 | 4 J K Spruce 1 | CALAVERS_JKS1 | Coal | 1992 | 555.0 | 0.842 | 467.3 | 18049.1 |
| 157 | 4 Gibbons Creek 1 | GIBCRK_GIB_CRG1 | Coal | 1982 | 470.0 | 0.842 | 395.7 | 18444.8 |

| | | | | | | | | | | | | | | | | | | | | |
|------------|------|------|------|------|------|-------|------|------|------|-------|------|------|-----|-----------|------------------------------------|---|----|-------|----|-----------|
| 12/31/2009 | 2200 | 1386 | 1041 | 8354 | 1117 | 13448 | 5084 | 1206 | 2496 | 34132 | 2300 | 1150 | 500 | 38082 | 264 Frontera 2 | 5 | \$ | 33.66 | \$ | 0.0038144 |
| 12/31/2009 | 2300 | 1342 | 974 | 8068 | 1108 | 13089 | 4796 | 1203 | 2641 | 33223 | 2300 | 1150 | 500 | 37173 | 257 Guadalupe Generating Station 4 | 5 | \$ | 33.66 | \$ | 0.0037233 |
| 12/31/2009 | 2400 | 1311 | 953 | 7870 | 1087 | 12832 | 4672 | 1197 | 2639 | 32561 | 2300 | 1150 | 500 | 36511 | 252 Bastrop Energy Center 1 | 5 | \$ | 33.66 | \$ | 0.0036570 |
| Total | | | | | | | | | | | | | | 336053224 | | | | | | 37.86 |