



Progress Energy

Serial: NPD-NRC-2011-038
May 4, 2011

U.S. Nuclear Regulatory Commission
Attention: Document Control Desk
Washington, D.C. 20555-0001

**LEVY NUCLEAR PLANT, UNITS 1 AND 2
DOCKET NOS. 52-029 AND 52-030
FINAL SAFETY ANALYSIS REPORT CHAPTER 14 – CORRECTIONS TO CONFORMANCE
WITH STANDARD CONTENT OF THE VOGTLE R-COLA**

Reference: Letter from B. L. Ivey (Southern Nuclear Operating Company, Inc. [SNC]) to U.S. Nuclear Regulatory Commission (NRC), dated January 31, 2011, "Submittal 7 of the Application", ND-11-0183

Ladies and Gentlemen:

Progress Energy Florida, Inc. (PEF) hereby submits corrections for conformance with standard content of the Vogtle R-COLA, as shown in Reference 1, for the Levy Nuclear Plant Units 1 and 2 (LNP) FSAR Chapter 14:

1. FSAR Subsection 14.2.3.1.2, Work Control, should have a Left Margin Annotation (LMA) of STD SUP 14.2-5.
2. FSAR Subsection 14.2.3.1.3, System Turnover, should have a LMA of STD SUP 14.2-6.
3. FSAR Subsection 14.2.3.1.4, Conduct of Modifications During the Initial Test Program, should have a LMA of STD SUP 14.2-7.
4. FSAR Subsection 14.2.3.1.5, Conduct of Maintenance During the Initial Test Program, should have a LMA of STD SUP 14.2-8.
5. FSAR Subsection 14.2.3.2.1, Review and Approval Responsibilities (STD COL 14.4-4), the third paragraph should be revised to site-specific content with a LMA of LNP COL 14.4-4 to reflect the replacement of the generic title of plant manager with the Levy-specific title of VP-Levy Nuclear Plant in the last sentence of the paragraph.
6. FSAR Subsection 14.2.9.4.24, Raw Water System (STD COL 14.4-5), should be revised to site-specific content with a LMA of LNP COL 14.4-5. In the portion of the subsection dealing with General Test Methods and Acceptance Criteria, Levy Nuclear Plant does not include heat tracing on the raw water system piping, thus the subparagraph c. in the R-COLA subsection regarding component and integrated system tests has been deleted for Levy.

7. FSAR Subsection 14.2.10.4.29, Cooling Tower(s), should have a LMA of STD COL 14.4-5.
8. FSAR Subsection 14.3.3.3, Turbine Building, Radwaste Building, and Annex Building Drilled Shafts ITAAC, should have a LMA of LNP SUP 14.3-4.


These corrections will be made in a future revision of the LNP application.

If you have any further questions, or need additional information, please contact Bob Kitchen at (919) 546-6992, or me at (727) 820-4481.

I declare under penalty of perjury that the foregoing is true and correct.

Executed on May 4, 2011.

Sincerely,

A handwritten signature in black ink, appearing to read 'John Elnitsky', with a long horizontal flourish extending to the right.

John Elnitsky
Vice President
New Generation Programs & Projects

cc : U.S. NRC Region II, Regional Administrator
Mr. Brian C. Anderson, U.S. NRC Project Manager
Mr. Thomas Galletta, U.S. NRC Project Manager