

CCNPP3COLA PEmails

From: Steckel, James
Sent: Wednesday, March 30, 2011 1:16 PM
To: Arora, Surinder
Cc: CCNPP3COL Resource
Subject: FW: INQUIRY: CCNPP3 FSAR Ch. 2, RAI 192, Question 02.03.02-10

David Brown is requesting a telecom with UniStar on an update the FSAR that has yet to be provided. Can we accommodate his request?

Jim

James Steckel
Project Manager
NRC EPR Projects Branch
301 415-1026
james.steckel@nrc.gov

From: Brown, David
Sent: Wednesday, March 30, 2011 12:37 PM
To: Steckel, James
Cc: Schaaf, Robert; Tammara, Seshagiri; Sisk, David
Subject: INQUIRY: CCNPP3 FSAR Ch. 2, RAI 192, Question 02.03.02-10

Jim,

Rao and I have updated Section 2.1-2.3 of the CCNPP3 SER to reflect resolution of open items and confirmatory items. All open and confirmatory items except one confirmatory item in SER Sec. 2.3.2.4.2 are now resolved. In its July 28, 2008, response to RAI 192, Question 02.03.02-10, the applicant committed to update the FSAR to reflect the use of higher efficiency drift eliminators on the CWS cooling tower, and higher cycles of concentration in the ESWS cooling towers. The applicant still hasn't provided this update.

Can we set up a phone call with the applicant to ask about the status of this update?

Dave

Hearing Identifier: CalvertCliffs_Unit3Cola_Public_EX
Email Number: 1868

Mail Envelope Properties (AF843158D8D87443918BD3AA953ABF781D269ED061)

Subject: FW: INQUIRY: CCNPP3 FSAR Ch. 2, RAI 192, Question 02.03.02-10
Sent Date: 3/30/2011 1:15:33 PM
Received Date: 3/30/2011 1:15:35 PM
From: Steckel, James

Created By: James.Steckel@nrc.gov

Recipients:
"CCNPP3COL Resource" <CCNPP3COL.Resource@nrc.gov>
Tracking Status: None
"Arora, Surinder" <Surinder.Arora@nrc.gov>
Tracking Status: None

Post Office: HQCLSTR02.nrc.gov

Files	Size	Date & Time
MESSAGE	1164	3/30/2011 1:15:35 PM

Options
Priority: Standard
Return Notification: No
Reply Requested: No
Sensitivity: Normal
Expiration Date:
Recipients Received: