

SeabrookNPEM Resource

From: Cliche, Richard [Richard.Cliche@fpl.com]
Sent: Monday, May 16, 2011 8:16 AM
To: Wentzel, Michael
Subject: Treated Borated Water Slide
Attachments: image001.png



Revision to License Renewal Guidance

Treated Borated Water (SER Sections 3.2.2.1.X and 3.3.2.1.Y)

- The staff is developing interim staff guidance to update the GAIL Report on aging management of treated borated water.
- Boron is no longer credited as being a corrosion inhibitor, and one-time inspections are recommended to verify the effectiveness of the Water Chemistry Program to manage loss of material and cracking in treated borated water that is not deoxygenated.
- Affected systems at Salem include the spent fuel pool systems, containment spray system, portions of the ECCS, and others.
- The applicant submitted a draft LRA supplement that:
 - Adds the One-Time Inspection Program to verify the effectiveness of the Water Chemistry Program to cover 110 line items
 - Updated the description of the One-Time Inspection Program and the Water Chemistry Program and one commitment in the UFSAR supplement
- The staff finds this acceptable and will update the SER

12

Rick Cliche

License Renewal Project Manager

Seabrook Station

richard.cliche@fpl.com

Desk: (603) 773-7003

Fax: (603) 773-7995

Cell: (603) 765-6358

Hearing Identifier: Seabrook_License_Renewal_NonPublic
Email Number: 1303

Mail Envelope Properties (2B617A8F06E7124F9D8C7AE069F68EF91A65F40698)

Subject: Treated Borated Water Slide
Sent Date: 5/16/2011 8:16:00 AM
Received Date: 5/16/2011 8:16:05 AM
From: Cliche, Richard

Created By: Richard.Cliche@fpl.com

Recipients:
"Wentzel, Michael" <Michael.Wentzel@nrc.gov>
Tracking Status: None

Post Office: GOXEXVS04.fplu.fpl.com

Files	Size	Date & Time
MESSAGE	194	5/16/2011 8:16:05 AM
image001.png	15355	

Options
Priority: Standard
Return Notification: No
Reply Requested: No
Sensitivity: Normal
Expiration Date:
Recipients Received:

