



UNITED STATES  
NUCLEAR REGULATORY COMMISSION  
WASHINGTON, D.C. 20555-0001

June 8, 2011

LICENSEE: Energy Northwest

FACILITY: Columbia Generating Station

SUBJECT: SUMMARY OF TELEPHONE CONFERENCE CALL HELD ON MAY 6, 2011, BETWEEN THE U.S. NUCLEAR REGULATORY COMMISSION AND ENERGY NORTHWEST, CONCERNING THE DRAFT REQUEST FOR ADDITIONAL INFORMATION PERTAINING TO THE COLUMBIA GENERATING STATION, LICENSE RENEWAL APPLICATION (TAC NO. ME3058)

The U.S. Nuclear Regulatory Commission (NRC or the staff) and representatives of Energy Northwest (the applicant), held a telephone conference call on May 6, 2011, to discuss and clarify the NRC's draft request for additional information (RAI) concerning the Columbia Generating Station, license renewal application.

Enclosure 1 provides a listing of the participants and Enclosure 2 contains a listing of the RAIs discussed with the applicant, including a brief description on the status of the items.

The applicant had an opportunity to comment on this summary.

A handwritten signature in black ink that reads "Arthur Cunanan".

Arthur D. Cunanan, Project Manager  
Projects Branch 1  
Division of License Renewal  
Office of Nuclear Reactor Regulation

Docket No. 50-397

Enclosures:  
As stated

cc w/encls: Listserv

TELEPHONE CONFERENCE CALL  
COLUMBIA GENERATING STATION LICENSE RENEWAL APPLICATION  
LIST OF PARTICIPANTS  
MAY 6, 2011

**PARTICIPANTS:**

Arthur Cunanan  
Chris Sydnor  
Abbas Mostala  
Janet Worthington  
Scott Wood

**AFFILIATIONS:**

U.S. Nuclear Regulatory Commission (NRC)  
NRC  
Energy Northwest (EN)  
EN  
EN

TELEPHONE CONFERENCE CALL  
COLUMBIA GENERATING STATION  
LICENSE RENEWAL APPLICATIONS  
MAY 6, 2011

The U.S. Nuclear Regulatory Commission (NRC or the staff) and representatives of Energy Northwest, held a telephone conference call on May 6, 2011, to discuss the following draft request for additional information (RAI) concerning the Columbia Generating Station (CGS) license renewal application (LRA).

D-RAI B.2.10-2 is related to the BWR Vessel Internals Program, specifically, BWRVIP-25 action items.

**Discussion:**

The applicant discovered that there are no core plate wedges located around the periphery of the core plate within the shroud. The applicant submitted its LRA on January 19, 2010, and stated that Columbia had core plate wedges installed around the periphery of the core plate within the shroud. The applicant also discussed submitting a letter informing the staff about the deviation from BWRVIP-25 inspection requirements.

The staff discussed changes to the boiling water reactor vessel internals program (BWRVIP) and other changes in the LRA that will be affected as a result of the applicant's recent statement on the core plate wedges.

The applicant understands the RAI and will provide a response.

The staff will issue the RAI.

June 8, 2011

LICENSEE: Energy Northwest

FACILITY: Columbia Generating Station

SUBJECT: SUMMARY OF TELEPHONE CONFERENCE CALL HELD ON MAY 6, 2011, BETWEEN THE U.S. NUCLEAR REGULATORY COMMISSION AND ENERGY NORTHWEST, CONCERNING THE DRAFT REQUEST FOR ADDITIONAL INFORMATION PERTAINING TO THE COLUMBIA GENERATING STATION, LICENSE RENEWAL APPLICATION (TAC NO. ME3058)

The U.S. Nuclear Regulatory Commission (NRC or the staff) and representatives of Energy Northwest (the applicant), held a telephone conference call on May 6, 2011, to discuss and clarify the NRC's draft request for additional information (RAI) concerning the Columbia Generating Station, license renewal application.

Enclosure 1 provides a listing of the participants and Enclosure 2 contains a listing of the RAIs discussed with the applicant, including a brief description on the status of the items.

The applicant had an opportunity to comment on this summary.

*/RA/*

Arthur D. Cunanan, Project Manager  
Projects Branch 1  
Division of License Renewal  
Office of Nuclear Reactor Regulation

Docket No. 50-397

Enclosures:  
As stated

cc w/encls: Listserv

DISTRIBUTION:  
See next page

**ADAMS Accession Number: ML11137A044**

<b>OFFICE</b>	LA: DLR	PM: DLR/RPB1	BC: DLR/RPB1	PM: DLR/RPB1
<b>NAME</b>	YEdmonds	ACunanan	BPham	ACunanan
<b>DATE</b>	05/24/2011	05/26/2011	06/08/2011	06/08/2011

**OFFICIAL RECORD COPY**

Letter to Energy Northwest from Arthur D. Cunanan dated June 08, 2011

**SUBJECT: SUMMARY OF TELEPHONE CONFERENCE CALL HELD ON MAY 6, 2011, BETWEEN THE U.S. NUCLEAR REGULATORY COMMISSION AND ENERGY NORTHWEST, CONCERNING THE DRAFT REQUEST FOR ADDITIONAL INFORMATION PERTAINING TO THE COLUMBIA GENERATING STATION, LICENSE RENEWAL APPLICATION (TAC NO. ME3058)**

**DISTRIBUTION:**

**HARD COPY:**

DLR R/F

**E-MAIL:**

PUBLIC

RidsNrrDir Resource

RidsNrrDirRpb1 Resource

RidsNrrDirRpb2 Resource

RidsNrrDirRarb Resource

RidsNrrDirRapb Resource

RidsNrrDirRasb Resource

RidsNrrDirRerb Resource

RidsNrrDirRpob Resource

-----  
ACunanan

DDoyle

MThadani

WWalker, RIV

RCohen, RIV

LSubin, OGC