

CCNPP3COLA PEmails

From: Steckel, James
Sent: Monday, May 09, 2011 12:50 PM
To: CCNPP3COL Resource
Subject: FW: RAI clarification call

James Steckel
Project Manager
NRC EPR Projects Branch
301 415-1026
james.steckel@nrc.gov

From: Steckel, James
Sent: Monday, May 09, 2011 12:41 PM
To: 'Poche, Robert'; Arora, Surinder
Subject: RE: RAI clarification call

A telecon was held on May 3, 2011, to discuss draft RAI 307 (eRAI 5741) on Calvert Cliffs Nuclear Power Plant Unit 3 COL application Section 2.5.4, Stability of Subsurface Materials and Foundations. Attendees included representatives from UniStar, Paul Rizzo Associates, AREVA, and NRC, shown in the following table:

UniStar	Paul Rizzo Asso.	AREVA	NRC
Rob Poche	Paul Rizzo	Todd Oswald	Weijun Wang
Steve Strout	Mike Edwards	Kelli Voelsing	James Steckel
Jay Leininger	Oner Tastan	Darrell Gardner	Surinder Arora
Oliver Mallet			
Antonio Fernandez			

Draft RAI 307, Question 02.05.04-31, was prepared as a follow up to RAI 268, Questions 02.05.04-26 and 02.05.04-27. The purpose of the call was to clarify the intent of the three parts of Question 02.05.04-31. The clarification discussion included the following:

1. The determination method for consolidation property parameters
2. How the anticipated actual settlement is aligned with the U.S. EPR DCD, and how the settlement will coincide with construction sequencing
3. Measurement of building basemat settlement differential values, and justification for use of pseudo-elastic analysis

At the completion of the telecon, UniStar agreed with the scope of the draft questions and made no request for revision of the draft RAI. UniStar agreed that the RAI could be sent as final.

James Steckel
Project Manager
NRC EPR Projects Branch
301 415-1026
james.steckel@nrc.gov

From: Poche, Robert [<mailto:robert.poche@unistarnuclear.com>]
Sent: Tuesday, May 03, 2011 4:12 PM

To: Arora, Surinder; Steckel, James

Subject: RAI clarification call

Mr. Arora,

The following individuals were on the RAI 307 clarification teleconference representing UniStar:

UniStar

Rob Poche

Steve Strout

Jay Leininger

Olivier Mallet

Antonio Fernandez

Paul Rizzo Associates

Paul Rizzo

Mike Edwards

Oner Tastan

AREVA

Todd Oswald

Kelli Voelsing

Darrell Gardner

Robert Poche

Regulatory Affairs Project Manager

Calvert Cliffs Nuclear Power Plant Unit 3

(410) 470-5530 Office

(509) 528-5513 Cell

robert.poche@unistarnuclear.com

rpoche1@aol.com

Disclaimer: This e-mail and any attachments are confidential, may contain legal, professional or other privileged information, and are intended solely for the addressee. If you are not the intended recipient, do not use the information in this e-mail in any way, delete this e-mail and notify the sender.

Hearing Identifier: CalvertCliffs_Unit3Cola_Public_EX
Email Number: 1916

Mail Envelope Properties (AF843158D8D87443918BD3AA953ABF781D38918CE6)

Subject: FW: RAI clarification call
Sent Date: 5/9/2011 12:49:46 PM
Received Date: 5/9/2011 12:49:48 PM
From: Steckel, James

Created By: James.Steckel@nrc.gov

Recipients:
"CCNPP3COL Resource" <CCNPP3COL.Resource@nrc.gov>
Tracking Status: None

Post Office: HQCLSTR02.nrc.gov

Files	Size	Date & Time
MESSAGE	3066	5/9/2011 12:49:48 PM

Options
Priority: Standard
Return Notification: No
Reply Requested: No
Sensitivity: Normal
Expiration Date:
Recipients Received: