



UNITED STATES
NUCLEAR REGULATORY COMMISSION
WASHINGTON, D.C. 20555-0001

May 23, 2011

Mr. David J. Bannister
Vice President and CNO
Omaha Public Power District
Fort Calhoun Station
444 South 16th St. Mall
Omaha, NE 68102-2247

SUBJECT: FORT CALHOUN STATION, UNIT NO. 1 – CLOSEOUT OF GENERIC LETTER 2008-01, “MANAGING GAS ACCUMULATION IN EMERGENCY CORE COOLING, DECAY HEAT REMOVAL, AND CONTAINMENT SPRAY SYSTEMS” (TAC NO. MD7829)

Dear Mr. Bannister:

On January 11, 2008, the U.S. Nuclear Regulatory Commission (NRC) issued Generic Letter (GL) 2008-01, “Managing Gas Accumulation in Emergency Core Cooling, Decay Heat Removal, and Containment Spray Systems” (Agencywide Documents Access and Management System (ADAMS) Accession No. ML072910759). The stated purpose of GL 2008-01 was (a) to request addressees to submit information to demonstrate that the subject systems are in compliance with the current licensing and design bases and applicable regulatory requirements, and that suitable design, operational, and testing control measures are in place for maintaining this compliance; and (b) to collect the requested information to determine if additional regulatory action is required.

GL 2008-01 requested that licensees provide the following information within 9 months of the date of the GL:

- (a) A description of the results of evaluations that were performed pursuant to requested actions [specified in the GL]. This description should provide sufficient information to demonstrate that you are or will be in compliance with the quality assurance criteria in Sections III, V, XI, XVI, and XVII of Appendix B to 10 CFR Part 50 and the licensing basis and operating license as those requirements apply to the subject systems;
- (b) A description of all corrective actions, including plant, programmatic, procedure, and licensing basis modifications that you determined were necessary to assure compliance with these regulations; and,
- (c) A statement regarding which corrective actions were completed, the schedule for completing the remaining corrective actions, and the basis for that schedule.


By letters dated October 14, 2008, and August 10, 2010 (ADAMS Accession No. ML082890096 and ML102230074, respectively) Omaha Public Power District (the licensee) provided

information in response to the GL for Fort Calhoun Station, Unit 1. The NRC staff has reviewed the submitted information and has concluded that the licensee has acceptably addressed each request.

Consequently, your GL response is considered closed and no further information or action is requested of you with the exception of any commitments you have made with respect to the GL responses. Notwithstanding, the NRC's Region IV staff may decide to perform, and would contact you to schedule, an inspection using Temporary Instruction (TI) 2515/177, "Managing Gas Accumulation in Emergency Core Cooling, Decay Heat Removal, and Containment Spray Systems (NRC Generic Letter 2008-01)" (ADAMS Accession No. ML082950666). The TI 2515/177 is confirmatory in nature in that it directs NRC inspectors to selectively verify that the licensee has implemented, or is in the process of acceptably implementing, the commitments, modifications, and programmatically controlled actions described in the licensee's response to GL 2008-01 and the plant-specific information supports a conclusion that subject systems operability is reasonably ensured.

If you have any questions, please contact me at 301-415-1377 or via e-mail at lynnea.wilkins@nrc.gov.

Sincerely,

A handwritten signature in black ink, appearing to read "Lynnea Wilkins". The signature is fluid and cursive, with a large initial "L" and "W".

Lynnea E. Wilkins, Project Manager
Plant Licensing Branch IV
Division of Operating Reactor Licensing
Office of Nuclear Reactor Regulation

Docket No. 50-285

cc: Distribution via Listserv

D. Bannister

- 2 -

information in response to the GL for Fort Calhoun Station, Unit 1. The NRC staff has reviewed the submitted information and has concluded that the licensee has acceptably addressed each request.

Consequently, your GL response is considered closed and no further information or action is requested of you with the exception of any commitments you have made with respect to the GL responses. Notwithstanding, the NRC's Region IV staff may decide to perform, and would contact you to schedule, an inspection using Temporary Instruction (TI) 2515/177, "Managing Gas Accumulation in Emergency Core Cooling, Decay Heat Removal, and Containment Spray Systems (NRC Generic Letter 2008-01)" (ADAMS Accession No. ML082950666). The TI 2515/177 is confirmatory in nature in that it directs NRC inspectors to selectively verify that the licensee has implemented, or is in the process of acceptably implementing, the commitments, modifications, and programmatically controlled actions described in the licensee's response to GL 2008-01 and the plant-specific information supports a conclusion that subject systems operability is reasonably ensured.

If you have any questions, please contact me at 301-415-1377 or via e-mail at lynnea.wilkins@nrc.gov.

Sincerely,

/RA/

Lynnea E. Wilkins, Project Manager
Plant Licensing Branch IV
Division of Operating Reactor Licensing
Office of Nuclear Reactor Regulation

Docket No. 50-285

cc: Distribution via Listserv

DISTRIBUTION:

PUBLIC
LPL4 R/F
RidsAcrcsAcnw_MailCTR Resource
RidsNrrDorlDpr Resource
RidsNrrDorlLpl4 Resource
RidsNrrDssSrxb Resource

RidsNrrLAJBurkhardt Resource
RidsNrrPMFortCalhoun Resource
RidsOgcRp
RidsRgn4MailCenter Resource
JMiller, NRR/DSS/SRXB

ADAMS Accession No. ML111400133

***by memo dated**

OFFICE	NRR/LPL4/PM	NRR/LPL4/LA	NRR/DSS/SRXB/BC	NRR/LPL4/BC	NRR/LPL4/PM
NAME	LWilkins	JBurkhardt	AUises*	MMarkley	LWilkins (NKalyanam for)
DATE	5/20/11	5/20/11	5/3/11	5/23/11	5/23/11

OFFICIAL RECORD COPY