2010 PALISADES NUCLEAR PLANT

INITIAL EXAMINATION

AS-ADMINISTERED EXAM FILES

ADMINISTRATIVE JPMs

NRC REGION III INITIAL LICENSE EXAM JOB PERFORMANCE MEASURE

JPM: RO ADMIN 1a

TITLE: DETERMINE QUADRANT POWER TILT PER PO-3

CANDIDATE: _____

EXAMINER:

JOB PERFORMANCE MEASURE DATA PAGE

Task: Determine	Quadrant Power Tilt per PO-3	
Alternate Path: N	N/A	
Facility JPM #: F	PL-OPS-ENG-014J	
K/A: G2.1.7	Importance: RO: 4.4 SRO: 4.7	
K/A Statement: A b ir	Ability to evaluate plant performance and make operational jud based on operating characteristics, reactor behavior, and instru interpretation.	lgments ument
Task Standard: F F	Four NI Power readings recorded within ± 1% of key and Quad Power Tilt calculated correctly per PO-3	Irant
Preferred Evaluat	ation Location: SimulatorX In Plant	
Preferred Evaluat	ation Method: PerformX_ Simulate	
References: F	PO-3, "Alternate Incore and Excore Applications"	
Validation Time:	12 minutes Time Critical: NO	
Candidate:		
Time Start:	Time Finish:	
Performance Tim	ne: minutes	
Performance Rat	ting: SAT UNSAT	
Comments:		
Examiner:	Date:	

AUGUST 2010

EXAMINER COPY ONLY

Tools/Equipment/Procedures Needed:

PO-3, "Alternate Incore and Excore Applications," Attachment 2

Also see **Simulator Operator Instructions** (last page of this document).

READ TO CANDIDATE

DIRECTION TO CANDIDATE:

I will explain the initial conditions, and state the task to be performed. All control room steps shall be performed for this JPM, including any required communications. I will provide initiating cues and reports on other actions when directed by you. Ensure you indicate to me when you understand your assigned task. To indicate that you have completed your assigned task return the handout sheet I provided you.

INITIAL CONDITIONS:

- Plant was at full power.
- Incores #9 and #35 are inoperable.
- Control Rod #11 has dropped into the core.

INITIATING CUES:

During performance of PO-3, Alternate Incore and Excore Applications, the Control Room Supervisor directs you to calculate Excore Quadrant Power Tilt utilizing Power Range NI Channels on Panel C-06.

EVALUATOR CUE: Provide candidate with a working copy of PO-3, Attachment 2.

Proc. Step	TASK ELEMENT 1	STANDARD	Grade
5.2.1	Obtain lower and upper excore readings as required. (S_{AL} , S_{BL} , S_{CL} , S_{DL} and S_{AU} , S_{BU} , S_{CU} , S_{DU}).	Lower and upper excore readings from the Upper and Lower NI Detector meters on EC-06 are entered on PO-3, Attachment 2, within \pm 1% of the answer key.	SU
Comment	STEP		
CRITICA			

Proc. Step	TASK ELEMENT 2	STANDARD	Grade
5.2.1	Calculate the sum from the Lower + Upper excore readings (S_A, S_B, S_C, S_D)	Lower + Upper excore readings (S_A , S_B , S_C , S_D) summed and entered on PO-3, Attachment #2, within ±1% of the answer key.	SU
Comment	STEP		

Proc. Step	TASK ELEMENT 3	STANDARD	Grade
5.2.1	 Calculate the sum of all excore readings divided by 4: (S = Σ all detectors/4). 	Sum of all excores reading divided by 4 calculated and entered on PO-3, Attachment 2.	ទប
Comment CRITICA	STEP		

Proc. Step	TASK ELEMENT 4	STANDARD	Grade			
5.2.1	Calculate the Quadrant Tilt.	Using the formula $T_{EX} = [(S_X - S)/S]$, calculate the tilt for each Quadrant.	SU			
Comment: EVALUATOR NOTE: Acceptance criteria are all four Quadrant Tilts should add						
up to approximately zero (0). CRITICAL STEP						

Proc. Step	TASK ELEMENT 5	STANDARD	Grade
5.2.1	Have calculations verified.	Have another qualified individual verify the calculations.	SU
Comment: EVALU	ATOR CUE: State that another O	perator will verify the calculation.	

Proc. Step	TASK ELEMENT 6	STANDARD	Grade
n/a	Notify the CRS that Excore Quadrant Power Tilt has been completed per PO-3, Attachment 2.	Operator notifies CRS of completion of PO-3, Attachment 2, Excore Quadrant Power Tilt.	SU
Commen	t:		

END OF TASK

SIMULATOR OPERATOR INSTRUCTIONS

SIMULATOR SET UP:

Simulator Setup Instructions:

- Full power IC
- Drop Control Rod #11 fully into the core with RD-11 (Final Value = 2) on PIDRD02
- When plant has stabilized, freeze the Simulator and SNAP
- Use PO-3, Attachment 2 and record/calculate from the Upper and Lower NI Detector meters on EC-06 and use as answer key.

Excore	Lower Reading (%) $S_{AL}, S_{BL}, S_{CL}, S_{DL}$	Upper Reading (%) S _{AU} , S _{BU} , S _{CU} , S _{DU}	Lower + Upper S _A , S _B , S _C , S _D	$S = (\Sigma \text{ All Detectors})/4$ = (S _A + S _B + S _C + S _D)/4	Excore Quadrant Tilt T _{EA} , T _{EB} , T _{EC} , T _{ED}	
5 (CH A)	S _{AL} = [NI-005 Lower (A)] 51	S _{AU} = [NI-005 Upper (B)] 50	$S_{A} = S_{AL} + S_{AU}$ 101		T _{EA} = [(S _A -S)/S] x 100% 5.2	QUAD 1
6 (CH B)	S _{BL} = [NI-0065 Lower (A)] 41	S _{BU} = [NI-006 Upper (B)] 40	S _B = S _{BL} + S _{BU} 81	96	T _{EB} = [(S _B -S)/S] x 100% -15.6	QUAD 3
7 (CH C)	S _{CL} = [NI-007 Lower (A)] 51	S _{CU} = [NI-007 Upper (B)] 50	S _c = S _{cL} + S _{cU} 101		T _{EC} = [(S _C -S)/S] x 100% 5.2	QUAD 4
8 (CH D)	S _{DL} = [NI-008 Lower (A)] 52	S _{DU} = [NI-008 Upper (B)] 49	S _D = S _{DL} + S _{DU} 101		T _{ED} = [(S _D -S)/S] × 100% 5.2	QUAD 2

<u>NOTE</u>: The four QPTs should sum to approximately zero.

Comments:	·					
Performed By:	_Pat Person		Date:	Today	Time:	Now
Calculations Verifie	d By:				Date:	 <u></u>
After calculations a	re verified, forward to NS	SSS and Reactor Enginee	ring Supervisor or design	nee for final review.		
Reactor Engineerin	g Supervisor or designed	e:		_	Date: _	
ANSWER KEY	ANSWER KEY	ANSWER KEY	ANSWER KEY	ANSWER KEY	ANSWE	ER KEY
PALISADES NUCLE	AR PLANT	Page 7 of 8	A	UGUST 2010		

CANDIDATE CUE SHEET

(TO BE RETURNED TO EXAMINER TO UPON COMPLETION OF TASK)

INITIAL CONDITIONS:

- Plant was at full power.
- Incores #9 and #35 are inoperable.
- Control Rod #11 has dropped into the core.

INITIATING CUES:

During performance of PO-3, Alternate Incore and Excore Applications, the Control Room Supervisor directs you to calculate Excore Quadrant Power Tilt utilizing Power Range NI Channels on Panel C-06.

NRC REGION III INITIAL LICENSE EXAM JOB PERFORMANCE MEASURE

JPM: RO ADMIN 1b TITLE: RESET UFM CORRECTION FACTORS

CANDIDATE:

EXAMINER:

JOB PERFORMANCE MEASURE DATA PAGE

Task: Reset	UFM Correction Factors
Alternate Path: N/A	
Facility JPM #: PL-OF	PS-PPC-001J
K/A: 2.1.19 Im	nportance: SRO: 3.0 RO:3.0
K/A Statement: At sy	pility to use plant computer to obtain and evaluate parametric information on stem or component status.
Task Standard: UI	FM correction factors set to 1.000 and UFM is not enabled on PPC Page 521.
Preferred Evaluation L	ocation: Simulator _X_ In Plant
Preferred Evaluation M	1ethod: Perform_X_ Simulate
References: DWO-1,	"Operator's Daily/Weekly Items MODES 1, 2, 3, and 4"
Validation Time:10_	_ minutes Time Critical: NO
Candidate:	
Time Start:	Time Finish:
Performance Time:	minutes
Performance Rating:	SAT UNSAT
Comments:	
Examiner:	Date:

EXAMINER COPY ONLY

Tools/Equipment/Procedures Needed:

DWO-1, "Operator's Daily/Weekly Items MODES 1, 2, 3, and 4" DWO-1 Attachment 12 GOP-8, "Power Reduction and Plant Shutdown to MODE 2 or MODE $3 \ge 525^{\circ}$ F" Tech Data Book

Also see **Simulator Operator Instructions** (later page of this document).

READ TO CANDIDATE

DIRECTION TO CANDIDATE:

I will explain the initial conditions, and state the task to be performed. All control room steps shall be performed for this JPM, including any required communications. I will provide initiating cues and reports on other actions when directed by you. Ensure you indicate to me when you understand your assigned task. To indicate that you have completed your assigned task return the handout sheet I provided you.

INITIAL CONDITIONS:

The Plant is at 86% power following a power reduction from full power.

INITIATING CUES:

The Control Room Supervisor directs you to ensure UFM CAL ENABLED on PPC Page 521 is <u>NOT</u> ENABLED per DWO-1, Section 5.2.3.

Evaluator Cue: Provide candidate with a working copy of DWO-1 section 5.2.3.

Proc.Step	TASK ELEMENT 1	STANDARD	Grade
5.2.3.a	OBTAIN PPC Page 521 "UFM PLANT CALORIMETRIC	Page 521 of PPC is displayed	SU
Comment CRITICA	STEP		

Proc.Step	TASK ELEMENT 2	STANDARD	Grade
5.2.3.b	DETERMINE if UFM CAL ENABLED on PPC Page 521 is correct. Refer to Technical Data Book Figure 14.1.	PPC Page 521 UFM CAL ENABLED noted to be "YES".	SU
Comment	a		

Proc.Step	TASK ELEMENT 3	STANDARD	Grade	
5.2.3.c	IF UFM CAL ENABLED will be changed from NOT ENABLED to ENABLED, THEN PERFORM the following:	Determines step is N/A.	SU	
Comment:				

Proc.Step	TASK ELEMENT 4	STANDARD	Grade
5.2.3.d.1	IF UFM CAL ENABLED will be changed from ENABLED to NOT ENABLED, THEN PERFORM the following: 1. UPDATE Technical Data Book Figure 14.1 indicating UFM CAL ENABLED status.	Updates Tech Data Book Figure 14.1 for UFM status to Not Enabled.	SU
Comment:			

Proc.Step	TASK ELEMENT 5	STANDARD	Grade
5.2.3.d.2	IF UFM CAL ENABLED will be changed from ENABLED to NOT ENABLED, THEN PERFORM the following: 2. ENSURE HB_PWR_STEADY is lowered to the 100% thermal power limit allowed by Attachment 12, "100% Thermal Power Limit."	Refers to Attachment 12 and determines power is < 2530 MWt.	s u
Comment:			

Evaluator Cue: Provide candidate with a working copy of DWO-1 Attachment 12.

Proc.Step	TASK ELEMENT 6	STANDARD	Grade
5.2.3.d.3	IF UFM CAL ENABLED will be changed from ENABLED to NOT ENABLED, THEN PERFORM the following:	UFM CAL ENABLED field is selected.	SU
	3. SELECT UFM CAL ENABLED.		
Comment:			
			1

Proc.Step	TASK ELEMENT 7	STANDARD	Grade
5.2.3.d.4	IF UFM CAL ENABLED will be changed from ENABLED to NOT ENABLED, THEN PERFORM the following:	'N' is entered.	S U
	4. ENTER N for no.		
Comment:			

Proc.Step	TASK ELEMENT 8	STANDARD	Grade
5.2.3.d.5	IF UFM CAL ENABLED will be changed from ENABLED to NOT ENABLED, THEN PERFORM the following: 5. PRESS UPDATE hardkey.	UPDATE hardkey is pressed.	sυ
Comment:			

Proc.Step	TASK ELEMENT 9	STANDARD	Grade
5.2.3.d.5	IF UFM CAL ENABLED will be changed from ENABLED to NOT ENABLED, THEN PERFORM the following: 6. ENSURE UFM Correction Factors set to 1.0000. Refer to Step 5.2.3f.	Operator goes to 5.2.3.f.	SU
Comment:			

Proc.Step	TASK ELEMENT 10	STANDARD	Grade
5.2.3.f.1	ENSURE Technical Data Book Figure 14.1 is updated.	Enters "1.0000" for UFM correction factors in Tech Data Book Figure 14.1.	SU
Comment	:		

Proc.Step	TASK ELEMENT 11	STANDARD	Grade
5.2.3.f.2	ENSURE HB_PWR_STEADY is acceptable for the new Total UFM Correction Factor Worth in Technical Data Book Figure 14.1.	Operator verifies HB_PWR_STEADY is lowered to a value less than the 'Maximum UFM Corrected Power for Resetting Correction Factors to 1.0' found in Tech Data Book Figure 14.1.	SU
Comment	. .		

Proc.Step	TASK ELEMENT 12	STANDARD	Grade
5.2.3.f.3	Select data.	On PPC page 521, data is selected for first UFM Correction Factor.	SU
Comment CRITICA	LISTEP		

Proc.Step	TASK ELEMENT 13	STANDARD	Grade
5.2.3.f.4	Enter new value.	1.0000 is entered.	SU
Comment CRITICA	: USTEP		

PALISADES NUCLEAR PLANT

Proc.Step	TASK ELEMENT 14	STANDARD	Grade
5.2.3.f.5	Press UPDATE hardkey.	UPDATE hardkey is pressed.	SU
Comment	:		
CRITICA	STEP		

Proc.Step	TASK ELEMENT 15	STANDARD	Grade
5.2.3.f.3	Select data.	On PPC page 521, data is selected for second UFM Correction Factor.	SU
Comment CRITICA	: L STEP		

Proc.Step	TASK ELEMENT 16	STANDARD	Grade
5.2.3.f.4	Enter '1.0000'.	1.0000 is entered.	SU
Comment			
CRITICA	LSTEP		

Proc.Step	TASK ELEMENT 17	STANDARD	Grade
5.2.3.f.5	Press UPDATE hardkey.	UPDATE hardkey is pressed.	SU
Comment	:		
CRITICA	LSTEP		_

Proc.Step	TASK ELEMENT 18	STANDARD	Grade			
5.2.3.d.7 5.2.3.f.6	Wait approximately 30 minutes for Heat Balance power to adjust to the change in the UFM Correction Factors.	Operator waits approximately 30 minutes for Heat Balance power to adjust to the change in the UFM Correction Factors.	SU			
Comment: EVALU	Comment: EVALUATOR CUE: Another person will perform the Heat Balance.					

Proc.Step	TASK ELEMENT 19	STANDARD	Grade
5.2.3.d.8	Perform a heat balance as soon as plant	Informs CRS that a heat balance is to be	S II
5.2.3.f.7	conditions allow.	performed as soon as plant conditions allow.	00
Comment:			

EVALUATOR CUE: Another Operator will perform a Heat Balance.

Proc.Step	TASK ELEMENT 20	STANDARD	Grade
	Inform CRS that the UFM Correction Factors are reset to 1.0000 per DWO-1.	Operator informs the CRS that the UFM Correction Factors are reset to 1.0000 per DWO-1.	SU
Comment EVALU	ATOR CUE: Repeat back notification		

END OF TASK

SIMULATOR OPERATOR INSTRUCTIONS

- IC-16, 86% power.
- Ensure UFM Correction Factors are 0.9890 and 0.9690 on PPC page 521 and Tech Data Book figure 14.1 is updated.
- Ensure UFM CAL ENABLED (= YES)

CANDIDATE CUE SHEET

(TO BE RETURNED TO EXAMINER UPON COMPLETION OF TASK)

INITIAL CONDITIONS:

The Plant is at 86% power following a power reduction from full power.

INITIATING CUES:

The Control Room Supervisor directs you to ensure UFM CAL ENABLED on PPC Page 521 is <u>NOT</u> ENABLED per DWO-1, Section 5.2.3.

NRC REGION III INITIAL LICENSE EXAM JOB PERFORMANCE MEASURE

JPM: RO ADMIN 2

TITLE: PERFORM DWO-1 ACOUSTIC MONITOR 7-DAY CHECK

CANDIDATE: _____

EXAMINER:

JOB PERFORMANCE MEASURE DATA PAGE

Task: Perform Operators Daily/Weekly/Bi-Weekly items in all MODES
Alternate Path: N/A
Facility JPM #: NEW
K/A: 2.2.12 Importance: RO: 3.7 SRO: 4.1
K/A Statement: Knowledge of surveillance procedures
Task Standard: Identification of one out-of-spec reading during the performance of DWO-1 for Acoustic Monitors.
Preferred Evaluation Location: Simulator In Plant
Preferred Evaluation Method: PerformX Simulate
References: DWO-1, "Operator's Daily/Weekly Items Modes 1, 2, 3, and 4"
Validation Time: 15 minutes Time Critical: NO
Candidate:
Time Start: Time Finish:
Performance Time: minutes
Performance Rating: SAT UNSAT
Comments:
Examiner: Date:

EXAMINER COPY ONLY

Tools/Equipment/Procedures Needed:

- DWO-1, "Operator's Daily/Weekly Items Modes 1, 2, 3, and 4," Section 6.1 and Attachment 1, Daily/Weekly Surveillance Data Sheet
- Red ink pen

Also see **Simulator Operator Instructions** (last page of this document).

READ TO CANDIDATE

DIRECTION TO CANDIDATE:

I will explain the initial conditions, and state the task to be performed. All control room steps shall be performed for this JPM, including any required communications. I will provide initiating cues and reports on other actions when directed by you. Ensure you indicate to me when you understand your assigned task. To indicate that you have completed your assigned task return the handout sheet I provided you.

INITIAL CONDITIONS:

- The Plant is at full power.
- It is Wednesday, 1900 hours.

INITIATING CUES:

You have been directed to take the readings of DWO-1, Item 6.1. ALL remaining readings have already been taken by another NCO.

EVALUATOR CUE: Provide candidate with page 3 of DWO-1, attachment 1 and section 6.1.

TASK ELEMENT 1	STANDARD	Grade			
	 Pushes "read preamp bias" button for one of the five (5) monitors 				
	CHECKS reading between 52.5 and 67.5				
PUSH "read preamp bias" button (should read between 52 5 and 67 5) AND ENTER	 RECORDS reading in "Wednesday Reading" column for applicable monitor 				
reading on Attachment 1, "Daily/Weekly	 Repeats above three steps for each monitor 	SU			
Surveillance Data Sheet."	 DETERMINES FI-1043B reading is less than 52.5 				
	 CIRCLES in RED FI-1043B reading* 				
	 NOTIFY CRS of the out of spec reading * 				
EVALUATOR CUE: If notified as the CRS of the out of spec reading: Acknowledge. If asked if the surveillance should continue: RESPOND to continue with the surveillance.					
* NOTE: Not part of the critical step					
CRITICAL STEP					
	TASK ELEMENT 1 PUSH "read preamp bias" button (should read between 52.5 and 67.5) AND ENTER reading on Attachment 1, "Daily/Weekly Surveillance Data Sheet." TOR CUE: If notified as the CRS of asked if the surveillance with the surveillance. Not part of the critical step STEP	TASK ELEMENT 1 STANDARD PUSH "read preamp bias" button (should read between 52.5 and 67.5) AND ENTER reading on Attachment 1, "Daily/Weekly Surveillance Data Sheet." • Pushes "read preamp bias" button for one of the five (5) monitors • CHECKS reading between 52.5 and 67.5) AND ENTER reading on Attachment 1, "Daily/Weekly Surveillance Data Sheet." • RECORDS reading in "Wednesday Reading" column for applicable monitor • DETERMINES FI-1043B reading is less than 52.5 • CIRCLES in RED FI-1043B reading is less than 52.5 • CIRCLES in RED FI-1043B reading * • NOTIFY CRS of the out of spec reading * TOR CUE: If notified as the CRS of the out of spec reading: Acknowledge asked if the surveillance should continue: RESPOND to continue with the surveillance. Not part of the critical step STEP			

Proc. Step	TASK ELEMENT 2	STANDARD	Grade			
	PUSH "high alarm test" pushbutton - high alarm on C-13 should annunciate.	 Pushes "high alarm test" pushbutton for one of the five (5) monitors 	sυ			
6.1.2		CHECKS that high alarm on C-13 annunciates				
		 Repeats above two steps for each monitor 				
Comment:						
CRITICAL	CRITICAL STEP					

JPM RO ADMIN 2

Proc. Step	TASK ELEMENT 3	STANDARD	Grade
6.1.3	TURN Channel 1 gain switch to highest point - some noise should be present after switch is at highest point.	 Turns Channel 1 gain switch clockwise until noise is heard. 	SU
Comment:			

NOTE: Channel 1 gain switch is switch on LEFT side of panel. CRITICAL STEP

Proc. Step	TASK ELEMENT 4	STANDARD	Grade
6.1.4	RETURN switch to zero.	 Turns Channel 1 gain switch counterclockwise to zero position 	SU
Comment:			
CRITICAL	STEP		

Proc. Step	TASK ELEMENT 5	STANDARD	Grade
6.1.5	IF the pre-amp bias for any of the acoustic monitors is found out of tolerance, THEN INITIATE a work request. The instrument is operable provided the other two checks (alarm operates, audible noise) passed satisfactorily.	 INITIALS RECRD BY in Wednesday column for Item 6.1 RECORDS a note at bottom of page that preamp bias for FI-1043B indicated zero Informs CRS that Work Request initiation is required for preamp bias issue on FI-0143B. 	SU
Commont			

Comment:

EVALUATOR CUE: If notified as the CRS of the out of spec reading and need for a Work Request: Acknowledge.

Proc. Step	TASK ELEMENT 6	STANDARD	Grade
n/a	 Return completed DWO-1 to CRS Inform CRS of out of spec readings (if not already done) 	 Completed DWO-1 RETURNED to the CRS CRS INFORMED of the out of spec readings (if not already done) 	sυ
Comment:			<u> </u>

END OF TASK

SIMULATOR OPERATOR INSTRUCTIONS

- Reset to any <u>full</u> power IC.
- Insert the following or use CAE file
 - Override for FI-1043B Controller Output to 0.011597
- Ensure copies of DWO-1, Section 6.1 and Attachment 1, page 3 of 4 are available
- Ensure Simulator clipboard copy of SHO-1, Attachment 1 is the current revision
- Ensure Channel #1 is selected on Audio Channels Switch (Panel C-11A rear, top right-hand corner of Acoustic Panel.)

CANDIDATE CUE SHEET

(TO BE RETURNED TO EXAMINER UPON COMPLETION OF TASK)

INITIAL CONDITIONS:

- The Plant is at full power.
- It is Wednesday, 1900 hours.

INITIATING CUES:

You have been directed to take the readings of DWO-1, Item 6.1. <u>All</u> remaining readings have already been taken by another NCO.

÷

NRC REGION III

INITIAL LICENSE EXAM

JOB PERFORMANCE MEASURE

JPM: RO ADMIN 3

TITLE: DETERMINE EXPECTED DOSE FOR EQUIPMENT INSPECTION

CANDIDATE:

EXAMINER:

JOB PERFORMANCE MEASURE DATA PAGE

Task: Determine I	Expected Dose for E	quipme	nt Inspec	ction	
Alternate Path:	N/A				
Facility JPM #:	PL-OPS-ADM-002	J			
K/A: 2.3.4	Importance:	SRO:	3.7	RO:	3.2
K/A Statement:	Knowledge of radia conditions.	tion exp	osure lin	nits unde	er normal or emergency
Task Standard:	Expected dose is ca	alculated	d to be 4	.5 mR (a	allow 4 to 5 mR).
Preferred Evaluation	n Location: ANY	_X_	_		
Preferred Evaluation	n Method: Perform	n _X_	_	Simulat	te
References: Hea	alth Physics Procedu	ıre 2.14,	"Radiol	ogical S	urveys"
Validation Time:	20 minutes	Time C	ritical:	NO	
Candidate:					
Time Start:	Time Finish	ı:			
Performance Time:	minu	ites			
Performance Rating	: SAT	UNSAT	-		
Comments:					
Examiner:	Signature			Date:	

EXAMINER COPY ONLY

Tools/Equipment/Procedures Needed:

Current "Radiological Area Status Sheet" for East Safeguards

READ TO CANDIDATE

DIRECTION TO CANDIDATE:

I will explain the initial conditions, and state the task to be performed. All control room steps shall be performed for this JPM, including any required communications. I will provide initiating cues and reports on other actions when directed by you. Ensure you indicate to me when you understand your assigned task. To indicate that you have completed your assigned task return the handout sheet I provided you.

INITIAL CONDITIONS:

The Plant is in a refueling outage. Work is in progress on P-67A Low Pressure Safety Injection Pump. A report has been received in the Control Room that scaffold erecting activities may have damaged the seal cooler and seal injection lines for P-67A.

INITIATING CUES:

You have been assigned the task of inspecting P-67A seal cooler and seal injection lines for damage. This will require close inspection (within 1-2 feet of pump skid area next to the seal cooler), but you are NOT to cross any contamination boundary. The inspection is expected to require 15 minutes to complete.

Determine the maximum expected radiation dose you will receive for this task. Do <u>not</u> include dose received during transit time.

JPM RO ADMIN 3

Proc.Step	TASK ELEMENT 1	STANDARD	Grade
	Obtains correct survey map for P-67A.	Obtains "Radiological Area Status Sheet" for East Engineering Safeguards.	SU

Comment:

EVALUATOR CUE: Provide candidate with attached Radiological Area Status Sheet and picture of P-67A skid.

Proc.Step	TASK ELEMENT 2	STANDARD	Grade
	Determine dose rate near the component.	Dose rate determined to be 18 mRem/hr.	SU
Comment	:		

EVALUATOR NOTE: Candidate should select 18 mR/hr dose rate reading from Status Sheet since this is the general area where seal cooler is located and they were instructed not to cross any contamination areas.

CRITICAL STEP

Proc.Step	TASK ELEMENT 3	STANDARD	Grade
	Calculates expected dose.	Expected dose calculated to be 4.5 mRem.	SU
Comment	:		
EVALU	ATOR NOTE: 18 mRem/hr X 0.25 hr :	= 4.5 mR (allow 4-5 mR)	
CRITICA	STEP		

END OF TASK

JPM RO ADMIN 3

SIMULATOR OPERATOR INSTRUCTIONS

Simulator NOT required for this JPM.

PALISADES NUCLEAR PLANT

Radiological Survey Sheet

4 2010 010 Aux Bldg 570' East Engineered Safeguards 8/16/10 2330 Brear Sama Status Sheek Wu Vocated Meter Type/Setal No. Note: Type/Setal No. It is sime Bate Sama Yes Note: Type/Setal No. Note: Type/Setal No. Presk Weatron J Technician J Supervisor 8/16/10 2330 Note: All Dose Rates in mRent/hr unless otherwise noted 1 10 10 10 Image: Set Status	Room ID	RWP#	Item Description		· · · · · · · · · · · · · · · · · · ·	Date/Time
Smear Gamma Status Sheet(RWP Updated Yes Meter TypeScrid No. XYZ:1/1234AA Meter TypeScrid No. N/A Meter TypeScrid No. N/A N/A Beta Status Sheet(RWP Updated Utgest(Recrifed by J Technician Redeved by J Supervisor Status Sheet(RWP Updated N/A Status Sheet(RWP Updated N/A Utgested Status Sheet(RWP Updated Utgested Status Sheet(RWP Updated J Technician Status Sheet(RWP Updated N/A Utgested Status Sheet(RWP Updated Status Sheet(RWP Updated J Technician N/A N/A Smear 5, Opmittle care J Technician Redeved by J Technician Smear 5, Opmittle care Smear	4	2010 01	0 Aux Bldg 570)' East Engineered Sa	feguards	8/16/10 2330
■ station ■ Station Yes XYZ1/1234AA N/A N/A ■ Wassion ■ Beta Surveyed/Recorded by J Technician J Supervisor 8/16/10 Stronger, Barrow, Stronger, St			Status Sheet/RWP Updated	Meter Type/Serial No.	Meter Type/Serial No.	Meter Type/Serial No.
Image:		Gamma	Yes	XYZ1/1234AA	N/A	N/A
□ Freix □ J Technician J Supervisor 8/16/10 Note: All Dose Rates in mRem/hr unless otherwise noted ① 16K ② ○ Comments: ○ <th>Masslinn</th> <th>🔲 Beta</th> <th>Surveyed/Recorded by</th> <th>7.12.0.120.000</th> <th>Reviewed by</th> <th>Date</th>	Masslinn	🔲 Beta	Surveyed/Recorded by	7.12.0.120.000	Reviewed by	Date
Note: All Dose Rates in mRem/hr unless otherwise noted Smears - emrition chr Comments: 9 16/ 0 16/ 0 0 16/ 0 0 16/ 0 0 16/ 0 0 16/ 0 0 16/ 0 0 16/ 0 0 16/ 0 0 16/ 0 0 10 0 0 10 0 0 1 0 18/ 1 0 18/ 1 0 18/ 0 0 18/ 0 0 18/ 0 0	Frisk	Neutron	J Technician		J Supervisor	8/16/10
Note: All Dose Rates in mRem/hr unless otherwise noted Image: state in mRem/hr unless otherwise noted Comments: Image: state in mRem/hr unless otherwise noted Image: state in mRem/hr unless otherwise noted Image: state in mRem/hr unless otherwise noted Image: state in mRem/hr unless otherwise noted Image: state in mRem/hr unless otherwise noted Image: state in mRem/hr unless otherwise noted Image: state in mRem/hr unless otherwise noted Image: state in mRem/hr unless otherwise noted Image: state in mRem/hr unless otherwise noted Image: state in mRem/hr unless otherwise noted Image: state in mRem/hr unless otherwise noted Image: state in mRem/hr unless otherwise noted Image: state in mRem/hr unless otherwise noted Image: state in mRem/hr unless otherwise noted Image: state in mRem/hr unless otherwise noted Image: state in mRem/hr unless otherwise noted Image: state in mRem/hr unless otherwise noted Image: state in mRem/hr unless otherwise noted Image: state in mRem/hr unless otherwise noted Image: state in mRem/hr unless otherwise noted Image: state in mRem/hr unless otherwise noted Image: state in mRem/hr unless otherwise noted Image: state in mRem/hr unless otherwise noted Image: state in mRem/hr unless otherwise noted Image: state in mRem/hr unless otherwise noted Image: state in mRem/hr unless otherwise noted Image: state in mRem/hr u						Smoore
	Smear Masslinn Frisk Comme	Gamma Gamma Beta Neutron ents:	P-75A P-75B P-75B P-75B	ates in mRem/hr unless ot $ \begin{array}{c} \hline $	N/A Reviewed by J Supervisor herwise noted -60 2 C-6A C-6A	N/A Date 8/16/10 Smears _ ① 16K ② N/A ③ ④ ③ ④ ④ ① ④ ① ○ N/A ③ ④ ④ ③ ● ① ○ N/A ③ ● ○ ● ● ① ● ① ● ① ● ① ● ① ● ① ● ① ● ① ● ① ○ ● ○ ● ● ① ● ① ● ① ● ○ ● ○ ● ○ ● ○ ● ○ ● ○ ● ○ ● ○ ● ○
		(sum	ソート	<u>× 10</u> ×		dpm/100 cm ²
$\frac{10}{2}$ $\frac{10}{2}$ $\frac{10}{2}$ $\frac{10}{2}$ $\frac{10}{2}$ $\frac{10}{2}$				x x x x x x x x x x	- Vil	
$\begin{array}{c} x \\ x $						
$\begin{array}{c} x & 10 \\ x & x $						N/A



CANDIDATE CUE SHEET

(TO BE RETURNED TO EXAMINER UPON COMPLETION OF TASK)

INITIAL CONDITIONS:

The Plant is in a refueling outage. Work is in progress on P-67A Low Pressure Safety Injection Pump. A report has been received in the Control Room that scaffold erecting activities may have damaged the seal cooler and seal injection lines for P-67A.

INITIATING CUES:

You have been assigned the task of inspecting P-67A seal cooler and seal injection lines for damage. This will require close inspection (within 1-2 feet of pump skid area next to the seal cooler), but you are NOT to cross any contamination boundary. The inspection is expected to require 15 minutes to complete.

Determine the maximum expected radiation dose you will receive for this task. Do <u>not</u> include dose received during transit time.

NRC REGION III

INITIAL LICENSE EXAM

JOB PERFORMANCE MEASURE

JPM: SRO ADMIN 1a

TITLE: DETERMINE COMPENSATION FOR A WITHDRAWN, INOPERABLE CONTROL ROD

CANDIDATE: ______

EXAMINER: _____

JOB PERFORMANCE MEASURE DATA PAGE

Task: Determine Compensation for a Withdrawn, Inoperable Control Rod
Alternate Path: N/A
Facility JPM #: PL-OPS-ENG-011J
K/A: 2.1.25 Importance:RO:3.9 SRO: 4.2
K/A Statement: Ability to interpret reference materials, such as graphs, curves, tables, etc.
Task Standard: EM-04-08, Attachment 1 properly completed per key.
Preferred Evaluation Location: ANYX
Preferred Evaluation Method: Perform_X_Simulate
References: EM-04-08, "Shutdown Margin Requirements"
Validation Time:20 minutes Time Critical: NO
Candidate:
Time Start: Time Finish:
Performance Time: minutes
Performance Rating: SAT UNSAT
Comments:
Examiner: Date:
EXAMINER COPY ONLY

Tools/Equipment/Procedures Needed:

EM-04-08, "Shutdown Margin Requirements" Technical Data Book Calculator

READ TO CANDIDATE

DIRECTION TO CANDIDATE:

I will explain the initial conditions, and state the task to be performed. All control room steps shall be performed for this JPM, including any required communications. I will provide initiating cues and reports on other actions when directed by you. Ensure you indicate to me when you understand your assigned task. To indicate that you have completed your assigned task return the handout sheet I provided you.

INITIAL CONDITIONS:

- Rod #6 is inoperable and fully withdrawn.
- It is believed that the rod is untrippable.
- Burnup is 7,000 MWD/MTU.
- Rx power is 100%.
- PCS Boron is 865 ppm.
- All rods out, equilibrium Xenon.

INITIATING CUES:

The Control Room Supervisor directs you to determine the compensation for shutdown margin required for control rod #6 utilizing EM-04-08.

[Provide a calculator to the examinee for this JPM.]

EVALUATOR CUE: Provide candidate a working copy of EM-04-08 Attachment 1.

Proc. Step	TASK ELEMENT 1	STANDARD	Grade	
1	Record inoperable control rod identification.	'A', '6' and 'untrippable' recorded.	SU	
Comment:				
CRITICAL STEP				

Proc. Step	TASK ELEMENT 2	STANDARD	Grade
2	Record worth of inoperable control rod.	'1.17 (1.16 to 1.18)' entered.	sυ
Commen EVALU CRITICA	^{t:} IATOR CUE: Reactor Engineering IL STEP	g is not available.	

Proc. Step	TASK ELEMENT 3	STANDARD	Grade
3	Record source of inoperable control rod worth data.	'Tech Data Book' entered.	SU
Comment	:		

Proc. Step	TASK ELEMENT 4	STANDARD	Grade
4.A	Record current cycle burnup.	Record current cycle burnup = 7000.	SU
Comment CRITICA	: L STEP		

Proc. Step	TASK ELEMENT 5	STANDARD	Grade
4.B	Record current power level.	'100' entered.	SU
Commen	t:		

Proc. Step	TASK ELEMENT 6	STANDARD	Grade
4.C	Control rod worth inserted into core.	'0' and 'Gp 4 @ 131/132" entered.	SU
Commen CRITICA	t: NL STEP		

Proc. Step	TASK ELEMENT 7	STANDARD	Grade	
4.D	Record PCS Boron concentration.	'865' entered.	sυ	
Comment:				

Proc. Step	TASK ELEMENT 8	STANDARD	Grade	
5.E	Determine and record worth of control rods at current power level.	'7.05 (7.04 to 7.06)' entered.	SU	
Comment:				

EVALUATOR NOTE: This will need to be obtained by interpolation of the graph. **CRITICAL STEP**

Proc. Step	TASK ELEMENT 9	STANDARD	Grade	
5.F	Determine and record max worth of stuck rod at current power.	'1.17 (1.16 to 1.18)' entered.	sυ	
Comment:				
CRITICAL STEP				

Proc. Step	TASK ELEMENT 10	STANDARD	Grade		
5.G	Determine and record PCS boron concentration at 100% at 7000 MWD/MTU.	'865 (860 to 870)' entered.	SU		
Comment:					
CRITICAL STEP					

Proc. Step	TASK ELEMENT 11	STANDARD	Grade	
5.H	Determine and record power defect for 100% power.	'1.53 (1.51 to 1.55)' entered.	SU	
Comment:				

Proc. Step	TASK ELEMENT 12	STANDARD	Grade
5.1	Determine and record power defect at current power level.	'1.53 (1.51 to 1.55)' entered.	SU
Comment	:		

Proc. Step	TASK ELEMENT 13	STANDARD	Grade
5.J	Determine and record required SDM.	'2.0' already entered.	SU
Comment	:		

Proc. Step	TASK ELEMENT 14	STANDARD	Grade
6.K	Calculate Net amount of shutdown margin.	'1.82 (1.80 to 1.84)' entered.	SU
Comment	:: L STEP		

Proc. Step	TASK ELEMENT 15	STANDARD	Grade
6.L	Enter worth of untrippable rod.	'1.17 (1.16 to 1.18)' entered.	SU
Comment CRITICA	: L STEP		<u> </u>

Proc. Step	TASK ELEMENT 16	STANDARD	Grade
6.M	Determine excess shutdown margin with the inoperable rod.	'0.65 (0.645 to 0.655)' entered. Determines Step 7 substeps are 'N/A'.	SU
Comment			
CRITICA	STEP		

Page 7 of 15

Proc. Step	TASK ELEMENT 17	STANDARD	Grade
7.N-Q	IF Shutdown margin is negative, THEN…	Determines Step 7 substeps are 'N/A'.	SU
Comment	:	-	

Proc. Step	TASK ELEMENT 18	STANDARD	Grade		
8.R	Determine and record PPC PDIL for current power level.	'Group 4 at 101" (100 to 105)' entered.	SU		
Comment	Comment:				
CRITICAL STEP					

Proc. Step	TASK ELEMENT 19	STANDARD	Grade
8.S	Determine and record control rod position corresponding to excess shutdown margin.	'Group 4 at 20" (18 to 22)' entered.	sυ
Comment CRITICA	: L STEP	· · · · · · ·	

Proc. Step	TASK ELEMENT 20	STANDARD	Grade
8.T	Determine and record PDIL for inoperable control rod condition.	'Group 4 at 101" (100 to 105)' entered.	SU
Comment			
CRITICA	STEP	· · · · · · · · · · · · · · · · · · ·	

Proc. Step	TASK ELEMENT 21	STANDARD	Grade
8.U	Determine if Caution Tagging Control Room joy-stick on Panel C-02 is NOT required.	Determines Caution Tagging Control Room joy-stick on Panel C-02 is NOT required.	SU
Comment			

Proc. Step	TASK ELEMENT 22	STANDARD	Grade
9	Sign and date Step 9.	Operator signs and dates.	SU
Comment			

Proc. Step	TASK ELEMENT 23	STANDARD	Grade		
N/A	Report results to Control Room Supervisor.	CRS notified.	SU		
Comment:					
EVALUATOR CUE: End JPM					
Note: Attach completed EM-04-08, Attachment 1 to this JPM.					

END OF TASK

SIMULATOR OPERATOR INSTRUCTIONS

NONE

UNTRIPPABLE OR DROPPED CONTROL ROD SHUTDOWN MARGIN CALCULATION

Proc No EM-04-	. 08
Attachment 1	
Revision 30	
Page 1 of 4	

1.	UNTRI	PPABLE OR DROPPED CONTROL ROD IDENTIFICATIO	N:	
	GROUF	D NUMBER <u>6</u>		
	CONDI	TIONuntrippable (Untrippable or Dropped)		
2.	WORTH CONTR (TDB Fi	H OF UNTRIPPABLE OR DROPPED	_%Δρ	
3.	SOURC	E OF UNTRIPPABLE OR DROPPED CONTROL ROD W	ORTH DATA:	
		Tech Data Book		
4.	REFER	ENCE DATA		
	A. C (CURRENT CYCLE BURNUP TDB Fig 1.10)		MWd/MTU
	B. C (I	CURRENT REACTOR POWER LEVEL Percent of Rated Power)	100	%
	C. C (CONTROL ROD WORTH INSERTED INTO CORE TDB Fig 1.3)	0	%Δρ
		GROUP <u>4</u> INCHES <u>132 (or 131)</u>		
	T tf	This Control Rod worth does not include he worth of a dropped Control Rod.		
	D. P ((CS BORON CONCENTRATION Chemistry Log or Reactor Logbook)	865	ppm

Proc No EM-04-08 Attachment 1 Revision 30 Page 2 of 4

UNTRIPPABLE OR DROPPED CONTROL ROD SHUTDOWN MARGIN CALCULATION

5. GENERAL DATA

E.	WORTH OF ALL CONTROL RODS AT A (TDB Fig 1.1)	7.05	%Δρ
F.	MAXIMUM WORTH OF STUCK CONTROL ROD AT A (TDB Fig 1.1)		%Δρ
G.	PCS BORON AT 100% POWER AT A (TDB Fig 6.1, Reactor Log)	865	ppm
H.	POWER DEFECT AT 100% POWER (TDB Fig 3.2 and G)	1.53	%Δρ
L.	POWER DEFECT AT POWER B		
	$\frac{\text{H x B}}{100} = \frac{(1.53) \text{ x (100)}}{100} =$	1.53	%Δρ
J.	REQUIRED SHUTDOWN MARGIN (4 PCPs Operating)	2.0	%Δρ

6. CALCULATION

K. NET AMOUNT OF SHUTDOWN MARGIN

$$\frac{(\mathbf{E} - \mathbf{C} - \mathbf{F})}{1.1} - \mathbf{I} - \mathbf{J}$$

$$= \frac{[(7.05) - (0) - 1.17]}{1.1} - (1.53) - (2.0) = \frac{1.82}{1.1}$$

PALISADES NUCLEAR PLANT

	UNTRIPPABLE OR DROPPED CONTROL ROD SHUTDOWN MARGIN CALCULATION		Proc No EM-04-08 Attachment 1 Revision 30 Page 3 of 4
L.	WORTH OF UNTRIPPABLE OR DROPPED CONTROL ROD Step 2	1.17	%Δρ
M.	EXCESS SHUTDOWN MARGIN WITH ONE UNTRIPPABLE OR DROPPED CONTROL ROD		
	K - L = (1.82) - (1.17) =	0.65	%Δρ

7. IF excess Shutdown Margin (M) is NEGATIVE, <u>THEN</u> borate the PCS to reduce reactor power until M is **POSITIVE** performing Steps N through Q to calculate the maximum reduced reactor power level.

N. POWER DEFECT AT REDUCED POWER

 $I + M = () + () = \frac{N/A}{2} %\Delta \rho$

O. MAXIMUM REDUCED POWER LEVEL

$$\frac{\mathbf{N} \times \mathbf{B}}{\mathbf{I}} = \frac{() \times ()}{()} = \frac{\mathbf{N}/\mathbf{A}}{\mathbf{X}}$$

- P. Caution Tag the Control Rod joy-stick on panel C-02 that the new PDIL is Control Rod position at **C**. N/A
- Q. <u>IF</u> power reduction is required, <u>THEN</u> after power reduction re-perform <u>Attachment 1</u> to verify Shutdown Margin N/A requirements are satisfied.

UNTRIPPABLE OR DROPPED CONTROL ROD SHUTDOWN MARGIN CALCULATION

Proc No EM-04-08 Attachment 1 Revision 30 Page 4 of 4

N/A

8. **IF M** is **POSITIVE**, **<u>THEN</u>** sufficient Shutdown Margin is available and no power reduction is necessary to ensure required Shutdown Margin. Perform Steps **R** though **U** to determine maximum allowable Control Rod insertion limit corresponding to excess Shutdown Margin available (**M**).

R.	PPC PDIL FOR CURRENT POWER LEVEL (TDB Fig 1.9)	Group	
		Inches	101
S.	CONTROL ROD POSITION CORRESPONDING TO EXCESS SHUTDOWN MARGIN IN M	Group	
	(TDB Fig 1.3 or 5.1 and M)	Inches	20
Τ.	PDIL FOR UNTRIPPABLE OR DROPPED CONTROL ROD CONDITION	Group	4
	(R or S, whichever is farthest withdrawn)	Inches	101

U. <u>IF</u> the Control Rod position in **S** is farther withdrawn than the Control Rod position in **R**, <u>THEN</u> Caution Tag the Control Rod joy-stick on panel C-02, identifying that the new PPC PDIL as the Control Rod position in **S**.

9. REVIEWS

/ (Today)	
Date	
/	
	/ (Today) Date

Forward Completed Form to Reactor Engineering Supervisor

Reactor Engineering Supervisor

Date

CANDIDATE CUE SHEET

(TO BE RETURNED TO EXAMINER TO UPON COMPLETION OF TASK)

INITIAL CONDITIONS:

- Rod #6 is inoperable and fully withdrawn.
- It is believed that the rod is untrippable.
- Burnup is 7,000 MWD/MTU.
- Rx power is 100%.
- PCS Boron is 865 ppm.
- All rods out, equilibrium Xenon.

INITIATING CUES:

The Control Room Supervisor directs you to determine the compensation for shutdown margin required for control rod #6 utilizing EM-04-08.

NRC REGION III

INITIAL LICENSE EXAM

JOB PERFORMANCE MEASURE

JPM: SRO ADMIN 1a

TITLE: DETERMINE COMPENSATION FOR A WITHDRAWN, INOPERABLE CONTROL ROD

CANDIDATE: _____

EXAMINER:

JOB PERFORMANCE MEASURE DATA PAGE

EXAMINER COPY ONLY

Tools/Equipment/Procedures Needed:

EM-04-08, "Shutdown Margin Requirements" Technical Data Book Calculator

READ TO CANDIDATE

DIRECTION TO CANDIDATE:

I will explain the initial conditions, and state the task to be performed. All control room steps shall be performed for this JPM, including any required communications. I will provide initiating cues and reports on other actions when directed by you. Ensure you indicate to me when you understand your assigned task. To indicate that you have completed your assigned task return the handout sheet I provided you.

INITIAL CONDITIONS:

- Rod #6 is inoperable and fully withdrawn.
- It is believed that the rod is untrippable.
- Burnup is 7,000 MWD/MTU.
- Rx power is 100%.
- PCS Boron is 865 ppm.
- All rods out, equilibrium Xenon.

INITIATING CUES:

The Control Room Supervisor directs you to determine the compensation for shutdown margin required for control rod #6 utilizing EM-04-08.

[Provide a calculator to the examinee for this JPM.]

EVALUATOR CUE: Provide candidate a working copy of EM-04-08 Attachment 1.

Proc. Step	TASK ELEMENT 1	STANDARD	Grade
1	Record inoperable control rod identification.	'A', '6' and 'untrippable' recorded.	SU
Comment CRITICA	:: L STEP		

Proc. Step	TASK ELEMENT 2	STANDARD	Grade
2	Record worth of inoperable control rod.	'1.17 (1.16 to 1.18)' entered.	sυ
Commen EVALU CRITICA	^{t:} IATOR CUE: Reactor Engineering NL STEP	y is not available.	

Proc. Step	TASK ELEMENT 3	STANDARD	Grade
3	Record source of inoperable control rod worth data.	'Tech Data Book' entered.	SU
Comment	:		

Proc. Step	TASK ELEMENT 4	STANDARD	Grade
4.A	Record current cycle burnup.	Record current cycle burnup = 7000.	SU
Comment CRITICA	: _ STEP		

Proc. Step	TASK ELEMENT 5	STANDARD	Grade
4.B	Record current power level.	'100' entered.	SU
Comment	:		

Proc. Step	TASK ELEMENT 6	STANDARD	Grade
4.C	Control rod worth inserted into core.	'0' and 'Gp 4 @ 131/132" entered.	sυ
Comment CRITICA	t: L STEP		

Proc. Step	TASK ELEMENT 7	STANDARD	Grade	
4.D	Record PCS Boron concentration.	'865' entered.	sυ	
Comment:				

Proc. Step	TASK ELEMENT 8	STANDARD	Grade			
5.E	Determine and record worth of control rods at current power level.	'7.05 (7.04 to 7.06)' entered.	SU			
Comment EVALU	Comment: EVALUATOR NOTE: This will need to be obtained by interpolation of the graph.					

CRITICAL STEP

Proc. Step	TASK ELEMENT 9	STANDARD	Grade		
5.F	Determine and record max worth of stuck rod at current power.	'1.17 (1.16 to 1.18)' entered.	SU		
Comment:					
CRITICAL STEP					

Proc. Step	TASK ELEMENT 10	STANDARD	Grade		
5.G	Determine and record PCS boron concentration at 100% at 7000 MWD/MTU.	'865 (860 to 870)' entered.	SU		
Comment:					
CRITICAL STEP					

Proc. Step	TASK ELEMENT 11	STANDARD	Grade	
5.H	Determine and record power defect for 100% power.	'1.53 (1.51 to 1.55)' entered.	SU	
Comment:				
CRITICAL STEP				

Proc. Step	TASK ELEMENT 12	STANDARD	Grade
5.1	Determine and record power defect at current power level.	'1.53 (1.51 to 1.55)' entered.	SU
Commen	t:		

Proc. Step	TASK ELEMENT 13	STANDARD	Grade
5.J	Determine and record required SDM.	'2.0' already entered.	SU
Comment	:		

Proc. Step	TASK ELEMENT 14	STANDARD	Grade
6.K	Calculate Net amount of shutdown margin.	'1.82 (1.80 to 1.84)' entered.	SU
Comment	: LISTEP		

Proc. Step	TASK ELEMENT 15	STANDARD	Grade	
6.L	Enter worth of untrippable rod.	'1.17 (1.16 to 1.18)' entered.	SU	
Comment:				
CRITICA	STEP			

Proc. Step	TASK ELEMENT 16	STANDARD	Grade	
6.M	Determine excess shutdown margin with the inoperable rod.	'0.65 (0.645 to 0.655)' entered. Determines Step 7 substeps are 'N/A'.	SU	
Comment:				
CRITICA	LISTEP			

Proc. Step	TASK ELEMENT 17	STANDARD	Grade
7.N-Q	IF Shutdown margin is negative, THEN	Determines Step 7 substeps are 'N/A'.	SU
Comment:			

Proc. Step	TASK ELEMENT 18	STANDARD	Grade	
8.R	Determine and record PPC PDIL for current power level.	'Group 4 at 101" (100 to 105)' entered.	SU	
Comment:				
CRITICAL STEP				

Proc. Step	TASK ELEMENT 19	STANDARD	Grade
8.S	Determine and record control rod position corresponding to excess shutdown margin.	'Group 4 at 20" (18 to 22)' entered.	SU
Comment CRITICA	STEP		

.

Proc. Step	TASK ELEMENT 20	STANDARD	Grade		
8.T	Determine and record PDIL for inoperable control rod condition.	'Group 4 at 101" (100 to 105)' entered.	SU		
Comment:					
CRITICAL STEP					

Proc. Step	TASK ELEMENT 21	STANDARD	Grade
8.U	Determine if Caution Tagging Control Room joy-stick on Panel C-02 is NOT required.	Determines Caution Tagging Control Room joy-stick on Panel C-02 is NOT required.	SU
Comment	:		

Proc. Step	TASK ELEMENT 22	STANDARD	Grade
9	Sign and date Step 9.	Operator signs and dates.	sυ
Commen	t:		

Proc. Step	TASK ELEMENT 23	STANDARD	Grade			
N/A	Report results to Control Room Supervisor.	CRS notified.	SU			
Comment EVALU Note: A	Comment: EVALUATOR CUE: End JPM Note: Attach completed EM-04-08, Attachment 1 to this JPM.					

END OF TASK

SIMULATOR OPERATOR INSTRUCTIONS

NONE

UNTRIPPABLE OR DROPPED CONTROL ROD SHUTDOWN MARGIN CALCULATION

Proc No EM-04-08 Attachment 1 Revision 30 Page 1 of 4

1. UNTRIPPABLE OR DROPPED CONTROL ROD IDENTIFICATION:

GROUP A____NUMBER 6_____

CONDITION <u>untrippable</u> (Untrippable or Dropped)

2. WORTH OF UNTRIPPABLE OR DROPPED <u>1.17</u>%Δρ CONTROL ROD (TDB Figure 1.1 or Reactor Engineering)

3. SOURCE OF UNTRIPPABLE OR DROPPED CONTROL ROD WORTH DATA:

Tech Data Book

4. **REFERENCE DATA**

A.	CURRENT CYCLE BURNUP (TDB Fig 1.10)		MWd/MTU
В.	CURRENT REACTOR POWER LEVEL (Percent of Rated Power)	100	%
C.	CONTROL ROD WORTH INSERTED INTO CORE (TDB Fig 1.3)	0	%Δρ
	GROUP 4 INCHES 132 (or 131)		
	This Control Rod worth does not include the worth of a dropped Control Rod.		
D.	PCS BORON CONCENTRATION (Chemistry Log or Reactor Logbook)	865	ppm

Proc No EM-04-08 Attachment 1 Revision 30 Page 2 of 4

UNTRIPPABLE OR DROPPED CONTROL ROD SHUTDOWN MARGIN CALCULATION

5. GENERAL DATA

E.	WORTH OF ALL CONTROL RODS AT A (TDB Fig 1.1)	7.05	%Δρ
F.	MAXIMUM WORTH OF STUCK CONTROL ROD AT A (TDB Fig 1.1)		%Δρ
G.	PCS BORON AT 100% POWER AT A (TDB Fig 6.1, Reactor Log)	865	ppm
H.	POWER DEFECT AT 100% POWER (TDB Fig 3.2 and G)	1.53	%Δρ
I.	POWER DEFECT AT POWER B		
	$\frac{\text{H x B}}{100} = \frac{(1.53) \text{ x } (100)}{100} =$	1.53	%Δρ
J.	REQUIRED SHUTDOWN MARGIN (4 PCPs Operating)	2.0	%Δρ

6. CALCULATION

K. NET AMOUNT OF SHUTDOWN MARGIN

$$\frac{(E - C - F)}{1.1} - I - J$$

$$= \frac{[(7.05) - (0) - 1.17]}{1.1} - (1.53) - (2.0) = \frac{1.82}{1.00} \% \Delta \rho$$

	UNTRIPPABLE OR DROPPED CONTROL ROD SHUTDOWN MARGIN CALCULATION		Proc No EM-04-08 Attachment 1 Revision 30 Page 3 of 4
L.	WORTH OF UNTRIPPABLE OR DROPPED CONTROL ROD Step 2	1.17	%Δρ
M.	EXCESS SHUTDOWN MARGIN WITH ONE UNTRIPPABLE OR DROPPED CONTROL ROD		
	K - L = (1.82) - (1.17) =	0.65	%Δρ

7.

<u>IF</u> excess Shutdown Margin (M) is **NEGATIVE**, <u>THEN</u> borate the PCS to reduce reactor power until M is **POSITIVE** performing Steps N through Q to calculate the maximum reduced reactor power level.

N. POWER DEFECT AT REDUCED POWER

 $I + M = () + () = N/A \% \Delta \rho$

O. MAXIMUM REDUCED POWER LEVEL

$$\frac{\mathbf{N} \times \mathbf{B}}{\mathbf{I}} = \frac{() \times ()}{()} = \frac{\mathbf{N}/\mathbf{A}}{\mathbf{N}}$$

- P. Caution Tag the Control Rod joy-stick on panel C-02 that the new PDIL is Control Rod position at **C**. N/A
- Q. <u>IF</u> power reduction is required, <u>THEN</u> after power reduction re-perform <u>Attachment 1</u> to verify Shutdown Margin N/A requirements are satisfied.

UNTRIPPABLE OR DROPPED CONTROL ROD SHUTDOWN MARGIN CALCULATION

Proc No EM-04-08 Attachment 1 Revision 30 Page 4 of 4

N/A

8. **IF M** is **POSITIVE**, **THEN** sufficient Shutdown Margin is available and no power reduction is necessary to ensure required Shutdown Margin. Perform Steps **R** though **U** to determine maximum allowable Control Rod insertion limit corresponding to excess Shutdown Margin available (**M**).

R.	PPC PDIL FOR CURRENT POWER LEVEL (TDB Fig 1.9)	Group	4
		Inches	<u> 101 </u>
S.	CONTROL ROD POSITION CORRESPONDING	Group	4
	(TDB Fig 1.3 or 5.1 and M)	Inches	20
Т.	PDIL FOR UNTRIPPABLE OR DROPPED CONTROL ROD CONDITION	Group	4
	(R or S, whichever is farthest withdrawn)	Inches	101
U.	IF the Control Rod position in S is farther withdrawn than the		

Control Rod position in **R**, <u>THEN</u> Caution Tag the Control Rod joy-stick on panel C-02, identifying that the new PPC PDIL as the Control Rod position in **S**.

9. **REVIEWS**

(Operators' Name)	/ (Te	oday)
Performed By		Date
	1	
Reviewed By		Date

Forward Completed Form to Reactor Engineering Supervisor

Reactor Engineering Supervisor

Date

PALISADES NUCLEAR PLANT

CANDIDATE CUE SHEET

(TO BE RETURNED TO EXAMINER TO UPON COMPLETION OF TASK)

INITIAL CONDITIONS:

- Rod #6 is inoperable and fully withdrawn.
- It is believed that the rod is untrippable.
- Burnup is 7,000 MWD/MTU.
- Rx power is 100%.
- PCS Boron is 865 ppm.
- All rods out, equilibrium Xenon.

INITIATING CUES:

The Control Room Supervisor directs you to determine the compensation for shutdown margin required for control rod #6 utilizing EM-04-08.

NRC REGION III INITIAL LICENSE EXAM JOB PERFORMANCE MEASURE

JPM: SRO ADMIN 1a

TITLE: DETERMINE COMPENSATION FOR A WITHDRAWN, INOPERABLE CONTROL ROD

CANDIDATE: _____

EXAMINER: _____

JOB PERFORMANCE MEASURE DATA PAGE

Task: Determine Compensation for a Withdrawn, Inoperable Control Rod
Alternate Path: N/A
Facility JPM #: PL-OPS-ENG-011J
K/A: 2.1.25 Importance:RO:3.9 SRO: 4.2
K/A Statement: Ability to interpret reference materials, such as graphs, curves, tables, etc.
Task Standard: EM-04-08, Attachment 1 properly completed per key.
Preferred Evaluation Location: ANYX
Preferred Evaluation Method: Perform_X_Simulate
References: EM-04-08, "Shutdown Margin Requirements"
Validation Time:20 minutes Time Critical: NO
Candidate:
Time Start: Time Finish:
Performance Time: minutes
Performance Rating: SAT UNSAT
Comments:
Examiner: Date:
Signature

EXAMINER COPY ONLY

Tools/Equipment/Procedures Needed:

EM-04-08, "Shutdown Margin Requirements" Technical Data Book Calculator

READ TO CANDIDATE

DIRECTION TO CANDIDATE:

I will explain the initial conditions, and state the task to be performed. All control room steps shall be performed for this JPM, including any required communications. I will provide initiating cues and reports on other actions when directed by you. Ensure you indicate to me when you understand your assigned task. To indicate that you have completed your assigned task return the handout sheet I provided you.

INITIAL CONDITIONS:

- Rod #6 is inoperable and fully withdrawn.
- It is believed that the rod is untrippable.
- Burnup is 7,000 MWD/MTU.
- Rx power is 100%.
- PCS Boron is 865 ppm.
- All rods out, equilibrium Xenon.

INITIATING CUES:

The Control Room Supervisor directs you to determine the compensation for shutdown margin required for control rod #6 utilizing EM-04-08.

[Provide a calculator to the examinee for this JPM.]

EVALUATOR CUE: Provide candidate a working copy of EM-04-08 Attachment 1.

Proc. Step	TASK ELEMENT 1	STANDARD	Grade
1	Record inoperable control rod identification.	'A', '6' and 'untrippable' recorded.	SU
Comment CRITICA	:: L STEP		

Proc. Step	TASK ELEMENT 2	STANDARD	Grade
2	Record worth of inoperable control rod.	'1.17 (1.16 to 1.18)' entered.	sυ
Commen EVALU CRITICA	nt: JATOR CUE: Reactor Engineering NL STEP	y is not available.	

Proc. Step	TASK ELEMENT 3	STANDARD	Grade
3	Record source of inoperable control rod worth data.	'Tech Data Book' entered.	SU
Comment	:		

Proc. Step	TASK ELEMENT 4	STANDARD	Grade
4.A	Record current cycle burnup.	Record current cycle burnup = 7000.	SU
Comment CRITICA	t: L STEP		

Proc. Step	TASK ELEMENT 5	STANDARD	Grade
4.B	Record current power level.	'100' entered.	SU
Commen	t:	· · · · · · · · · · · · · · · · · · ·	

Proc. Step	TASK ELEMENT 6	STANDARD	Grade
4.C	Control rod worth inserted into core.	'0' and 'Gp 4 @ 131/132" entered.	SU
Comment CRITICA	t: L STEP		

Proc. Step	TASK ELEMENT 7	STANDARD	Grade
4.D	Record PCS Boron concentration.	'865' entered.	SU
Comment	t:		

Proc. Step	TASK ELEMENT 8	STANDARD	Grade			
5.E	Determine and record worth of control rods at current power level.	'7.05 (7.04 to 7.06)' entered.	SU			
Comment: EVALUATOR NOTE: This will need to be obtained by interpolation of the graph.						
CRITICAL STEP						

Proc. Step	TASK ELEMENT 9	STANDARD	Grade		
5.F	Determine and record max worth of stuck rod at current power.	'1.17 (1.16 to 1.18)' entered.	SU		
Comment:					
CRITICAL STEP					

Proc. Step	TASK ELEMENT 10	STANDARD	Grade			
5.G	Determine and record PCS boron concentration at 100% at 7000 MWD/MTU.	'865 (860 to 870)' entered.	SU			
Comment	:					
CRITICA	CRITICAL STEP					

Proc. Step	TASK ELEMENT 11	STANDARD	Grade	
5.H	Determine and record power defect for 100% power.	'1.53 (1.51 to 1.55)' entered.	SU	
Comment:				
CRITICA	_STEP			

Proc. Step	TASK ELEMENT 12	STANDARD	Grade
5.1	Determine and record power defect at current power level.	'1.53 (1.51 to 1.55)' entered.	SU
Comment:			

Proc. Step	TASK ELEMENT 13	STANDARD	Grade
5.J	Determine and record required SDM.	'2.0' already entered.	SU
Comment	:		

Proc. Step	TASK ELEMENT 14	STANDARD	Grade	
6.K	Calculate Net amount of shutdown margin.	'1.82 (1.80 to 1.84)' entered.	SU	
Comment: CRITICAL STEP				

Proc. Step	TASK ELEMENT 15	STANDARD	Grade	
6.L	Enter worth of untrippable rod.	'1.17 (1.16 to 1.18)' entered.	SU	
Comment: CRITICAL STEP				

Proc. Step	TASK ELEMENT 16	STANDARD	Grade
6.M	Determine excess shutdown margin with the inoperable rod.	'0.65 (0.645 to 0.655)' entered. Determines Step 7 substeps are 'N/A'.	sυ
Comment CRITICA	:: L STEP		

•

Proc. Step	TASK ELEMENT 17	STANDARD	Grade
7.N-Q	IF Shutdown margin is negative, THEN	Determines Step 7 substeps are 'N/A'.	SU
Comment:			

Proc. Step	TASK ELEMENT 18	STANDARD	Grade	
8.R	Determine and record PPC PDIL for current power level.	'Group 4 at 101" (100 to 105)' entered.	SU	
Comment:				
CRITICAL STEP				

Proc. Step	TASK ELEMENT 19	STANDARD	Grade
8.S	Determine and record control rod position corresponding to excess shutdown margin.	'Group 4 at 20" (18 to 22)' entered.	SU
Comment CRITICAI	STEP		

Proc. Step	TASK ELEMENT 20	STANDARD	Grade
8.T	Determine and record PDIL for inoperable control rod condition.	'Group 4 at 101" (100 to 105)' entered.	SU
Comment	:		
CRITICA	- STEP		
JPM SRO ADMIN 1a

Proc. Step	TASK ELEMENT 21	STANDARD	Grade			
8.U	Determine if Caution Tagging Control Room joy-stick on Panel C-02 is NOT required.	Determines Caution Tagging Control Room joy-stick on Panel C-02 is NOT required.	SU			
Comment:						

Proc. Step	TASK ELEMENT 22	STANDARD	Grade
9	Sign and date Step 9.	Operator signs and dates.	SU
Comment			

Proc. Step	TASK ELEMENT 23	STANDARD	Grade		
N/A	Report results to Control Room Supervisor.	CRS notified.	sυ		
Comment: EVALUATOR CUE: End JPM Note: Attach completed EM-04-08, Attachment 1 to this JPM					

END OF TASK

SIMULATOR OPERATOR INSTRUCTIONS

NONE

UNTRIPPABLE OR DROPPED CONTROL RO	D
SHUTDOWN MARGIN CALCULATION	

1.	UNTR	UNTRIPPABLE OR DROPPED CONTROL ROD IDENTIFICATION:							
	GROL	JP <u>A</u> NUMBER <u>6</u>							
	COND	DITION <u>untrippable</u> (Untrippable or Dropped)							
2.	WORT CONT (TDB I	TH OF UNTRIPPABLE OR DROPPED 1.17 ROL ROD Figure 1.1 or Reactor Engineering)	%Δρ						
3.	SOUR	CE OF UNTRIPPABLE OR DROPPED CONTROL ROD WO	RTH DATA:						
		Tech Data Book							
4.	REFE	RENCE DATA							
	A.	CURRENT CYCLE BURNUP (TDB Fig 1.10)		MWd/MTU					
	В.	CURRENT REACTOR POWER LEVEL (Percent of Rated Power)	100	%					
	C.	CONTROL ROD WORTH INSERTED INTO CORE (TDB Fig 1.3)	0	%Δρ					
		GROUP <u>4</u> INCHES <u>132 (or 131)</u>							
		This Control Rod worth does not include the worth of a dropped Control Rod.							
	D.	PCS BORON CONCENTRATION (Chemistry Log or Reactor Logbook)	865	ppm					

Proc No EM-04-08 Attachment 1 Revision 30 Page 2 of 4

UNTRIPPABLE OR DROPPED CONTROL ROD SHUTDOWN MARGIN CALCULATION

5. GENERAL DATA

E.	WORTH OF ALL CONTROL RODS AT A (TDB Fig 1.1)	7.05	%Δρ
F.	MAXIMUM WORTH OF STUCK CONTROL ROD AT A (TDB Fig 1.1)		%Δρ
G.	PCS BORON AT 100% POWER AT A (TDB Fig 6.1, Reactor Log)	865	ppm
H.	POWER DEFECT AT 100% POWER (TDB Fig 3.2 and G)	<u> 1.53 </u>	%Δρ
I.	POWER DEFECT AT POWER B		
	$\frac{H \times B}{100} = \frac{(1.53) \times (100)}{100} =$	1.53	%Δρ
J.	REQUIRED SHUTDOWN MARGIN (4 PCPs Operating)	2.0	%Δρ

6. CALCULATION

K. NET AMOUNT OF SHUTDOWN MARC

$$\frac{(\mathbf{E} - \mathbf{C} - \mathbf{F})}{1.1} - \mathbf{I} - \mathbf{J}$$
$$= \frac{[(7.05) - (0) - 1.17]}{1.1} - (1.53) - (2.0) = \frac{1.82}{1.00} \% \Delta \rho$$

PALISADES NUCLEAR PLANT

	UNTRIPPABLE OR DROPPED CONTROL ROD SHUTDOWN MARGIN CALCULATION		Proc No EM-04-08 Attachment 1 Revision 30 Page 3 of 4
L.	WORTH OF UNTRIPPABLE OR DROPPED CONTROL ROD Step 2	1.17	%Δρ
M.	EXCESS SHUTDOWN MARGIN WITH ONE UNTRIPPABLE OR DROPPED CONTROL ROD		
	K - L = (1.82) - (1.17) =	0.65	%Δρ

7.

IF excess Shutdown Margin (M) is **NEGATIVE**, **<u>THEN</u>** borate the PCS to reduce reactor power until **M** is **POSITIVE** performing Steps **N** through **Q** to calculate the maximum reduced reactor power level.

N. POWER DEFECT AT REDUCED POWER

 $I + M = () + () = \frac{N/A}{2} % \Delta \rho$

O. MAXIMUM REDUCED POWER LEVEL

$$\frac{\mathbf{N} \times \mathbf{B}}{\mathbf{I}} = \frac{() \times ()}{()} = \frac{\mathbf{N}/\mathbf{A}}{\mathbf{N}}^{\%}$$

- P. Caution Tag the Control Rod joy-stick on panel C-02 that the new PDIL is Control Rod position at **C**. N/A
- Q. **IF** power reduction is required, **THEN** after power reduction re-perform <u>Attachment 1</u> to verify Shutdown Margin N/A requirements are satisfied.

.

UNTRIPPABLE OR DROPPED CONTROL ROD SHUTDOWN MARGIN CALCULATION

Proc No EM-04-08 Attachment 1 Revision 30 Page 4 of 4

8. **IF M** is **POSITIVE**, <u>**THEN**</u> sufficient Shutdown Margin is available and no power reduction is necessary to ensure required Shutdown Margin. Perform Steps **R** though **U** to determine maximum allowable Control Rod insertion limit corresponding to excess Shutdown Margin available (**M**).

R.	PPC PDIL FOR CURRENT POWER LEVEL (TDB Fig 1.9)	Group	4
		Inches	101
S.	CONTROL ROD POSITION CORRESPONDING	Group	4
	(TDB Fig 1.3 or 5.1 and M)	Inches	20
Т.	PDIL FOR UNTRIPPABLE OR DROPPED CONTROL ROD CONDITION	Group	4
	(R or S, whichever is farthest withdrawn)	Inches	<u> 101 </u>
U.	IF the Control Rod position in S is farther withdrawn than the		

Control Rod position in **R**, <u>THEN</u> Caution Tag the Control Rod N/A joy-stick on panel C-02, identifying that the new PPC PDIL as the Control Rod position in **S**.

9. REVIEWS

(Operators' Name)	1	(Today)
Performed By		Date
	1	
Reviewed By	/	Date

Forward Completed Form to Reactor Engineering Supervisor

Reactor Engineering Supervisor

Date

PALISADES NUCLEAR PLANT

CANDIDATE CUE SHEET

(TO BE RETURNED TO EXAMINER TO UPON COMPLETION OF TASK)

INITIAL CONDITIONS:

- Rod #6 is inoperable and fully withdrawn.
- It is believed that the rod is untrippable.
- Burnup is 7,000 MWD/MTU.
- Rx power is 100%.
- PCS Boron is 865 ppm.
- All rods out, equilibrium Xenon.

INITIATING CUES:

The Control Room Supervisor directs you to determine the compensation for shutdown margin required for control rod #6 utilizing EM-04-08.

NRC REGION III INITIAL LICENSE EXAM JOB PERFORMANCE MEASURE

JPM: SRO ADMIN 1b

TITLE: CALCULATE BLEND RATIO FOR MAKEUP TO SIRWT

CANDIDATE: ____

EXAMINER:

JOB PERFORMANCE MEASURE DATA PAGE

Task: Perforn	n Safety Injection	Refuelin	g Wate	r Tank C	Operatio	ns	
Alternate Path:	N/A						
Facility JPM #:	PL-OPS-ENG-0	19J					
K/A: 2.1.34	Importa	nce: F	RO:	2.3	SRO:	2.9	
K/A Statement:	Ability to mainta allowable limits.	in primar	y and s	econdar	y plant o	chemistry	/ within
Task Standard:	Correct volume addition to SIRV	of Boric / VT	Acid and	d Primar	y Make	up Water	Calculated fo
Preferred Evalu	ation Location:	Any	_X_				
Preferred Evalu	ation Method:	Perforn	n _X_	Sim	ulate		
References:	SOP-2A, "Cherr Technical Data	nical and Book, fig	Volume ure 8.2	Control	System	า"	
Validation Time	e: _12_ minute	es -	Time Cr	itical:	NO		
Candidate:							
Time Start:	Tim	e Finish:					
Performance Ti	me:	minute	es				
Performance R	ating: SAT	(UNSAT				
Comments:							
Examiner:	Signati	ure			Date:		

EXAMINER COPY ONLY

Tools/Equipment/Procedures Needed:

- SOP-2A, "Chemical and Volume Control System"
- Calculator
- Pencil and paper

READ TO CANDIDATE

DIRECTION TO CANDIDATE:

I will explain the initial conditions, and state the task to be performed. All control room steps shall be performed for this JPM, including any required communications. I will provide initiating cues and reports on other actions when directed by you. Ensure you indicate to me when you understand your assigned task. To indicate that you have completed your assigned task return the handout sheet I provided you.

INITIAL CONDITIONS:

- Safety Injection Refueling Water Storage Tank boron concentration = 2149ppm
- Safety Injection Refueling Water Storage Tank level = 96%
- Boric Acid Storage Tank T-53A boron concentration = 12,524ppm

INITIATING CUES:

The Control Room Supervisor directs you to perform SOP-2A section 7.6.1.a to calculate the volumes of Boric Acid and Primary Makeup water needed to raise SIRWT level by 3000 gallons while maintaining current SIRWT boron concentration.

JPM SRO ADMIN 1b

Proc. Step	TASK ELEMENT 1	STANDARD	Grade			
7.6.1.a Caution	During makeup operations to the SIRWT:					
	1. Makeup to the volume control tank is not available.					
	2. Opening CV-2155, Boric Acid Blender Outlet Control Valve, will inject the blended batch intended for the SIRWT into the PCS.	Operator reviews caution	SU			
	3. Additions that exceed 2500 ppm may result in exceeding boron concentration limits of Technical Specifications LCO 3.5.4. SITs may also be affected during fill and drain operations					
Comment:	Comment:					

EVALUATOR CUE: Provide candidate a working copy of SOP-2A Section 7.6.1

Proc. Step	TASK ELEMENT 2	STANDARD	Grade
7.6.1.a.1	To determine the amount of boric acid and primary makeup water to be transferred to SIRW tank, REFER TO the following formulas: SIRW Tank Volume = (% meter reading x 2797) + 18,646 Where: SIRW Tank Volume = SIRW total gallons % meter reading = LIA-0332A or LIA-0331.	Operator calculates the following: Amount of volume to add = 3000 gallons (give in initial conditions)	SU
Comment:			

JPM SRO ADMIN 1b

Proc. Step	TASK ELEMENT 3	STANDARD	Grade	
	Blend Ratio = (BAST ppm/SIRW ppm) - 1			
	Where:	Operator calculates the following:		
7.6.1.a.2	Blend Ratio = gallons of PMW per 1 gallon of concentrated Boric Acid BAST ppm = 12,524 SIRWT ppm = 2149	(12,524/2149) – 1 = 4.83 (allow 4.80 – 4.85)	SU	
Comment:				
EVALUATOR NOTE: Allow 4.80 to 4.86 CRITICAL STEP				

Proc. Step	TASK ELEMENT 4	STANDARD	Grade
	Gallons of concentrated boric acid to add = Total Volume Makeup to SIRW/(Blend Ratio + 1)		
	Where:		
7.6.1.a.3	Total Volume Makeup to SIRWT =	Operator calculates the following:	su
	Desired SIRWT level in gallons minus current level in gallons	3000/(4.83 + 1) = 514.6 gal of boric acid	
	Blend Ratio = gallons of PMW per 1 gallon of concentrated Boric Acid		
Comment:			
EVALU	ATOR NOTE: Allow 511.9 – 517.2	2	
CRITICAL	STEP		

JPM SRO ADMIN 1b

Proc. Step	TASK ELEMENT 5	STANDARD	Grade	
	Gallons of PMW to add = Total volume makeup to SIRWT - Gallons of Boric Acid to add			
	Where:	Operator calculates the following:		
7.6.1.a.4	Total Volume Makeup to SIRWT = Desired SIRWT level in gallons minus current level in gallons	3000 – 514.6 = 2485.4 gal of PMW	SU	
	Gallons of Boric Acid to Add = Item 3. above			
Comment:				
EVALUA	ATOR NOTE: Allow 2483 – 2488			
CRITICAL STEP				

Proc. Step	TASK ELEMENT 6	STANDARD	Grade
n/a	Operator informs Control Room Supervisor of the volume of boric acid and primary makeup water to add.	CRS informed of the following volumes: Primary Makeup Water: 2485.4 gal Concentrated Boric Acid: 514.6 gal	SU

Comment:

EVALUATOR NOTE: Allow 2483 – 2488 gal for Primary Makeup Water and 511.9 – 517.2 gal for Boric Acid

EVALUATOR CUE: Role play as CRS

END OF TASK

SIMULATOR OPERATOR INSTRUCTIONS

• NONE

CANDIDATE CUE SHEET

(TO BE RETURNED TO EXAMINER TO UPON COMPLETION OF TASK)

INITIAL CONDITIONS:

- Safety Injection Refueling Water Storage Tank boron concentration = 2149ppm
- Safety Injection Refueling Water Storage Tank level = 96%
- Boric Acid Storage Tank T-53A boron concentration = 12,524ppm

INITIATING CUES:

The Control Room Supervisor directs you to perform SOP-2A section 7.6.1.a to calculate the volumes of Boric Acid and Primary Makeup water needed to raise SIRWT level by 3000 gallons while maintaining current SIRWT boron concentration.

NRC REGION III INITIAL LICENSE EXAM JOB PERFORMANCE MEASURE

JPM: SRO ADMIN 2

TITLE: APPROVE A HEAVY LOAD MOVEMENT

CANDIDATE: _____

EXAMINER:

JOB PERFORMANCE MEASURE DATA PAGE

Task: Approve a heavy load movement
Alternate Path: N/A
Facility JPM #: PL-OPS-ADM-001J
K/A: 2.2.14 Importance: SRO: 4.3
K/A Statement: Knowledge of the process for controlling equipment configuration or status
Task Standard: Approve a heavy load movement, ensuring all prerequisites and operational requirements are met.
Preferred Evaluation Location: ANYX
Preferred Evaluation Method: PerformX Simulate
References: FHS-M-23, "Movement of Heavy Loads in The Spent Fuel Pool Area" Administrative Procedure AP 4.02, "Control Of Equipment"
Validation Time: 20 minutes Time Critical: NO
Candidate:
Time Start: Time Finish:
Performance Time: minutes
Performance Rating: SAT UNSAT
Comments:
Examiner: Date:

EXAMINER COPY ONLY

Tools/Equipment/Procedures Needed:

FHS-M-23, "Movement of Heavy Loads in The Spent Fuel Pool Area," Attachment 1, Heavy Load Data Sheet, with applicable sections completed by Heavy Load Person In Charge (HL PIC)

Also see **Simulator Operator Instructions** (last page of this document).

READ TO CANDIDATE

DIRECTION TO CANDIDATE:

I will explain the initial conditions, and state the task to be performed. All control room steps shall be performed for this JPM, including any required communications. I will provide initiating cues and reports on other actions when directed by you. Ensure you indicate to me when you understand your assigned task. To indicate that you have completed your assigned task return the handout sheet I provided you.

INITIAL CONDITIONS:

- The Plant is in Mode 1
- A refueling outage was completed 95 days ago, with all spent fuel from the core stored in the south end of the Spent Fuel Pool
- You are an on-shift SRO
- It is Tuesday, 'Night' shift, 1930 hours
- V-10, Radwaste Area Supply Fan; V-14A and V-14B Radwaste Area Exhaust Fan are in service
- Both Control Room HVAC trains for filtration and cooling are operable, with the left train in service, normal operation
- VF-66, Fuel Pool Area Refueling Charcoal Filter, is bypassed (not in service)
- V-7, Fuel Handling Area Supply Fan; V-8A and V-8B, Radwaste Area Exhaust Fans are in service
- Mechanical Maintenance has requested to move the MSB Shielding Lid from the Cask Washdown Pit onto the loaded fuel cask, in the Spent Fuel Pool
- This evolution is expected to begin immediately after authorization and to be completed by 2300 hours
- No other load movements are planned or in progress
- No fuel movement in the SFP is planned or in progress
- All spent fuel in the north tilt pit and has decayed for greater than one year

INITIATING CUES:

The Shift Manager directs you to approve the requested load movement, ensuring all Operational prerequisites and requirements are met prior to the approval.

EVALUATOR CUE Provide candidate the completed FHS-M-23, Att. 1 Working Copy.

Proc. Step	TASK ELEMENT 1	STANDARD	Grade
Att. 6	ls the load a heavy load (>1300 lbs)?	SRO determines: <u>YES</u> , Object is a heavy load (MSB Shield Lid weighs 6457 lbs from Att. 2)	รบ
Comment: EVALUA CRITICAL	ATOR CUE:Provide candidate with .STEP	a working copy of FHS-M-23.	

Proc. Step	TASK ELEMENT 2	STANDARD	Grade
Att. 6	Is the load movement within Load Path 3 only?	NO Heavy Load path #4 determined for movement of DFS components between cask wash-down pit and cask loading floor area, Att.3	SU

Comment:

EVALUATOR CUE: If asked by SRO what load move will be taking place, Reply: the MSB Shielding Lid is being moved from the Cask Wash-down area to the loaded fuel cask in the Spent Fuel Pool.

Evaluator Note: Candidate determines FHS-M-23 Attachment 1 working copy Block 7 "HL Path(s) Authorized For Use" is wrong and changes to reflect Load Path 4 (may be done at anytime prior to end of JPM).

CRITICAL STEP

Proc. Step	TASK ELEMENT 3	STANDARD	Grade
Att. 6	Will loads be moved over Load Path 1?	<u>NO</u>	รบ
Comment:			
EVALUA	ATOR CUE:If asked by SRO what lo Shielding Lid is being m	ad move will be taking place, Reply: the loved from the Cask Wash-down area to	erectory MSB Sthe

loaded fuel cask in the Spent Fuel Pool.

CRITICAL STEP

.

Proc. Step	TASK ELEMENT 4	STANDARD	Grade
Att. 6	Will loads be moved over Load Path 4 (Main Fuel Pool)?	YES	SU
Comment:			

Evaluator Note: Candidate determines FHS-M-23 Attachment 1 working copy Block 7 "HL Path(s) Authorized For Use" is wrong and changes to reflect Load Path 4 (may be done at anytime prior to end of JPM).

CRITICAL STEP

Proc. Step	TASK ELEMENT 5	STANDARD	Grade
Att. 6	Has fuel decayed ≥ 30 days?	YES (given in the initial conditions)	SU
Comment:			

Proc. Step	TASK ELEMENT 6	STANDARD	Grade
Att. 6	V-10, V-14A and V-14B inservice OR V-10 off and either V-14A OR V-14B inservice	V-10, V-14A and V-14B verified in-service	SU
Comment:			

Proc. Step	TASK ELEMENT 7	STANDARD	Grade
Att. 6	Both CRHVAC filtration operable (refer to TS 3.7.10 if one train inoperable)	Both CRHVAC filtration trains verified operable	SU
Comment:			

EVALUATOR CUE: If asked by SRO if both CRHVAC Filtration trains are operable, RESPOND: they are not on the LCO or LCO Annex sheet for being inoperable or degraded.

Proc. Step	TASK ELEMENT 8	STANDARD	Grade
Att. 6	Both CRHVAC cooling operable (refer to TS 3.7.11 if one train inoperable)	Both CRHVAC cooling trains verified operable	sυ
Comment: EVALUA	ATOR CUE: If asked by SRO if both RESPOND: they are not inoperable or degraded.	CRHVAC cooling trains are operable, on the LCO or LCO Annex sheet, for bei	ng

Proc. Step	TASK ELEMENT 9	STANDARD	Grade
Att. 6	Has fuel decayed ≥ 90 days?	YES (given in the initial conditions)	SU
Comment:			

Proc. Step	TASK ELEMENT 10	STANDARD	Grade
Att. 6	VF-66 maybe bypassed OR out of service At least one V-8 shall be inservice	One V-8 fan verified inservice	SU
Comment:			

Proc. Step	TASK ELEMENT 11	STANDARD	Grade
Att. 6	Will loads be moved over Load Path 2?	NO	SU

Comment:

Evaluator Note: Candidate determines FHS-M-23 Attachment 1 working copy Block 7 "HL Path(s) Authorized For Use" is wrong and changes to reflect Load Path 4 (may be done at anytime prior to end of JPM).

CRITICAL STEP

Proc. Step	TASK ELEMENT 12	STANDARD	Grade
Att. 6	Will loads be moved over Load Path 3?	NO	SU
Comment:			

Proc. Step	TASK ELEMENT 13	STANDARD	Grade
Att. 6	Will non-heavy loads be moved under this procedure?	<u>NO</u> (given in initial conditions)	SU
Comment:			

Proc. Step	TASK ELEMENT 14	STANDARD	Grade
Att. 6	Will load be moved in an alternate path?	NO (Path 4 is the only path for this evolution)	SU
Comment:			

Proc. Step	TASK ELEMENT 15	STANDARD	Grade
5.1.1a	On-Shift, Duty SRO <u>shall</u> : Review and understand Sections 1.0 through 4.0 of procedure.	SRO references Section 1.0 through 4.0, and ensures: No fuel movements in SFP Area (given in initial conditions)	SU
Comment:			

Proc. Step	TASK ELEMENT 16	STANDARD	Grade
5.1.1b	On-Shift, Duty SRO <u>shall</u> : ENSURE plant systems and conditions are met.	SRO verifies plant systems and conditions are met (has effectively completed this step by ensuring Att. 6 complete)	SU
Comment:			

Proc. Step	TASK ELEMENT 17	STANDARD	Grade
	On-Shift, Duty SRO shall: Complete Attachment 1 to document	SRO enters on FHS-M-23, Att. 1: <u>Signs, Dates and Times</u> , in box (8)	
5.1.1c	permission to commence heavy load movement for approved Load Paths during specified time period.	<u>Today/1930</u> for Start in box (9) <u>Today/2300 OR 0700 tomorrow/ Signed</u> for Stop in box(9)	SU

Comment:

Evaluator Note: Candidate determines FHS-M-23 Attachment 1 working copy Block 7 "HL Path(s) Authorized For Use" is wrong and changes to reflect Load Path 4 (may be done at anytime prior to end of JPM).

Evaluator Note: one-week duration limit found in Section 3.1.3d CRITICAL STEP

Proc. Step	TASK ELEMENT 18	STANDARD	Grade
	On-Shift, Duty SRO <u>shall</u> :		
5.1.1.d	DOCUMENT authorization of heavy loads movements in the Operations log.	SRO makes log entry.	SU
Comment:			
1			

END OF TASK

SIMULATOR OPERATOR INSTRUCTIONS

• N/A

(1) Date: <u>TODAY</u>		(2) Work Or	der N	o: <u>5199999</u>		(3) Authoriza x Shift	tion Perioo □ Daily	d: □Week
(4) Procedure used in conju w/FHS-M-23: <u>NONE</u>	unction	(5) Special p <u>Measure gir</u>	oreca der te	utions to be taken: emperature for single fai	ilure power l	ift		
(6) General Description of HL(s) Allowed To Be Moved (Can attach schedule to satisfy)		(7) HL Path(s) Authorized For Use		(8) Approved By: On-Shift, Duty SRO (Name / Date / Time)		(9) HL Duration Approved Start: (Date / Time) Stop: (Date / Time)		
MSB Shielding Lid		4		J Operator/ TODAY /	NOW	START:	TODAY	<u>1930</u>
	· · · · · · · · · · · · · · · · · · ·					STOP:	TODAY (O Tomorrow	<u>R 2300 (OR</u> /) <u>0700)</u>
		<u>(10) (</u>	CALIB	RATED EQUIPMENT (If	Required)			
Equipment Description	Range / A	ccuracy	-	Serial Number	Calibr	ation Date	Ca	ibration Due Date
FLUKE Model 8660	0-200°F/	±.02°F		CMS234567	06/	01/2010		06/01/2011
	·							
(11) HL PIC Name / Date / Time (Print)	(12) Inspe Comp	Crane ection lete (√)	(1 N	3) Crane Operator lame / Date / Time (Print)	(14) Sig Name / (gnal Person Date / Time Print)	(15) C	On-Shift, Duty SRO ontacted Name (Print)
J JOHNSON/ TODAY/ NOV	N 2	X						
				<u></u>		···· - · · · · · · · · · · · · · · · ·		
								<u></u>
·				<u> </u>				
ANSWER KEY	ANSWER M	KEY		ANSWER KEY	ANS	SWER KEY		ANSWER KEY

PALISADES NUCLEAR PLANT

HEAVY LOAD DATA SHEET

Instructions for completion of Attachment 1:

- 1. **ENTER** today's date.
- 2. ENTER Work Order number that controls movement of heavy loads.

NOTE: Heavy Load Person-in-Charge will contact the Work Control Center or Control Room each shift to ensure that plant conditions have not changed.

- 3. **CHECK** time period where authorization from an On-Shift Duty SRO will be required (Shift, Daily, or Week).
- 4. ENTER any procedure used in conjunction with FHS-M-23.
- 5. ENTER any special precautions or temperature measurements for bridge girder (See Step 3.4.1h).
- 6. ATTACH schedule information to Attachment 1 or list general description of heavy loads to be moved.
- 7. LIST heavy load paths authorized for use.
- **NOTE:** This information is only required to approve the beginning of heavy load movements for an extended load move campaign. All subsequent authorizations can be handled over the phone (See Section 3.1).
- 8. On-Shift, Duty SRO **PRINT** name, date, and time (SRO authorization required before starting heavy load movements. SRO authorization confirms plant/system/component conditions are met. SRO signature not required for Load Path No 3 or non-heavy loads covered under this procedure).
- 9. LIST START date and time. LIST STOP date and time (this can not exceed time period authorized in Step No 3).
- 10. Enter calibrated equipment information.

NOTE: Multiple Page 3 of this attachment may be used for an extended moving campaign.

- 11. Heavy Load Person-in-Charge (HL PIC) **PRINT** name, date, and time (HL PIC signoff confirms proper load path, weight, & rigging requirements are understood and will be met. Each time HL PIC changes, new information shall be entered).
- 12. Crane Inspection requires Crane Operator to ENSURE daily crane inspection is completed. PLACE a check (□) in the box next to the Crane Operator that performed the inspection.
- 13. Crane Operator **PRINT** name, date, and time (Crane Operator signoff confirms understanding of heavy load requirements AND that all heavy load prerequisites, precautions & limitation, and equipment/plant safety or limits are met. Each time Crane Operator changes, new information shall be entered).
- 14. Signal Person **PRINT** name, date, and time (Signal Person signoff confirms understanding of heavy load requirements AND that all heavy load prerequisites, precautions & limitation, and equipment/plant safety or limits are met. Each time Signal Person changes, new information shall be entered).
- 15. Heavy Load Person-in-Charge will **DOCUMENT** On-Shift, Duty SRO that was contacted by printing name.
- 16. Page 3 duplicates the information recorded in Items 11 through 15.
- 17. DESCRIBE Alternate Load Path (assistance may be required from Engineering to best determine how to best fulfill Step 5.1.4i). CIRCLE YES or NO for Attachment.
- 18. IF alternate load path is required, THEN OBTAIN Reactor Engineer approval. [CMT891009645, CMT922001477]
- 19. IF alternate load path is required, THEN **OBTAIN** On-Shift Duty SRO approval. [CMT891009645]
- 20. **PROVIDE** a sketch in the space provided (when adequate space is not available, an Attachment can be attached -- See Item 17).

Proc No FHS-M-23

HEAVY LOAD DATA SHEET

Attachment 1 Revision 29

					Pa	age 2 of 4
(1) Date: <u>TODAY</u>		(2) Work Order No: <u>5199999</u>			(3) Authorizatio	n Period: Daily
(4) Procedure used in conju w/FHS-M-23: <u>NONE</u>	Inction	(5) Special pre Measure girder	ecautions to be taken: temperature for single failu	ire power lift		
(6) General Description of H To Be Moved (Can attach schedule t	IL(s) Allowed o satisfy)	(7) HL Path(Authorized F Use	s) (8) Approved By: On for SRO (Name / Date /	-Shift, Duty Time)	(9) HL Start: (Date / Ti	Duration Approved me) Stop: (Date / Time)
MSB Shielding Lid		2		/	START: STOP:	
Equipment Description			Sorial Number	<u>(Required)</u>	ation Data	Calibration Due Date
FLUKE Model 8660	0-200°F/	± .02°F	CMS234567	06/	01/2010	06/01/2011
(11) HL PIC Name / Date / Time (Print)	(12) (Inspe Compl	Crane ction ete (√)	(13) Crane Operator Name / Date / Time (Print)	(14) Sig Name /	g nal Person Date / Time Print)	(15) On-Shift, Duty SRO Contacted Name (Print)
J JOHNSON/ TODAY/ NOW						

PALISADES NUCLEAR PLANT

AUGUST 2010

Proc No FHS-M-23

Attachment 1

HEAVY LOAD DATA SHEET

		HEAVY LOAD DATA SHEET		Revision 29 Page 3 of 4
(16) (11) HL PIC Name / Date / Time (Print)	(12) Crane Inspection Complete (√)	(13) Crane Operator Name / Date / Time (Print)	(14) Signal Person Name / Date / Time (Print)	(15) On-Shift, Duty SRO Contacted Name (Print)
		······································		
· · · · · · · · · · · · · · · · · · ·				
	······			
		· · · · · · · · · · · · · · · · · · ·		
· · · · · · · · · · · · · · · · · · ·				
······································				
	· · · · · · · · · · · · · · · · · · ·			

HEAVY LOAD DATA SHEET

Proc No FHS-M-23 Attachment 1 Revision 29 Page 4 of 4

		 			Attachment (YES / NO)
(18) Approved By:		1	(19) Approved By:		1
	Reactor Engineer	 Date		On-Shift, Duty SRO	Dat
(20) Attach sketch,	if necessary.				

CANDIDATE CUE SHEET

(TO BE RETURNED TO EXAMINER UPON COMPLETION OF TASK)

INITIAL CONDITIONS:

- The Plant is in Mode 1
- A refueling outage was completed 95 days ago, with all spent fuel from the core stored in the south end of the Spent Fuel Pool
- You are an on-shift SRO
- It is Tuesday, 'Night' shift, 1930 hours
- V-10, Radwaste Area Supply Fan; V-14A and V-14B Radwaste Area Exhaust Fan are in service
- Both Control Room HVAC trains for filtration and cooling are operable, with the left train in service, normal operation
- VF-66, Fuel Pool Area Refueling Charcoal Filter, is bypassed (not in service)
- V-7, Fuel Handling Area Supply Fan; V-8A and V-8B, Radwaste Area Exhaust Fans are in service
- Mechanical Maintenance has requested to move the MSB Shielding Lid from the Cask Washdown Pit onto the loaded fuel cask, in the Spent Fuel Pool
- This evolution is expected to begin immediately after authorization and to be completed by 2300 hours
- No other load movements are planned or in progress
- No fuel movement in the SFP is planned or in progress
- All spent fuel in the north tilt pit and has decayed for greater than one year

INITIATING CUES:

The Shift Manager directs you to approve the requested load movement, ensuring all Operational prerequisites and requirements are met prior to the approval

NRC REGION III

INITIAL LICENSE EXAM

JOB PERFORMANCE MEASURE

JPM: SRO ADMIN 3

TITLE: DETERMINE INCREASED MONITORING ACTIONS PER ONP-23.2, STEAM GENERATOR TUBE LEAK PROCEDURE

CANDIDATE: _____

EXAMINER:

JOB PERFORMANCE MEASURE DATA PAGE

Task:	Respond to	Steam Generat	tor Tube leal	kage in a	accordance with ONP-23.	2
Alternat	e Path:	N/A				
Facility	JPM #:	NEW				
K/A:	2.3.11	Importance:	RO:3.8	SRO:	4.3	
K/A Sta	tement: Abil	lity to control rac	liation releas	ses.		
Task St	andard: Det 9.0I	ermines RIA-06 E+03 cpm)	31 count rat	e of 8.5E	E+03 cpm (allow 8.0E+03	to
Preferre	ed Evaluation	n Location: Sin	nulator	x	In Plant	
Preferre	ed Evaluation	n Method: Pe	rform	x	Simulate	
Referen	ices: ON	P-23.2, "Steam	Generator T	ube Lea	k"	
Validatio	on Time:	20 minute	s Time C	ritical:	NO	
Candida	ate:		·			
Time St	art:	Time F	inish:			
Perform	ance Time:	r	ninutes			
Perform	ance Rating	: SAT	_ UNSAT		•	
Comme	nts:					
Examine	er:	Signature			Date:	_

EXAMINER COPY ONLY

Tools/Equipment/Procedures Needed:

ONP-23.2, "Steam Generator Tube Leak"

Also see **Simulator Operator Instructions** (later page of this document).

READ TO CANDIDATE

DIRECTION TO CANDIDATE:

I will explain the initial conditions, and state the task to be performed. All control room steps shall be performed for this JPM, including any required communications. I will provide initiating cues and reports on other actions when directed by you. Ensure you indicate to me when you understand your assigned task. To indicate that you have completed your assigned task return the handout sheet I provided you.

INITIAL CONDITIONS:

- The Plant is at full power.
- A Steam Generator Tube Leak is in progress on the 'A' Steam Generator.
- ONP-23.2, Steam Generator Tube Leak Procedure has been entered.
- Current estimated primary to secondary leakage is 0.01 gpm and stable.
- PCS Gas Total Isotope = 0.5 µCi/cc
- Offgas flowrate = 4 cfm (taken within last 30 minutes).

INITIATING CUES:

During implementation of ONP-23.2, the Control Room Supervisor directs you to determine the new setpoint for RIA-0631, Condenser Offgas Monitor, per ONP-23.2, Attachment 2 Step 3a.

EVALUATOR CUE: Provide candidate a working copy of ONP-23.2.

Proc.Step	TASK ELEMENT 1	STANDARD	Grade
Att 2 step 3.a	ESTIMATE the count rate indication on RIA-0631, Condenser Off Gas Monitor, which would result in a 0.02 gpm primary to secondary leakrate. Refer to Attachment 1, "Estimation of Primary to Secondary Leakrate."	Refer to ONP-23.2 Attachment 1 page 2 of 3.	SU
Comment	:		

Proc.Step	TASK ELEMENT 2	STANDARD	Grade
Pg 2 Step 1	OBTAIN Condenser Off Gas flow rate (preferred) OR USE last known reading if taken within 24 hours.	Determines Off Gas flow rate = 4 cfm from initiating cue	SU
Commen	t:	·	

Proc.Step	TASK ELEMENT 3	STANDARD	Grade
Pg 2	OBTAIN "PCS Gas Total Isotope" from	Determines PCS Gas Total Isotope =	е II
Step 2	Chemistry using last known analysis.	0.5 μCi/cc from initiating cue.	30
Commen	t:		

Proc.Step	TASK ELEMENT 4	STANDARD	Grade
Pg 2 Step 3	DETERMINE maximum Primary to Secondary Leakrate based on current Action Level.	Determines 0.02 gpm (from Attachment 2 Step 3a.)	SU
Commen	t: IISTEP		

Proc.Step	TASK ELEMENT 5	STANDARD	Grade
Pg 2 Step 4	CALCULATE uncorrected leakrate using the following equation: Uncorrected Leakrate (µCi-gal/min-kg) = Primary to Secondary Leakrate (gal/min) X PCS Gas Total Isotope (µCi/cc) X 1000 (cc/kg)	Calculates uncorrected leakrate using formula: 0.02 gpm X 0.5 μCi/cc X 1000 = 10.0 μCi-gal/min-kg	SU
Commen	t: L STEP		

Proc.Step	TASK ELEMENT 6	STANDARD	Grade
Pgs 2&3 Step 5	ESTIMATE RIA-0631 count rate using the "Uncorrected Leakrate Graph" on page 3.	 Determines 8.5E+03 cpm using Attachment 1 pg 3 graph with 4 scfm Off Gas flowrate line and 2.0E+00 Uncorrected Leak Rate line. SIGNS "Completed By" on Attachment 1 pg 2.* Informs CRS of results and that "Reviewed By" signature is still required.* 	SU

Comment:

EVALUATOR NOTE: allow 8.0E+03 to 9.0E+03 cpm

EVALUATOR CUE: If notified as the CRS of reading and need for Review signature: Acknowledge. If asked if Attachment 2 steps should be completed: RESPOND that another operator will complete Attachment 2 steps.

* NOTE: Not part of the critical step

CRITICAL STEP

END OF TASK
SIMULATOR OPERATOR INSTRUCTIONS

- No Simulator setup required.
- It is preferred that this JPM be done separately from the simulator. If, by chance, candidate IS in the simulator while doing this JPM, THEN ensure the IC is an at-power IC.

CANDIDATE CUE SHEET

(TO BE RETURNED TO EXAMINER UPON COMPLETION OF TASK)

INITIAL CONDITIONS:

- The Plant is at full power.
- A Steam Generator Tube Leak is in progress on the 'A' Steam Generator.
- ONP-23.2, Steam Generator Tube Leak Procedure has been entered.
- Current estimated primary to secondary leakage is 0.01 gpm and stable.
- PCS Gas Total Isotope = 0.5 µCi/cc
- Offgas flowrate = 4 cfm (taken within last 30 minutes).

INITIATING CUES:

During implementation of ONP-23.2, the Control Room Supervisor directs you to determine the new setpoint for RIA-0631, Condenser Offgas Monitor, per ONP-23.2, Attachment 2 Step 3a.

NRC REGION III

INITIAL LICENSE EXAM

JOB PERFORMANCE MEASURE

JPM: SRO ADMIN 3

TITLE: DETERMINE INCREASED MONITORING ACTIONS PER ONP-23.2, STEAM GENERATOR TUBE LEAK PROCEDURE

CANDIDATE: _____

EXAMINER:

JOB PERFORMANCE MEASURE DATA PAGE

Task: Respond to Steam Generator Tube leakage in accordance with ONP-23.2					
Alternate Path:	N/A				
Facility JPM #:	NEW				
K/A: 2.3.11	Importance: RO:3	.8 SRO:	4.3		
K/A Statement: Abi	lity to control radiation	releases.			
Task Standard: Det 9.01	ermines RIA-0631 cou E+03 cpm)	nt rate of 8.5E	E+03 cpm (allow 8.0E+03 to		
Preferred Evaluation	n Location: Simulator	X	In Plant		
Preferred Evaluation	n Method: Perform	X	Simulate		
References: ON	P-23.2, "Steam Genera	ator Tube Lea	k"		
Validation Time:	20 minutes T	ime Critical:	NO		
Candidate:	· · · · · · · · · · · · · · · · · · ·				
Time Start:	Time Finish:				
Performance Time:	minute	S			
Performance Rating	g: SAT U	NSAT			
Comments:					
Examiner:	Signature		Date:		

EXAMINER COPY ONLY

Tools/Equipment/Procedures Needed:

ONP-23.2, "Steam Generator Tube Leak"

Also see **Simulator Operator Instructions** (later page of this document).

READ TO CANDIDATE

DIRECTION TO CANDIDATE:

I will explain the initial conditions, and state the task to be performed. All control room steps shall be performed for this JPM, including any required communications. I will provide initiating cues and reports on other actions when directed by you. Ensure you indicate to me when you understand your assigned task. To indicate that you have completed your assigned task return the handout sheet I provided you.

INITIAL CONDITIONS:

- The Plant is at full power.
- A Steam Generator Tube Leak is in progress on the 'A' Steam Generator.
- ONP-23.2, Steam Generator Tube Leak Procedure has been entered.
- Current estimated primary to secondary leakage is 0.01 gpm and stable.
- PCS Gas Total Isotope = 0.5 µCi/cc
- Offgas flowrate = 4 cfm (taken within last 30 minutes).

INITIATING CUES:

During implementation of ONP-23.2, the Control Room Supervisor directs you to determine the new setpoint for RIA-0631, Condenser Offgas Monitor, per ONP-23.2, Attachment 2 Step 3a.

EVALUATOR CUE: Provide candidate a working copy of ONP-23.2.

Proc.Step	TASK ELEMENT 1	STANDARD	Grade
Att 2 step 3.a	ESTIMATE the count rate indication on RIA-0631, Condenser Off Gas Monitor, which would result in a 0.02 gpm primary to secondary leakrate. Refer to Attachment 1, "Estimation of Primary to Secondary Leakrate."	Refer to ONP-23.2 Attachment 1 page 2 of 3.	SU
Comment	:		

Proc.Step	TASK ELEMENT 2	STANDARD	Grade
Pg 2 Step 1	OBTAIN Condenser Off Gas flow rate (preferred) OR USE last known reading if taken within 24 hours.	Determines Off Gas flow rate = 4 cfm from initiating cue	SU
Commen	t:		

Proc.Step	TASK ELEMENT 3	STANDARD	Grade
Pg 2 Step 2	OBTAIN "PCS Gas Total Isotope" from Chemistry using last known analysis.	Determines PCS Gas Total Isotope = 0.5 μCi/cc from initiating cue.	sυ
Commen	t:		

JPM SRO ADMIN 3

Proc.Step	TASK ELEMENT 4	STANDARD	Grade
Pg 2 Step 3	DETERMINE maximum Primary to Secondary Leakrate based on current Action Level.	Determines 0.02 gpm (from Attachment 2 Step 3a.)	SU
Commen	t:		
CRITICA	STEP		

Proc.Step	TASK ELEMENT 5	STANDARD	Grade			
Pg 2 Step 4	CALCULATE uncorrected leakrate using the following equation: Uncorrected Leakrate (µCi-gal/min-kg) = Primary to Secondary Leakrate (gal/min) X PCS Gas Total Isotope (µCi/cc) X 1000 (cc/kg)	Calculates uncorrected leakrate using formula: 0.02 gpm X 0.5 μCi/cc X 1000 = 10.0 μCi-gal/min-kg	SU			
Commen CRITICA	Comment: CRITICAL STEP					

Proc.Step	TASK ELEMENT 6	STANDARD	Grade
Pgs 2&3 Step 5	ESTIMATE RIA-0631 count rate using the "Uncorrected Leakrate Graph" on page 3.	 Determines 8.5E+03 cpm using Attachment 1 pg 3 graph with 4 scfm Off Gas flowrate line and 2.0E+00 Uncorrected Leak Rate line. SIGNS "Completed By" on Attachment 1 pg 2.* Informs CBS of results and that 	SU
		"Reviewed By" signature is still required.*	

Comment:

EVALUATOR NOTE: allow 8.0E+03 to 9.0E+03 cpm

EVALUATOR CUE: If notified as the CRS of reading and need for Review signature: Acknowledge. If asked if Attachment 2 steps should be completed: RESPOND that another operator will complete Attachment 2 steps.

* NOTE: Not part of the critical step

CRITICAL STEP

END OF TASK

SIMULATOR OPERATOR INSTRUCTIONS

- No Simulator setup required.
- It is preferred that this JPM be done separately from the simulator. If, by chance, candidate IS in the simulator while doing this JPM, THEN ensure the IC is an at-power IC.

CANDIDATE CUE SHEET

(TO BE RETURNED TO EXAMINER UPON COMPLETION OF TASK)

INITIAL CONDITIONS:

- The Plant is at full power.
- A Steam Generator Tube Leak is in progress on the 'A' Steam Generator.
- ONP-23.2, Steam Generator Tube Leak Procedure has been entered.
- Current estimated primary to secondary leakage is 0.01 gpm and stable.
- PCS Gas Total Isotope = 0.5 µCi/cc
- Offgas flowrate = 4 cfm (taken within last 30 minutes).

INITIATING CUES:

During implementation of ONP-23.2, the Control Room Supervisor directs you to determine the new setpoint for RIA-0631, Condenser Offgas Monitor, per ONP-23.2, Attachment 2 Step 3a.

NRC REGION III

INITIAL LICENSE EXAM

JOB PERFORMANCE MEASURE

JPM: SRO ADMIN 3

TITLE: DETERMINE INCREASED MONITORING ACTIONS PER ONP-23.2, STEAM GENERATOR TUBE LEAK PROCEDURE

CANDIDATE:

EXAMINER:

JOB PERFORMANCE MEASURE DATA PAGE

Task: Respond to Steam Generator Tube leakage in accordance with ONP-23.2				
Alternate Path:	N/A			
Facility JPM #:	NEW			
K/A: 2.3.11	Importance:	RO:3.8	SRO:	4.3
K/A Statement: Abi	lity to control rac	liation relea	ses.	
Task Standard: Det 9.01	ermines RIA-06 E+03 cpm)	31 count rat	e of 8.5E	+03 cpm (allow 8.0E+03 to
Preferred Evaluation	n Location: Sin	nulator	x	In Plant
Preferred Evaluation	n Method: Pe	rform	x	Simulate
References: ON	P-23.2, "Steam	Generator T	ube Lea	k"
Validation Time:	20 minute	s Time C	Critical:	NO
Candidate:	- Martin			
Time Start:	Time F	inish:		
Performance Time:	I	minutes		
Performance Rating	g: SAT	_ UNSAT	Г	
Comments:				
Examiner:	Signature			Date:

EXAMINER COPY ONLY

Tools/Equipment/Procedures Needed:

ONP-23.2, "Steam Generator Tube Leak"

Also see **Simulator Operator Instructions** (later page of this document).

READ TO CANDIDATE

DIRECTION TO CANDIDATE:

I will explain the initial conditions, and state the task to be performed. All control room steps shall be performed for this JPM, including any required communications. I will provide initiating cues and reports on other actions when directed by you. Ensure you indicate to me when you understand your assigned task. To indicate that you have completed your assigned task return the handout sheet I provided you.

INITIAL CONDITIONS:

- The Plant is at full power.
- A Steam Generator Tube Leak is in progress on the 'A' Steam Generator.
- ONP-23.2, Steam Generator Tube Leak Procedure has been entered.
- Current estimated primary to secondary leakage is 0.01 gpm and stable.
- PCS Gas Total Isotope = 0.5 µCi/cc
- Offgas flowrate = 4 cfm (taken within last 30 minutes).

INITIATING CUES:

During implementation of ONP-23.2, the Control Room Supervisor directs you to determine the new setpoint for RIA-0631, Condenser Offgas Monitor, per ONP-23.2, Attachment 2 Step 3a.

EVALUATOR CUE: Provide candidate a working copy of ONP-23.2.

Proc.Step	TASK ELEMENT 1	STANDARD	Grade
Att 2 step 3.a	ESTIMATE the count rate indication on RIA-0631, Condenser Off Gas Monitor, which would result in a 0.02 gpm primary to secondary leakrate. Refer to Attachment 1, "Estimation of Primary to Secondary Leakrate."	Refer to ONP-23.2 Attachment 1 page 2 of 3.	SU
Comment	:		

Proc.Step	TASK ELEMENT 2	STANDARD	Grade
Pg 2 Step 1	OBTAIN Condenser Off Gas flow rate (preferred) OR USE last known reading if taken within 24 hours.	Determines Off Gas flow rate = 4 cfm from initiating cue	SU
Commen	t:		

Proc.Step	TASK ELEMENT 3	STANDARD	Grade
Pg 2 Step 2	OBTAIN "PCS Gas Total Isotope" from Chemistry using last known analysis.	Determines PCS Gas Total Isotope = 0.5 μCi/cc from initiating cue.	SU
Commen	t:		

JPM SRO ADMIN 3

Proc.Step	TASK ELEMENT 4	STANDARD	Grade
Pg 2 Step 3	DETERMINE maximum Primary to Secondary Leakrate based on current Action Level.	Determines 0.02 gpm (from Attachment 2 Step 3a.)	SU
Commen	t:		
CRITICA	STEP		

Proc.Step	TASK ELEMENT 5	STANDARD	Grade
Pg 2	CALCULATE uncorrected leakrate using the following equation:	Calculates uncorrected leakrate using formula:	
Step 4	Primary to Secondary Leakrate (µCi-gai/min-kg) – PCS Gas Total Isotope (µCi/cc) X 1000 (cc/kg)	0.02 gpm X 0.5 μCi/cc X 1000 = 10.0 μCi-gal/min-kg	SU
Commen	t:		
CRITICA	STEP		

Proc.Step	TASK ELEMENT 6	STANDARD	Grade
Pgs 2&3 Step 5	ESTIMATE RIA-0631 count rate using the "Uncorrected Leakrate Graph" on page 3.	 Determines 8.5E+03 cpm using Attachment 1 pg 3 graph with 4 scfm Off Gas flowrate line and 2.0E+00 Uncorrected Leak Rate line. SIGNS "Completed By" on Attachment 1 pg 2.* Informs CRS of results and that "Reviewed By" signature is still required.* 	s u

Comment:

EVALUATOR NOTE: allow 8.0E+03 to 9.0E+03 cpm

EVALUATOR CUE: If notified as the CRS of reading and need for Review signature: Acknowledge. If asked if Attachment 2 steps should be completed: RESPOND that another operator will complete Attachment 2 steps.

* NOTE: Not part of the critical step

CRITICAL STEP

END OF TASK

Page 5 of 7

SIMULATOR OPERATOR INSTRUCTIONS

- No Simulator setup required.
- It is preferred that this JPM be done separately from the simulator. If, by chance, candidate IS in the simulator while doing this JPM, THEN ensure the IC is an at-power IC.

JPM SRO ADMIN 3

CANDIDATE CUE SHEET

(TO BE RETURNED TO EXAMINER UPON COMPLETION OF TASK)

INITIAL CONDITIONS:

- The Plant is at full power.
- A Steam Generator Tube Leak is in progress on the 'A' Steam Generator.
- ONP-23.2, Steam Generator Tube Leak Procedure has been entered.
- Current estimated primary to secondary leakage is 0.01 gpm and stable.
- PCS Gas Total Isotope = 0.5 µCi/cc
- Offgas flowrate = 4 cfm (taken within last 30 minutes).

INITIATING CUES:

During implementation of ONP-23.2, the Control Room Supervisor directs you to determine the new setpoint for RIA-0631, Condenser Offgas Monitor, per ONP-23.2, Attachment 2 Step 3a.

NRC REGION III INITIAL LICENSE EXAM JOB PERFORMANCE MEASURE

JPM: SRO ADMIN 4

TITLE: CLASSIFY EVENT AND DETERMINE PAR

CANDIDATE:

EXAMINER:

JOB PERFORMANCE MEASURE DATA PAGE

Task: Classify	y an Event ar	nd Determine P	ARs - Protec	tive Action F	Recommendations
Alternate Path:	N/A				
Facility JPM #:	NEW				
K/A: 2.4.41,	2.4.44	Importance:	RO:4.1, 4.0) SRO:	4.1, 4.4
K/A Statement:	(2.4.41) Kno classification (2.4.44) Kno recommend	owledge of the e ns. owledge of eme ations.	emergency a rgency plan	ction level th protective ad	nreshholds and
Task Standard:	Event class evacuation	ified as a Gener of Areas 1 and 3	al Emergeno 3, within 15 r	cy within 15 ninutes from	minutes and PAR is declaration of GE.
Preferred Evalu	ation Locatio	on: Any	X		
Preferred Evalu	ation Methoo	1: Perform	X	Simulate	
References:	El-1, "Emer El-3, "Comr El-6.13, "Pr	gency Classifica nunications and otective Action I	ations and Ad Notifications Recommend	ctions" s" ations for O	ffsite Populations"
Validation Time	e:20	minutes Tin	ne Critical:	YES - see	task standard
Candidate:					
Time Start:		Time Finish:	<u></u>		
Performance T	ime:	minutes			
Performance R	ating: SA ⁻	「 UN	SAT	-	
Comments:					
Examiner:	S	ignature		Date:	

EXAMINER COPY ONLY

Tools/Equipment/Procedures Needed:

EI-1, "Emergency Classifications and Actions," Attachment 1
EI-3, "Communications and Notifications"
EI-6.13, "Protective Action Recommendations for Offsite Populations," Attachment 1

Also see **Simulator Operator Instructions** (later page of this document).

READ TO CANDIDATE

DIRECTION TO CANDIDATE:

I will explain the initial conditions, and state the task to be performed. All control room steps shall be performed for this JPM, including any required communications. I will provide initiating cues and reports on other actions when directed by you. Ensure you indicate to me when you understand your assigned task. To indicate that you have completed your assigned task return the handout sheet I provided you.

INITIAL CONDITIONS:

- The Reactor tripped 10 minutes ago.
- A Steam Generator Tube Rupture Event is in progress on the 'A' Steam Generator.
- Pressurizer level is off-scale LOW.
- PCS pressure is 1000 psia.
- CETs indicate 500°F.
- SIRWT level is 92% and lowering slowly.
- A release IS occurring through a stuck open code safety valve on the 'A' Steam Generator.
- Reactor Vessel Level Monitoring System (RVLMS) indicates ALL red lights
- Failed fuel analysis is in progress with no results to report yet.
- The weather is clear with no precipitation.

INITIATING CUES:

During activation of the Site Emergency Plan, you are the Shift Manager (acting as the Emergency Plant Manager). You are to classify the event given the above information and complete the Event Notification Form. No previous event declaration has been made.

This JPM is Time Critical.

PALISADES NUCLEAR PLANT

EVALUATOR: Candidate may use placard of site emergency plan classifications or use paper copy from EI-1, attachment 1.

Proc.Step	TASK ELEMENT 1	STANDARD	Grade
EI-1	Refers to "Fission Product Barriers" section	Refers to lower right-hand corner of El-1,	S 11
Att 1	(lower right-hand corner)	(PCS > 200 degrees F)".	
Comment			

Proc.Step	TASK ELEMENT 2	STANDARD	Grade
	Determines status of fission product barriers.	Refers to Table F1	
		Determines a POTENTIAL LOSS of Fuel Cladding (based on RVLMS < 614 ft elevation readings (item 4)	
EI-1 Att 1		 Determines a LOSS of PCS Barrier (based on S/G leak rate causing SI actuation) (item 3). 	SU
		Determines a LOSS of Containment Barrier (based on affected S/G faulted outside Containment) (item 4).	
Commen	t:		

Proc.Step	TASK ELEMENT 3	STANDARD	Grade
El-1 Att 1	Declares Emergency Classification.	Declares a GENERAL EMERGENCY per FG1 based on status of fission product barriers (loss of TWO and potential loss of THIRD).	sυ
Comment CRITICA	_ STEP - must be performed within 15 minut	es of start of JPM.	

JPM SRO ADMIN 4

Proc.Step	TASK ELEMENT 4	STANDARD	Grade
El-1	Prepares Emergency Actions/Notifications	Obtains EL1 Attachment 2 and fills out	с II
Att 2	form.		30

Comment:

EVALUATOR NOTE: This Task Element may be performed at any time during the JPM. Filling out this form is NOT required for this JPM.

EVALUATOR NOTE: It is NOT the intent of this JPM to have candidate actually make the notifications.

Proc.Step	TASK ELEMENT 5	STANDARD	Grade
El-3	Propares Event Natification Form	Obtains EI-3, Attachment 1 and fills out per	S 11
Att 1	Frepares Event Notification Form.	attached KEY.	30

Comment:

EVALUATOR CUE: When candidate asks for Meteorological Data, hand them attachment 1 of El-6.7, "Plant Site Meteorological System Worksheet," which has been previously completed (attached).

EVALUATOR CUE: If JPM is not conducted in the Simulator, hand them a blank Event Notification form to fill out (attached).

EVALUATOR NOTE: KEY is attached to this JPM.

EVALUATOR NOTE: EI-3, Attachment 2, "Palisades Event Technical Data Sheet" is NOT required during this JPM.

EVALUATOR NOTE: If JPM is conducted in the Simulator, then Candidate may use computer on Control Room island area to prepare this form.

Proc.Step	TASK ELEMENT 6	STANDARD	Grade
EI-6.13 Att 1	Determines Protective Action Recommendations (PARs).	Obtains EI-6.13 and corresponding Attachment 1 and determines: Evacuate Areas 1 and 3 (minimum GE recommendation on bottom of Pg 1 of Attachment 1)	SU
Commen EVALU	^{t:} ATOR NOTE: Provide candidate with	h a working copy of El-6.13.	

CRITICAL STEP

JPM SRO ADMIN 4

Proc.Step	TASK ELEMENT 7	STANDARD	Grade
E!-11	Candidate may determine status of Core Damage per EI-11.	Candidate refers to EI-11: determines there is not enough info provided in initiating cue to determine amount of core damage.	SU

Comment:

EVALUATOR NOTE: If candidate attempts to perform this step, provide them with a working copy of EI-11, attachment 2.

Proc.Step	TASK ELEMENT 8	STANDARD	Grade
El-3 Att 1	Completes filling out Palisades Event Notification Form.	Palisades Event Notification Form completely filled per attached KEY AND form is approved (Candidate initials, date, and time entered at bottom of form) *	SU

Comment:

EVALUATOR CUE: If JPM is not conducted in the Simulator, hand them a blank Event Notification form to fill out (attached) if not done already.

EVALUATOR NOTE: If JPM is conducted in the Simulator, then Candidate may use computer on back-bar of Control Room island area to complete and print this form.

* The following are the critical parts of this step:

- General Emergency is checked in "current classification" section
- Date and time filled in "current classification" section
- FG1 filled in "reason for classification" section AND Fission Product Barrier Degradation checked in "reason for classification" section
- "Yes" checked in Radiological Release in Progress
- Areas 1 and 3 checked for Evacuation of Areas

CRITICAL STEP - must be performed within 15 minutes of declaration of General Emergency.

END OF TASK

ANSWER KEY

JPM SRO ADMIN 4 Proc No El-3

Attachment 1 Revision 29

PALISADES	EVENT	NOTIFI	CATION	FORM

Actual Event	Drill	
Plant Contact Information		
Plant Communicator: Time of 0	Communication: V.B S.O.M NRC Plant Message Number	
Calling From: Control Room TSC	EOF Other	
Current Clas	sification	
☐ Unusual Event ☐ Alert ☐ Site Area Emergen This Classification was declared as of: Date: <u>Today</u>	cy 🛛 General Emergency 🔲 Termination Time: <u>Within 15 minutes from start of JPM</u>	
Reason for Classification		
Abnormal Rad Levels / Radiological Effluent	System Malfunctions	
Hazards and Other Conditions Affecting Plant Safety	Cold Shutdown / Refueling System Malfunction	
	Independent Spent Fuel Storage Installation Events	
IC Number: FG1	Fission Product Barrier Degradation	
Radiological Release in F	Progress Due to Event	
🛛 Yes	□ No	
Protective Action Recommendations		
Evacuation of Areas(s): 🛛 1 🗍 2 🖂 3 🗍 4 🗍 5		
In-Place Shelter of Area(s)	☐ 4 ☐ 5	
PAR based on: Dose Calculation (Palisades Event Techn	ical Data Sheet required) 🛛 Plant Status 🔲 Security Event	
Meteorological Data		
Wind Direction (degrees): From <u>305</u> To <u>125</u> Wind Speed (MPH): <u>1</u>		
Stability Class: <u>G</u> Pre	cipitation: 🔲 Yes 🖾 No	
Emergency Director Approval:	Date: Time:	
ANSWER KEY		

SIMULATOR OPERATOR INSTRUCTIONS

- No Simulator setup required.
- It is preferred that this JPM be done separately from the simulator. If, by chance, candidate IS in the simulator while doing this JPM, THEN ensure the IC does NOT have a release in progress.

ENSURE ALL DATA IS CLEARED FROM EP NOTIFICATION COMPUTER ON BACK-BAR OF CRS ISLAND PRIOR TO NEXT USE OF THIS JPM.

Proc No El-6.7 Attachment 1 Revision 8 Page 1 of 1

PLANT SITE METEOROLOGICAL SYSTEM WORKSHEET

1.	WS, Wind Speed = <u>1.0</u> mph	(X) 10 meters () 60 meters, *corrected
	*Multiply by 0.77	(see Step 5.1.3 or 5.2.6)

2.	WD, Wind Direction = <u>305</u> ° from	(X) 10 meters () 60 meters
		(see Step 5.1.3 or 5.2.6)
		(see Step 5.1.4 or 5.2.7)
3.	Stability Class = <u>G</u>	

Date: TODAY Time: NOW Completed By: JOE OPERATOR

Г

CANDIDATE CUE SHEET

(TO BE RETURNED TO EXAMINER UPON COMPLETION OF TASK)

INITIAL CONDITIONS:

- The Reactor tripped 10 minutes ago.
- A Steam Generator Tube Rupture Event is in progress on the 'A' Steam Generator.
- Pressurizer level is off-scale LOW.
- PCS pressure is 1000 psia.
- CETs indicate 500°F.
- SIRWT level is 92% and lowering slowly.
- A release IS occurring through a stuck open code safety valve on the 'A' Steam Generator.
- Reactor Vessel Level Monitoring System (RVLMS) indicates ALL red lights
- Failed fuel analysis is in progress with no results to report yet.
- The weather is clear with no precipitation.

INITIATING CUES:

During activation of the Site Emergency Plan, you are the Shift Manager (acting as the Emergency Plant Manager). You are to classify the event given the above information and complete the Event Notification Form. No previous event declaration has been made.

This JPM is Time Critical.