

## Speakers Notes

- Staff issued Standard Review Plan NUREG-0800 Chapter. 1 guidance to include review of applicant evaluations of defects and non-compliances submitted in Part 21 notifications. The guidance was published for comments in April 2011 and comment period ends May 27, 2011.
- Specific guidance language is shown in the published guidance.
- This guidance contains a requirement that all applicants should have a program in place for implementing the requirements of 10 CFR part 21 in the applicants submittals
- Applicant evaluations should determine applicability and potential implications on Design Certification, DC renewals, and Combined operating license applications that reference a DC. This requirement applies to all design centers.
- The applicability, relevancy and significance of these failure notifications in DC and COL reviews shall be determined by the individual applicant and specific to each design center with emphasis on significant notifications.
- For design certification reviews, the scope of the applicants review should include notifications issued prior to submittal of the DC application.
- For DC renewals, and COL applications that reference a DC, the scope of the applicants review should include those notifications issued between the original DCR and submittal of the DC renewal, or COL application that references the DCR, as applicable.
- Staff will perform a review of applicants evaluations or perform confirmatory review
- Staff will document these results in the safety evaluation report in Chapter 1. and provide an opportunity for the ACRS committee to review and comment on the findings when the Safety evaluation is presented to the ACRS.