

CCNPP3eRAIPEm Resource

From: Arora, Surinder
Sent: Friday, June 10, 2011 9:33 AM
To: 'Robert.Poche@unistarnuclear.com'; 'cc3project@constellation.com'
Cc: CCNPP3eRAIPEm Resource; Dehmel, Jean-Claude; Colaccino, Joseph; Clark, Phyllis; Wilson, Anthony; Vrahoretis, Susan; Roach, Edward
Subject: Final RAI 312 CHPB 5752
Attachments: FINAL RAI 312 CHPB 5752.doc

Rob,

Attached please find the subject request for additional information (RAI). The draft of this RAI was sent to you on May 27, 2011. No clarification phone call was requested by UniStar during the draft review period on this RAI.

The schedule we have established for review of your application assumes technically correct and complete responses within 30 days of receipt of RAIs. For any RAIs that cannot be answered within 30 days, it is expected that a schedule date for submitting your technically correct and complete response will be provided to the staff within the 30 day period so that the staff can assess how this information will impact the review schedule.

Your response letter should also include a statement confirming that the response does or does not contain any sensitive or proprietary information.

Thanks.

SURINDER ARORA, PE
PROJECT MANAGER,
Office of New Reactors
US Nuclear Regulatory Commission

Phone: 301 415-1421
FAX: 301 415-6406
Email: Surinder.Arora@nrc.gov

Hearing Identifier: CalvertCliffs_Unit3Col_RAI
Email Number: 128

Mail Envelope Properties (B46615B367D1144982B324704E3BCEED7E44DC5EE6)

Subject: Final RAI 312 CHPB 5752
Sent Date: 6/10/2011 9:32:41 AM
Received Date: 6/10/2011 9:32:49 AM
From: Arora, Surinder

Created By: Surinder.Arora@nrc.gov

Recipients:

"CCNPP3eRAIPEm Resource" <CCNPP3eRAIPEm.Resource@nrc.gov>

Tracking Status: None

"Dehmel, Jean-Claude" <Jean-Claude.Dehmel@nrc.gov>

Tracking Status: None

"Colaccino, Joseph" <Joseph.Colaccino@nrc.gov>

Tracking Status: None

"Clark, Phyllis" <Phyllis.Clark@nrc.gov>

Tracking Status: None

"Wilson, Anthony" <Anthony.Wilson@nrc.gov>

Tracking Status: None

"Vrahoretis, Susan" <Susan.Vrahoretis@nrc.gov>

Tracking Status: None

"Roach, Edward" <Edward.Roach@nrc.gov>

Tracking Status: None

"Robert.Poche@unistarnuclear.com" <Robert.Poche@unistarnuclear.com>

Tracking Status: None

"cc3project@constellation.com" <cc3project@constellation.com>

Tracking Status: None

Post Office: HQCLSTR01.nrc.gov

Files	Size	Date & Time
MESSAGE	1410	6/10/2011 9:32:49 AM
FINAL RAI 312 CHPB 5752.doc		30202

Options

Priority: Standard

Return Notification: No

Reply Requested: No

Sensitivity: Normal

Expiration Date:

Recipients Received:

Request for Additional Information No. 312 (eRAI 5752)

6/10/2011

Calvert Cliffs Unit 3

UniStar

Docket No. 52-016

SRP Section: 11.05 - Process and Effluent Radiological Monitoring Instrumentation and Sampling Systems

Application Section: 11.5.2

QUESTIONS for Health Physics Branch (CHPB)

11.05-3

Phase 4 RAI:

A review of CCNPP-3 FSAR Revision 7, Section 11.5.2 and FSAR Revision 7, Section 1.8, Table 1.8-2 indicates that COL Information Item 11.5-1 addressing compliance with Part 50 Appendix I design objectives is inconsistently worded. When compared to U.S. EPR FSAR Revision 2, Table 1.8-2, one of the provisions is missing in the text presented in CCNPP-3 FSAR Section 11.5.2 and that provision is erroneously duplicated in CCNPP-3 FSAR Table 1.8-2. The applicant is requested to review COL Information Item 11.5-1 and revise it to ensure that the stated commitments are consistently described in both sections of the CCNPP-3 FSAR.