

Attachment 2

Proposed TS Amendment No. 87c

Affected Page TS 6-12

8912280254 891220
PDR . ADUCK 05000305
P PIC

6.7 SAFETY LIMIT VIOLATION

6.7.1 The following actions shall be taken in the event a safety limit is violated:

- a. The reactor shall be shutdown and operation shall not be resumed until authorized by the Commission.

- b. The Report shall be prepared in accordance with Section 6.6 of the Technical Specifications.

6.8 PROCEDURES

- 6.8.1 Written procedures and administrative policies shall be established, implemented and maintained that meet the requirements and recommendations of Section 5.2.2, 5.2.5, 5.2.15 and 5.3 of ANSI N18.7-1976.

- 6.8.2 Changes to procedures are made in accordance with the provisions of ANSI N18.7-1976 Section 5.2.2 except that temporary changes which clearly do not change the intent of the procedure shall, as a minimum, be approved by two individuals knowledgeable in the area affected one of which holds an active SRO license at Kewaunee.

- 6.8.3 Procedures are reviewed in accordance with the provisions of ANSI N18.7-1976, Section 5.2.15, except for procedures that are performed at a frequency interval of greater than every two years. Procedures performed at a frequency interval greater than every two years shall, instead, be reviewed prior to use or within the previous two years.