

MEMO ROUTE SLIP Form AEC-93 (Rev. May 14, 1947) AECM 0240		See me about this. Note and return.	For concurrence. For signature.	For action. For information.
TO (Name and unit) RO Chief, FS&EB RO:HQ (4) Licensing (4) DR Central Files Region I	INITIALS	REMARKS Wisconsin Public Service Corporation Kewaunee 50-305		
	DATE			
TO (Name and unit) Region II Local PDR PDR NSIC DTIE	INITIALS	REMARKS		
	DATE			
TO (Name and unit) OGC, Beth, P-506A R. Renfrow, GC	INITIALS	REMARKS		
	DATE			
FROM (Name and unit) W. E. Vetter RO:III	REMARKS Attached is a copy of licensee's adequate reply to RO Bulletin 73-1.			
PHONE NO.	DATE 7-10-73			

USE OTHER SIDE FOR ADDITIONAL REMARKS

GPO : 1971 O - 445-469

W. E. Vetter
7-10-73

WISCONSIN PUBLIC SERVICE CORPORATION



P.O. Box 1200, Green Bay, Wisconsin 54305

June 26, 1973

Mr. Boyce H. Grier, Regional Director
U. S. Atomic Energy Commission
Directorate of Regulatory Operations,
Region III
799 Roosevelt Road
Glen Ellyn, Illinois 60137

Dear Mr. Grier:

Subject: Kewaunee Nuclear Power Plant
Overcurrent Trip Relay in Circuit Breakers
Ref: Docket No. 50-305

In response to your letter dated February 28, 1973, and received by Wisconsin Public Service on May 28, 1973, we submit the following.

Wisconsin Public Service has investigated the use of "Faulty Overcurrent Trip Device in Circuit Breakers for Engineered Safety Systems", as identified in DRO Bulletin No. 73-1, at Kewaunee. The referenced breakers have only been used in the Scram Breaker locations and therefore we do not have the problem referred to in your letter.

Should you have any questions concerning this matter further, we will be pleased to discuss them with you.

Very truly yours,

A handwritten signature in cursive script, appearing to read "E. W. James".

E. W. James, Senior Vice President
Power Generation and Engineering

EWJ:mem