

50-305

FILE NUMBER

## NRC DISTRIBUTION FOR PART 50 DOCKET MATERIAL

TO: A. SCHWENCER

FROM: WISCONSIN PUBLIC SVC. CORP.  
GREEN BAY, WISCONSIN  
E.W. JAMES

DATE OF DOCUMENT

11-18-76

DATE RECEIVED

11-23-76

☐ LETTER☐ NOTORIZED

PROP

INPUT FORM

NUMBER OF COPIES RECEIVED

☒ ORIGINAL  
☐ COPY☒ UNCLASSIFIED

1

## DESCRIPTION

LTR. RE. OUR 11-2-76 LTR...

LTR. FURNISHING SCHEDULE FOR SUBMITTING TECH.  
SPECS PERTAINING TO THE APPENDIX J "PRIMARY  
REACTOR CONTAINMENT LEAKAGE TESTING FOR WATER-  
COOLED POWER REACTORS" REQUIREMENTS.....

( 1 PAGE )

( 1 SIGNED CY. RECEIVED )

PLANT NAME: KEWAUNEE

## ENCLOSURE

ACKNOWLEDGED

DO NOT REMOVE

## SAFETY

## FOR ACTION/INFORMATION

## ENVIRO

SAB 11-26-76

ASSIGNED AD:

BRANCH CHIEF:

PROJECT MANAGER:

LIC. ASST.:

SCHWENCER

SHEPPARD

ASSIGNED AD:

BRANCH CHIEF:

PROJECT MANAGER:

LIC. ASST.:

## INTERNAL DISTRIBUTION

<input checked="" type="checkbox"/> REG FILE	SYSTEMS SAFETY	PLANT SYSTEMS	SITE SAFETY &
<input checked="" type="checkbox"/> NRC PDR	HEINEMAN	TEDESCO	ENVIRO ANALYSIS
<input checked="" type="checkbox"/> I & E (2)	SCHROEDER	BENAROYA	DENTON & MULLER
<input type="checkbox"/> OELD		LAINAS	
<input type="checkbox"/> GOSSICK & STAFF	ENGINEERING	IPPOLITO	ENVIRO TECH.
<input checked="" type="checkbox"/> MIPC	MACCARRY	KIRKWOOD	ERNST
<input type="checkbox"/> CASE	KNIGHT		BALLARD
<input checked="" type="checkbox"/> HANAUER	SIHWEIL	OPERATING REACTORS	SPANGLER
<input type="checkbox"/> HARLESS	PAWLICKI	STELLO	
			SITE TECH.
<input type="checkbox"/> PROJECT MANAGEMENT	REACTOR SAFETY	OPERATING TECH.	GAMMILL
<input type="checkbox"/> BOYD	ROSS	EISENHUT	STEP
<input type="checkbox"/> P. COLLINS	NOVAK	SHAO	HULMAN
<input type="checkbox"/> HOUSTON	ROSZTOCZY	BAER	
<input type="checkbox"/> PETERSON	CHECK	BUTLER	SITE ANALYSIS
<input type="checkbox"/> MELTZ		GRIMES	VOLLMER
<input type="checkbox"/> HELTEMES	AT & I		BUNCH
<input type="checkbox"/> SKOVHOLT	SALTZMAN		J. COLLINS
	RUTBERG		KREGER

## EXTERNAL DISTRIBUTION

## CONTROL NUMBER

<input checked="" type="checkbox"/> LPDR: KEWAUNEE, WIS.	NAT LAB:	BROOKHAVEN NAT LAB
<input checked="" type="checkbox"/> TIC:	REG. VIE	ULRIKSON (ORNL)
<input checked="" type="checkbox"/> NSIC:	LA PDR	
<input checked="" type="checkbox"/> ASLB:	CONSULTANTS	
<input checked="" type="checkbox"/> ACRS / CYS HOLDING/SENT	CAT 'B'	

11917

muse

Regulatory

File Cy

# WISCONSIN PUBLIC SERVICE CORPORATION



P.O. Box 1200, Green Bay, Wisconsin 54305

November 18, 1976

50-305


U. S. Nuclear Regulatory Commission  
Division of Operating Reactors  
Washington, D. C. 20555

ATTN: Mr. A. Schwencer, Chief  
Operating Reactors Branch #1

Dear Mr. Schwencer:

SUBJ: Appendix J, "Primary Reactor Containment Leakage  
Testing for Water-Cooled Power Reactors"

REF: NRC Letter to WPS Dated November 2, 1976



The referenced letter requested that we inform you of our schedule for submitting the necessary technical specifications or specific exemption requests pertaining to the Appendix J requirements. We have reviewed the enclosure attached to the referenced letter and we will submit a proposed change to the Technical Specifications indicating that Type A tests would not exclude the requirements of Type C tests. Furthermore, we will include with the submittal a list of valves for which we will request an exemption because of their application, where they will either operate during or are assured to be filled with water following a LOCA.

This submittal will be made by January 3, 1977, allowing sufficient time for NRC review prior to our next scheduled refueling.

Sincerely,

E. W. James  
Senior Vice President  
Power Supply & Engineering

EWJ:sna

11517