REGULATE INFORMATION DISTRIBUTION YSTEM (RIDS)

ACCESSION NBR:8001140509 DOC,DATE: 80/01/08 NOTARIZED: YES DOCKET # FACIL:50-305 Kewaunee Nuclear Power Plant, Wisconsin Public Servic 05000305 AUTH.NAME AUTHOR AFFILIATION MATHEWS;E.R. Wisconsin Public Service Corp.

RECIPINAME RECIPIENT AFFILIATION EISENHUT, D.G. Division of Operating Reactors

SUBJECT: Forwards Westinghouse & Exxon evaluations re potential impact of using clad swelling & fuel blockage models presented in draft NUREG-0630 on LOCA analysis.

DISTRIBUTION CODE: A039S COPIES RECEIVED:LTR _ ENCL _ SIZE: O TITLE: Resp to Lesson Learn Task Force - Westinghouse

NUTES: I E E - 3 CUS ALL MATL.

ACTION:	RECIPIENT ID CODEZNAME 10 BC ORG #	COPIE CTTR 7	ES Encl 7	RECIPIENT ID CODEZNÂME	COPI LTTR	ES Eñcl
INTERNAL	1 REG FILE 19 TA/EDO 20 CORE PERF BR 22 REAC SFTY BR 24 EEB 3 LPDR 5 J OLSHINSKI 7 J BURDION 9 G IMBRU M FIELDS		1 1 1 1 1 1 1 1	17 I & E 2 NRC. PDR 21 ENG BR 23 PLANT SYS BR 25 EFLT TRT SYS 4 NSIC 6 J KERRIGAN 8 C WILLIS J.T. TELFORD N ANDERSON	2 1 1 1 1 1 2 1	2 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1
EXTERNAL:	26 ACRS	1	0 <u> </u>	P U'REILLY	1	<u>Î</u>

JAN 15 1980

COPIES

REQUIRED:

小牛 医克雷尔变

418.55

LTTR

ENCL

TOTAL

(青月 年) 望夜宫

NUMBER

ÛF

1. 2. 61% 14:

MA 4

WISCONSIN PUBLIC SERVICE CORPORATION



P.O. Box 1200, Green Boy, Wisconsin 54305

January 8, 1980

Darrel G. Eisenhut, Acting Director Division of Operating Reactors Office of Nuclear Reactor Regulation Nuclear Regulatory Commission Washington, D. C. 20555

Dear Mr. Eisenhut:

Docket 50-305 Operating License DPR-43 Clad Swelling and Fuel Blockage Models

In response to the concerns raised by the staff regarding the above referenced subject, WPS commissioned Westinghouse Electric Corporation and Exxon Nuclear Company, Inc., to perform the analyses which would address those concerns. We received the Westinghouse analysis late yesterday and the Exxon analysis today and have not had sufficient time to review them in detail. To the best of our knowledge, these analyses are correct and contain the information necessary to answer the concerns of the staff. We have attached a copy of these analyses to this letter.

Sincerely yours,

E. R. Mathews, Vice President Power Supply & Engineering

rgm

Attach.

Subscribed and Sworn to Before Me This 7th Day of January 1980

Lews Kome O Notate Public, State of Wisconsin

My Commission Expires 2-6-83

8001140509

•		
	ATTACHMENT	4

VESTINGHOUSE

Page 1 of 4

A. Evaluation of the potential impact of using fuel rod models presented in draft NUREG-D530 on the Loss of Coolant Accident (LOCA) analysis for KEWAUNEE

This evaluation is based on the limiting break LOCA analysis identified as follows:

BREAK TYPE - DOUBLE ENDED COLD LEG GUILLOTINE

BREAK DISCHARGE COEFFICIENT 0.4

HESTINGHOUSE ECCS EVALUATION MODEL VERSION _ FEBRUARY 1978

CORE PEAKING FACTOR 2.27

Received 1-8-80

HOT ROD MAXIMUM TEMPERATURE CALCULATED FOR THE BURST REGION OF THE CLAD - 1839 of - PCTB

ELEVATION - 6.0 Feet.

HOT ROD MAXIMUM TEMPERATURE CALCULATED FOR A NON-RUPTURED REGION OF THE CLAD - 2197 of = PCT_N

ELEVATION - 7.5 Feet

CLAD STRAIN DURING BLOWDOWN AT THIS ELEVATION 3.8 Percent MAXIMUM CLAD STRAIN AT THIS ELEVATION - <u>6.5</u> Percent

Maximum temperature for this node occurs when the core reflood rate is (//LESS) than 1.0 inch per second and reflood heat transfer is based on the (//STEAM COOLING) calculation.

AVERAGE HOT ASSEMBLY ROD BURST ELEVATION - N/A Feet HOT ASSEMBLY BLOCKAGE CALCULATED - 0.0 Percent

1. HURST NODE

The maximum potential impact on the ruptured clad node is expressed in letter NS-THA-2174 in terms of the change in the peaking factor limit (FQ) required to maintain a peak clad temperature (PCT) of 2200°F and in terms of a change in PCT at a constant FQ. Since the clad-water reaction rate increases significantly at temperatures above 2200.°F, individual effects (such as APCT due to changes in several fuel rod models) indicated here may not accurately apply over large ranges,

Page but a simulaneous chance in FQ which cause the PCT to remain in the neighborhood of 2200. OF justifies use of this evaluation procedure.

2 -

of

From NS-TMA-2174:

- For the Burst Node of the clad:
 - 0.01 AFO + 150 F BLAST NODE APCT
 - Use of the MRC burst model could require an FQ reduction of 0.015
 - The minimum estimated impacts of using the NRC/strain model is a required FQ reduction of 0.03.

Therefore, the maximum benalty for the Hot Rod burst node is:

 $\Delta PCT_1 = (.015 + .03) (150^{\circ}F/.01) = 675^{\circ}F$

Margin to the 22009F limit is:

 $\Delta PCT_{7} = 2200.0F - PCT_{8} = 361 0F$

The FQ reduction required to maintain the 2200°F clad temperature limit is:

$$\Delta FQ_8 = (\Delta PCT_1 - \Delta PCT_2) \cdot (\frac{-01 \ \Delta FQ}{150^{\circ}F})$$

$$= (\underline{1.75} - \underline{3.61}) (\frac{.01}{150})$$

.021 (but not less than zero).

MON-BURST NODE 2.

The maximum temperature calculated for a non-burst section of clad typically occurs at an elevation above the core mid-plane during the core reflood phase of the LOCA transient. The potential impact on that maximum clad temperature of using the NRC fuel rod models can be estimated by examining two aspects of the analyses. The first aspect is the change in pellet-clad gap conductance resulting from a difference in clad strain at the non-burst maximum clad temperature node elevation. Note that clad strain all along the fuel rod stops after clad burst occurs and use of a different clad burst model can change the time at mich burst is calculated. Three sets of LOCA analysis results were studied to establish an acceptable sensitivity to apply generically in this evaluation. The possible PCT increase resulting from a change in strain (in the Hot Rod) is +20.9F per percent decrease in strain at the maximum clad temperature

Page 3 of 4 locations. Since the clad strain calculated during the reactor coplant system blowdown phase of the accide is not changed by the use of NRC fuel rod models, the maximum decrease in clad strain that must be considered here is the difference between the "maximum clad strain" and the "clad strain at the end of RCS blowdown" indicated above.

Therefore:

 $\Delta PCT_{3} = \left(\frac{20^{\circ}F}{.01 \text{ strain}}\right) (MAX \text{ STRAIN} - BLOHDOWN \text{ STRAIN})$ $= \left(\frac{20}{.01}\right) \left(\frac{.045}{.015} - \frac{.038}{.038}\right)$ = 54

The second aspect of the analysis that can increase PCT is the flow blockage calculated. Since the greatest value of blockage indicated by the NRC blockage model is 75 percent, the maximum PCT increase can be estimated by assuming that the current level of blockage in the analysis (indicated above) is raised to 75 percent and then applying an appropriate sensitivity formula shown in NS-TMA-2174.

Therefore,

 $APCT_4 = 1.250F (50 - PERCENT CURRENT BLOCKAGE) + 2.350F (75-50)$

$$= 1.25 (50 - 0) + 2.35 (75 - 50)$$

121 OF

If PCTM occurs when the core reflood rate is greater than 1.0 inch per second $\Delta PCT_4 = 0$. The total potential PCT increase for the non-burst node is then

 $\Delta PCT_5 = \Delta PCT_3 + \Delta PCT_4$

Margin to the 2200°F limit is

 $\Delta PCT_{5} = 22009F - PCT_{N}$

The FQ reduction required to maintain this 22000F clad temperature limit is (from NS-TMA-2174)

$$\Delta FQ_{\rm N} = (\Delta PCT_5 - \Delta PCT_6) \left(\frac{.01\Delta FQ}{.10^{9} F \ APCT} \right)$$

 $\Delta FQ_N = 0.17$ but not less than zero.

The peaking factor reduction required to maintain the 2200 $^{\circ}$ F clad temperature limit is therefore the greater of Δ FQ_p and Δ FQ_p.

or; $\Delta FO_{PENALTY} = 0.17$

B. The effect on LOCA analysis results of using improved analytical and modeling techniques (which are currently approved for use in the Upper Head Injection plant LOCA analyses) in the reactor coolant system blowdown calculation (SATAN computer code) has been quantified via an analysis which has recently been submitted to the NRC for review. Recognizing that review of that analysis is not yet complete and that the benefits associated with those model improvements can change for other plant designs, the NRC has established a credit that is acceptable for this interim period to help offset penalties resulting from application of the NRC fuel rod models. That credit for two, three and four loop plants is an increase in the LOCA peaking factor limit of 0.12, 0.15 and 0.20 respectively.

C. The peaking factor limit adjustment required to justify plant operation for this interim period is determined as the appropriate AFQ credit identified in section (B) above, minus the AFQ period calculated in section (A) above (but not greater than zero).

FQ ADJUSTMENT =
$$0.12 - 0.17$$

= -0.05

This evaluation indicates that the allowable peaking factor limit is

2.27 - 0.05 = 2.22

for Westinghouse fuel.

ATTACHMENT

page 1 of 3

In response to NRC concerns, this letter provides specific information on the impact of the newly proposed NRC Clad Swelling and Rupture Model ⁽¹⁾ on ENC's ECCS analyses for Kewaunee. The difference between peak cladding temperatures calculated with the NRC model and the ENC model is quite small and the ENC calculated total peaking limit of 2.21 for Kewaunee continues to be valid.

The change in calculated peak clad temperature (PCT) for ENC fuel at Kewaunee when the NRC model for clad swelling and rupture is used in place of the ENC model is an increase of less than 2.0° F (Table 1). The calculation is for the ENC CD=0.4 DECLG limiting break at Kewaunee (This increase in PCT is small compared to the approximately 70° F margin in ENC's ECCS analysis to the limiting PCT of 2200° F. The present sensitivity calculations were made in accordance with ENC's approved WREM-IIA PWR ECCS Evaluation Model (3,4,5,6). The fuel rod internal pressure corresponds to the ENC model (7) for nominal conditions. In view of the continued $(\approx 70^{\circ}$ F) margin to a PCT of 2200° F with the NRC clad swelling and rupture model, the current total peaking limit of 2.21 for ENC fuel at Kewaunee insures conformance to 10 CFR 50.46.

References -

- 1. D. A. Powers and R. O. Meyer, "Cladding Swelling and Rupture Models for LOCA Analysis," Draft NUREG-0630, November 8, 1979.
- "ECCS Analysis for Kewaunee using ENC WREM-IIA PWR Evaluation Model," XN-NF-79-1, January 1979.
- 3. "Exxon Nuclear Company WREM-Based Generic PWR ECCS Evaluation Model: Update ENC WREM-IIA," XN-NF-78-30, August 1978.
- 4. "Exxon Nuclear Company WREM-Based Generic PWR ECCS Evaluation Model." XN-75-41:

Volume I, July 1975 a. Volume II, August 1975 b. Volume 111, Revision 2, August 1975 c. Supplement 1, August 1975 d. Supplement 2, August 1975 e. Supplement 3, August 1975 f. Supplement 4, August 1975 g. Supplement 5, Revision 5, October 1975 'n. Supplement 6, October 1975 1. Supplement 7, November 1975. <u>.</u>

- "Exxon Nuclear Company WREM-Based Generic PWR ECCS Evaluation Model Update ENC WREM-II," XN-76-27, July 1976; Supplement 1, September 1976; Supplement 2, November 1976.
- 6. "Exxon Nuclear Company WREM-Based Generic PWR ECCS Evaluation Model Update ENC WREM-IIA: Responses to NRC Request for Additional Information," XN-NF-78-30(A) & XN-NF-78-30, Amendment 1(A), May 1979.
- "Flow Blockage and Exposure Sensitivity Study for ENC D. C. Cook Unit 1 Reload Fuel Using ENC WREM-II," XN-76-51; Supplement 1, January 1977; Supplement 2, February 1978; Supplement 3, April 1978.

EFFECT OF NRC RUPTURE AND FLOW BLOCKAGE MODEL ON THE ENC ECCS ANALYSIS FOR KEWAUNEE

+1.70

92

page 3 of 3

Tota]	Peaking,	Fq	•			2.21
Heatup	Rate at	Rupture	(⁰ C/S))		7.0

PCT Impact of NRC Model vs ENC Model