## REGULATORY IN RMATION DISTRIBUTION SYST

ACCESSION NBR:8001280331 DOC.DATE: 80/01/21 NOTARIZED: NO DOCKET # 05000305 FACIL:50-305 Kewaunee Nuclear Power Plant, Wisconsin Public Servic

AUTH NAME

AUTHUR AFFILIATION

MATHEWS, E.R. RÉCIP. NAME Wisconsin Public Service Corp.

RECIPIENT AFFILIATION

Operating Reactors Branch 1 SCHWENCER, A.

SUBJECT: Submits agreement to meet NRC position re restricting purge valve opening pending confirming technical verification from vendor or plant-specific NRC evaluation. Info re component delivery will be forwarded by telcon.

COPIES RECEIVED: LTR L ENCL Q DISTRIBUTION CODE: A034S TITLE: Containment Purging

ALL MATERIAL

	RECIPIENT ID CODEZNAME	COPIES LTIR ENCL	RECIPIENT ID CODE/NAME	COPIES LTTR ENCL
ACTION:	05 BCORB#1	7		
INTERNAL:	12-18E 15 CORE PERF BR 18 REAC SPTY BR 20 EEB 22 BRINKMAN 24 E REEVES	3/2 3/2 1 1 1 1 1	02 NRC PDR 14 TAZEĎO 17 ENGR BR 19 PLĀNT SYS BR 21 EFLT TRT SÝS 23 D SHUM	
EXTERNAL:	03 LPDR 25 ACRS	1 16 16	04 NS1C	1



## WISCONSIN PUBLIC SERVICE CORPORATION



P.O. Box 1200, Green Bay, Wisconsin 54305

January 21, 1980

Mr. A. Schwencer, Chief Operating Reactors Branch #1 Division of Operating Reactors U.S. Nuclear Regulatory Commission Washington, D.C. 20555

Gentlemen:

Docket No. 50-305 Operating License DPR-43 Containment Purge and Vent System

Our December 10, 1979 letter to Mr. A. Schwencer from Mr. E. R. Mathews responded to long and short term commitments for our containment purge and vent system isolation valves. Subsequent phone conversations with members of the NRC staff have revealed specific information concerning limiting the purge valve opening to 30-50 degrees (item 2a in the October 23, 1979 letter to Mr. Mathews from Mr. A. Schwencer). We agree to meet the NRC staff position in regards to restricting valve opening pending confirming technical verification from the valve vendor or receipt of specific NRC staff evaluation applicable to the Kewaunee plant. As the valve vendor was unavailable to provide a schedule of completing this evaluation or providing the required mechanical steps for the valves as of this writing, information concerning the evaluation and mechanical component delivery will be forwarded by telecon as it becomes available.

Very truly yours,

E. R. Mathews, Vice President

Power Supply and Engineering

ERM: 1jh

8001280331