

REGULATOR INFORMATION DISTRIBUTION SYSTEM (RIDS)

ACCESSION NBR: 8103260593 DOC. DATE: 81/03/19 NOTARIZED: NO DOCKET #
 FACIL: 50-305 Kewaunee Nuclear Power Plant, Wisconsin Public Service 05000305
 AUTH. NAME: MATHEWS, E. R. AUTHOR AFFILIATION: Wisconsin Public Service Corp.
 RECIP. NAME: EISENHUT, D. G. RECIPIENT AFFILIATION: Division of Licensing

SUBJECT: Advises that dedicated shutdown capability will be completed within 30 months of NRC approval. Design description will be submitted by 810409. Emergency lighting w/8-h battery for all shutdown operations areas & routes will be provided.

DISTRIBUTION CODE: A006S COPIES RECEIVED: LTR 1 ENCL 0 SIZE: 2
 TITLE: Fire Protection Information (After Issuance of OP. Lic.)

NOTES: I&E: 3 copies all material.

05000305

	RECIPIENT ID CODE/NAME		COPIES		RECIPIENT ID CODE/NAME	COPIES	
			LTR	ENCL		LTR	ENCL
ACTION:	VARGA, S.	04	7	7			
INTERNAL:	CHEM ENG BR-A	7	5	5	DIR, DIV OF LIC		1
	I&E	06	2	2	NRC PDR	02	1
	OFLD		1	0	OGC		1
	REG FILE	01	1	1	WAMBACH, T.	10	1
EXTERNAL:	ACRS	09	16	16	LPDR	03	1
	NSIC	05	1	1			

MAR 27 1981

TOTAL NUMBER OF COPIES REQUIRED: LTR 41 ENCL 0
~~38~~ ~~31~~

JF

WISCONSIN PUBLIC SERVICE CORPORATION



P.O. Box 1200, Green Bay, Wisconsin 54305

March 19, 1981

Mr. Darrell G. Eisenhut, Director
 Division of Licensing
 Office of Nuclear Reactor Regulation
 U.S. Nuclear Regulatory Commission
 Washington, D.C. 20555

Gentlemen:

Docket 50-305
 Operating License DPR-43
 Kewaunee Nuclear Power Plant
Fire Protection Modification: 10CFR50.48

This letter is in response to the requirements of paragraph (c)(5) of 10CFR50.48, which requires licensees to submit plans and schedules for meeting the provisions of paragraphs (c)(2), (c)(3), and (c)(4) of 10CFR50.48. It is our interpretation that items III.G., III.J. and III.O. of Appendix R to 10CFR50.48 are the only items applicable to Wisconsin Public Service Corporation which fall under the requirements of 10CFR50.48 (c)(5).

Item III.G. of Appendix R to 10CFR50.48 requires that fire protection features shall be provided for structures, systems, and components important to safe shutdown. Wisconsin Public Service Corporation intends to provide dedicated shutdown capability in accordance with paragraph (3) of this section. Accordingly, our schedule for completion of this system will be 30 months after NRC approval as allowed by 10CFR50.48 (c)(4). As discussed with our project manager on March 19, we are unable to submit a design description at this time due to an illness on our technical staff. The design description is scheduled for submittal by April 9, 1981.

Item III.J. of Appendix R to 10CFR50.48 requires that emergency lighting with at least an 8-hour battery shall be provided in all areas needed for operation of safe shutdown equipment and in access and regress routes thereto. Wisconsin Public Service Corporation plans of providing this capability in accordance with 10CFR50.48 (c)(2); therefore, the necessary modifications are scheduled for completion by November 17, 1981, pending equipment availability.

*Asob
5/10*

F

8103260593

Mr. Darrell G. Eisenhut

March 19, 1981

Page 2

Item III.O. requires Oil Collection Systems for Reactor Coolant Pumps. Wisconsin Public Service Corporation plans to install oil collection systems on the Kewaunee Reactor Coolant pumps prior to startup of the scheduled 1982 refueling outage, pending equipment availability and necessary engineering qualifications, in accordance with 10CFR50.48 (c)(3).

Very truly yours,

A handwritten signature in cursive script, appearing to read "E. R. Mathews" with a flourish underneath.

E. R. Mathews, Vice President
Power Supply and Engineering

ERM:ljh