

REGULATORY INFORMATION DISTRIBUTION SYSTEM (RIDS)

ACCESSION NBR: 8202030163 DOC. DATE: 82/01/28 NOTARIZED: NO DOCKET #
 FACIL: 50-305 Kewaunee Nuclear Power Plant, Wisconsin Public Service 05000305
 AUTH. NAME: MATHEWS, E. R. AUTHOR AFFILIATION: Wisconsin Public Service Corp.
 RECIP. NAME: VARGA, S. A. RECIPIENT AFFILIATION: Operating Reactors Branch 1

SUBJECT: Advises that auxiliary feedwater flow indication has been upgraded to NUREG-0737 Item II.E.1.2 requirements per 811218 ltr. Indication will not be upgraded to safety grade. Commitment re design change to isolation valve unchanged.

DISTRIBUTION CODE: A046S COPIES RECEIVED: LTR 1 ENCL 0 SIZE: 1
 TITLE: Response to NUREG-0737/NUREG-0660 TMI Action Plan Rgmts (OL's)

NOTES: I&E: 3 copies all material.

05000305

ACTION:	RECIPIENT ID CODE/NAME		COPIES		RECIPIENT ID CODE/NAME		COPIES	
			LTTR	ENCL			LTTR	ENCL
	ORB #1 BC	01	7	7				
INTERNAL:	ELD		1	0	IE	12	2	2
	IE/DEP DIR	33	1	1	IE/DEP/EPDB		1	1
	IE/DEP/EPLB		3	3	NRR/DE DIR	21	1	1
	NRR/DE/ADCSE	22	1	1	NRR/DE/ADMGE	23	1	1
	NRR/DE/ADSA	17	1	1	NRR/DHFS DIR	28	1	1
	NRR/DHFS/DEPY	29	1	1	NRR/DL DIR	14	1	1
	NRR/DL/ADL	16	1	1	NRR/DL/ADOR	15	1	1
	NRR/DL/ORAB	18	3	3	NRR/DSI ADRS	27	1	1
	NRR/DSI DIR	24	1	1	NRR/DSI/ADGP	31	1	1
	NRR/DSI/ADPS	25	1	1	NRR/DSI/ADRP	26	1	1
	NRR/DSI/AEB		1	1	NRR/DSI/ETSB		1	1
	NRR/DSI/RAB		1	1	NRR/DST DIR	30	1	1
	NRR/DST/ADT	32	1	1	<u>REG FILE</u>	04	1	1
EXTERNAL:	ACRS	34	10	10	FEMA-REP DIV		1	1
	INPO, J. STARNES		1	1	LPDR	03	1	1
	NRC PDR	02	1	1	NSIC	05	1	1
	NTIS		1	1				

MA
4

TOTAL NUMBER OF COPIES REQUIRED: LTTR

57
54

ENCL

0
53

M

WISCONSIN PUBLIC SERVICE CORPORATION



P.O. Box 1200, Green Bay, Wisconsin 54305

January 28, 1982

Mr. Steven A. Varga, Chief
Operating Reactors Branch No. 1
Division of Licensing
U. S. Nuclear Regulatory Commission
Washington, D. C. 20555



Dear Mr. Varga:

Operating License DPR-43
Docket 50-305
NUREG-0737 Item II.E.1.2 Auxiliary Feedwater Automatic Initiation
and Flow Indication

Reference: Letter from Mr. S. A. Varga to Mr. E. R. Mathews dated
December 24, 1981

The above referenced letter transmitted the Safety Evaluation Report (SER) and the Technical Evaluation Report prepared by Franklin Research Center. These reports concluded that the AFW System design is acceptable upon completion of two system design changes, one of these being the upgrade of the AFW flow measurement channels to Safety Grade by January 1, 1982.

As we informed you in our letter of December 18, 1981, we have upgraded the AFW flow indication to the requirements of NUREG-0737 Item II.E.1.2, and do not intend to upgrade the indication to Safety Grade. This is a change from our previous commitment in this regard; however, since the indication satisfies the criteria of NUREG-0737, it is our understanding that it is acceptable and does not affect the conclusion of your SER.

The second design change will provide power to AFW isolation valve MV32028 from the "B" battery by the end (May 1982) of the 1982 refueling outage. This commitment is unchanged.

Very truly yours,

E. R. Mathews, Senior Vice President
Power Supply & Engineering

snf

cc - Mr. Robert Nelson, US NRC

8202030163 820128
PDR ADDCK 05000305
PDR

A046
S110