### REGULATORY I RMATION DISTRIBUTION SYSTEM (RIDS) ACCESSION NBR:8205120194 DUC.DATE: 82/05/07 NOTARIZED: NO DOCKET # FACIL:50=305 Kewaunee Nuclear Power Plant, Wisconsin Public Servic 05000305

AUTH.NAME MATHEWS,E.R. Wisconsin Public Service Corp. RECIP.NAME EISENHUT.D.G. Division of Licensing

SUBJECT: Forwards instrument specs re emergency preparedness upgraded meteorological sys per NUREG=0737, Item III.A.2.

DISTRIBUTION CODE: A046S COPIES RECEIVED:LTR J ENCL J SIZE: 4

NOTES:

	RECIPIENT		COPIES LTTR FNCL		RECIPIENT		COPIES LTTR ENCL	
	ORB #1 BC	01	7	7		-		
INTERNAL:	ELD		1	0	IE/DEP DIR	33	1	1
	IE/DEP EPDS		1	1	IE/DEP/EPLB		- 3	3
	NRR/DE DIR	21	1	1	NRR/DE/ADCSE	22	1 -	1 -
	NRR/DE/ADMQE	23	1	1	NRR/DE/ADSA	17	1	1
	NRR/DHFS DIR	28	1	1	NRR/DHFS/DEP	129	1	1
	NRR/DL DIR	14	1	1	NRR/DL/ADL	16	1	1
	NRR/DL/ADOR	15	1	1	NRR/DL/ORAB	18	3	-3
	NRR/DSI ADRS	27	1	1	NRR/DSI DIR	24	1	1
	NRR/DSI/ADPS	25	1	1	NRR/DSI/ADRP	26	1	1
	NRR/DSI/AEB		1	1	NRR/DSI/ETSB		1	1
	NRR/DSI/RAB		1	1	NRR/DST DIR	30	1	- 1
	NRR/DST/ADGP	31	1	1	NRR/DST/ADT	32	1	1
<	REG FILE	04	1	1	RGN3		1	1
EXTERNAL:	ACRS	34	10	10	FEMA-REP DIV		1	1
	INPO, J. STARNE	S	1	1	LPDR	03	1	1
	NRC PDR	20	1	1	NSIC	05	1	1
	NTIS		ĩ	1				

TOTAL NUMBER OF COPIES REQUIRED: LTTR 53 ENCL 52

Public

#### WISCONSIN PUBLIC SERVICE CORPORATION

P.O. Box 1200, Green Bay, Wisconsin 54305



May 7, 1982

Mr. Darrell G. Eisenhut, Director Division of Licensing U. S. Nuclear Regulatory Commission Washington, D. C. 20555

Dear Mr. Eisenhut:

Docket 50-305 Operating License DPR-43 Kewaunee Nuclear Power Plant Emergency Preparedness - Upgraded Meteorological System NUREG-0737 Item III.A.2 -

References: (1) Letter from E. R. Mathews to D. G. Eisenhut dated December 30, 1981

> Letter from E.R. Mathews to D. G. Eisenhut dated (2) November 17, 1981

In reference (1) we agreed to provide you with a description of the meteorological instrumentation being installed as part of the meteorological monitoring system upgrade. We have selected a vendor to supply the meteorological instrumentation and the instrument specifications are attached for your information.

The site location drawing transmitted by reference (2) will be revised to show a minor relocation of the primary (60 meter) tower and the location of the (10 meter) backup tower based upon final site evaluation. The movement of the primary tower is away from the containment structure which further reduces the possible effects of building wake.

A final system description will be prepared as the total design of the system progresses. The description and the revised tower location map will be sent to you for your information as they become available.

A046

Mr. D. G. Eisenhut May 7, 1982 Page 2

For your additional information, WPS will have in place the 10 meter backup tower to obtain data concurrent with the National Oceanic and Atmospheric Administration (NOAA) study planned for June 1982. A temporary instrument shed will be placed on site to gather data from this tower.

Very truly yours,

## E.R. Mathewa

E. R. Mathews, Senior Vice President Power Supply and Engineering

jac

Attach.

# INSTRUMENT SPECIFICATIONS

20

#### o Wind Direction System

Processor MDL 21.21

Teledyne Geotech Wind Direction Sensor 50.2C Vane, Quick Two 53.2

Starting threshold = 0.41 m/sec (0.95mph) @10° Damping ratio = 0.4 @ 10°

Distance Constant = 1.1m
(3.7ft)

Accuracy =  $\pm 2^{\circ}$ 

Temperature Coefficient 0.03°
angle/°C, Linearity ± 0.1%
(phase to dc), Time constant =
50ms

#### o Wind Speed System

Teledyne Geotech Wind Speed Sensor 50.1B

Cup Assembly 52.1

Wind Speed Processor Model 40.12C Range 0-50mph

o Recorder: Esterline Angus Apeed Servo II. D104

#### o Temperature System

Teledyne Geotech Platinum Temperature Probe, Model T-200

Temperature Processor, Model 21.32 T range -40 to 110°F (10m Backup)

Threshold = 0.2 m/sec (0.6mph) Distance constant = 1.5m (5ft)

Accuracy  $\pm$  0.15mph for WS between 0.5 and 15mph and  $\pm$  1% between 15 and 90mph

Linearity  $\pm$  0.2%

Time Constant = 0.35 sec to 90%

Temperature Coefficient = 0.02%/ °C max.

Accuracy = ± 0.35% of voltage or milliamp span

zero drift = 2uv/°C

#### Accuracy

Compensation provided in Processor

2 ± 0.1°C for all output ranges Typical maximum error is ± 0.05°C for processor operating temperature of 25°C ± 5°C T/∆T Processor, Model 40.35 T range -40 to 110°F ∆T range -5 to 10°F (60m Primary tower)  $\pm$  0.05°C for processor operating temperature of 25°C  $\pm$  5°C. Maximum error is  $\pm$  0.1°C for all output ranges, at operating temperatures outside 25  $\pm$  5°C and between 0 and 50°C

o Dew Point

Cooled Mirror Dew Point System Model DP - 100 Range - 40 to +110°F

o Recorder: Esterline Angus Speed Servo II Multipoint Dll2 ± 0.2 °C

± 0.35% of voltage or milliamp span zero drift = 2uv/C°