

REGULATOR INFORMATION DISTRIBUTION SYSTEM (RIDS)

ACCESSION NBR:8208030396 DOC. DATE: 82/07/30 NOTARIZED: NO DOCKET #
 FACIL:50-305 Kewaunee Nuclear Power Plant, Wisconsin Public Service 05000305
 AUTH. NAME AUTHOR AFFILIATION
 GIESLER, C.W. Wisconsin Public Service Corp.
 RECIPIENT NAME RECIPIENT AFFILIATION
 EISENHUT, D.G. Division of Licensing

SUBJECT: Revises commitment date to develop procedures utilizing containment high range radiation monitors for emergency class determination per TMI Action Item II.F.1. Emergency plan implementing procedures to be revised 821001.

DISTRIBUTION CODE: A046S COPIES RECEIVED: LTR 1 ENCL 1 SIZE: 1
 TITLE: Response to NUREG -0737/NUREG-0660 TMI Action Plan Rgmts (OL's)

NOTES:

	RECIPIENT		COPIES		RECIPIENT		COPIES	
	ID	CODE/NAME	LTR	ENCL	ID	CODE/NAME	LTR	ENCL
	ORB #1	BC 01	7	7				
INTERNAL:	ELD/HDS3		1	0	IE/DEP DIR	33	1	1
	IE/DEP EPDS		1	1	IE/DEP/EPLB		3	3
	NRR/DE DIR	21	1	1	NRR/DE/ADCSE	22	1	1
	NRR/DE/ADMGE	23	1	1	NRR/DHFS DIR	28	1	1
	NRR/DHFS/DEPY29		1	1	NRR/DL DIR	14	1	1
	NRR/DL/ADL	16	1	1	NRR/DL/ADOR	15	1	1
	NRR/DL/ADSA	17	1	1	NRR/DL/ORAB	18	3	3
	NRR/DSI DIR	24	1	1	NRR/DSI/ADDP25	25	1	1
	NRR/DSI/ADRP	26	1	1	NRR/DSI/ADRS	27	1	1
	NRR/DSI/AEB		1	1	NRR/DSI/ETSB		1	1
	NRR/DSI/RAB		1	1	NRR/DST DIR	30	1	1
	NRR/DST/ADGP	31	1	1	NRR/DST/ADT	32	1	1
	<u>REG FILE</u>	04	1	1	RGN3		1	1
EXTERNAL:	ACRS	34	10	10	FEMA-REP DIV		1	1
	INPO, J. STARNES		1	1	LPDR	03	1	1
	NRC PDR	02	1	1	NSIC	05	1	1
	NTIS		1	1				

TOTAL NUMBER OF COPIES REQUIRED: LTR 53 ENCL 52

WISCONSIN PUBLIC SERVICE CORPORATION


P.O. Box 1200, Green Bay, Wisconsin 54305

July 30, 1982

Mr. D. G. Eisenhut, Director
 Division of Licensing
 Office of Nuclear Reactor Regulation
 U. S. Nuclear Regulatory Commission
 Washington, D.C. 20555

Dear Mr. Eisenhut:

Docket 50-305
 Operating License DPR-43
 Kewaunee Nuclear Power Plant
 NUREG-0737, Item II.F.1, Attachment 3
Containment High-Range Radiation Monitor

- References: 1) Letter from E. R. Mathews (WPSC) to D. G. Eisenhut (NRC)
 dated April 23, 1982
 2) Letter from E. R. Mathews (WPSC) to D. G. Eisenhut (NRC)
 dated December 18, 1981

WPSC committed to develop procedures (Ref. 1) utilizing the containment high-range radiation monitors for emergency class determination by August 1, 1982. Due to the circumstances below we find it necessary to revise our commitment date.

We are presently experiencing interfacing problems with the control room recorders and an equipment failure has disabled one train of the readout module. The redundant channel is available to support accident assessment with its readout in the relay room. Since the information is not readily available in the control room, it is premature to issue procedures on the use of this equipment.

We are continuing our activity necessary to resolve these problems and expect to have full system capability by September 1, 1982. Emergency Plan Implementing Procedures will be revised by October 1, 1982 to include this instrumentation.

Very truly yours,

Carl W. Giesler
 Vice President - Nuclear Power

js

cc - Mr. Robert Nelson, US NRC

A046