

REGULATORY INFORMATION DISTRIBUTION SYSTEM (RIDS)

ACCESSION NBR: 8402280210 DOC. DATE: 84/02/24 NOTARIZED: NO DOCKET #
 FACIL: 50-305 Kewaunee Nuclear Power Plant, Wisconsin Public Service 05000305
 AUTH. NAME: AUTHOR AFFILIATION
 GIESLER, C.W. Wisconsin Public Service Corp.
 RECIP. NAME: RECIPIENT AFFILIATION
 VARGA, S.A. Operating Reactors Branch 1

SUBJECT: Clarifies commitment re performing NDE of all critical members & welds on reactor vessel head lifting rig in response to NUREG-0612. Exam will be performed prior to lifting reactor vessel head.

DISTRIBUTION CODE: A033S COPIES RECEIVED: LTR 1 ENCL 0 SIZE: 1
 TITLE: OR Submittal: USI A-36 Control of Heavy Load Near Spent Fuel-NUREG-06

NOTES:

	RECIPIENT ID CODE/NAME	COPIES LTR ENCL	RECIPIENT ID CODE/NAME	COPIES LTR ENCL
	NRR ORB1 BC	7	NRR SINGH, A 01	4
INTERNAL:	NRR NEIGHBORS09	1	NRR/DL/ORAB 12	1
	NRR/DSI/AEB	1	NRR/DSI/ASI	1
	<u>REG FILE</u> 04	1	RGN3	1
EXTERNAL:	ACRS 13	6	LPDR 03	1
	NRC PDR 02	1	NSIC 06	1
	NTIS	1		

TOTAL NUMBER OF COPIES REQUIRED: LTR 27 ENCL 2

WISCONSIN PUBLIC SERVICE CORPORATION



P.O. Box 1200, Green Bay, Wisconsin 54305

February 24, 1984

Director of Nuclear Reactor Regulation
 Attention: Mr. S. A. Varga, Chief
 Operating Reactors Branch No. 1
 Division of Licensing
 U.S. Nuclear Regulatory Commission
 Washington, D.C. 20555

Dear Mr. Varga:

Docket 50-305
 Operating License DPR-43
 Kewaunee Nuclear Power Plant
Clarification of Commitment Made in Response to NUREG 0612

Reference: 1) Letter to S. A. Varga from C. W. Giesler dated July 27, 1983

This letter is intended to clarify our commitment in regards to performing a non-destructive examination of all critical members and welds on the reactor vessel head lifting rig.

The commitment states: "To supplement the measures taken to ensure initial quality and workmanship we will perform a non-destructive examination of all critical members and welds on the special lifting devices prior to further use."

The intent of this commitment was to perform a non-destructive examination of all critical welds and members prior to lifting the reactor vessel head.

Future discussions in this regard should use the interpretation presented in this letter.

Very truly yours,

Charles A. Schrock for

C. W. Giesler
 Vice President - Nuclear Power

DJM/js
 cc - Mr. Robert Nelson, US NRC

8402280210 840224
 PDR ADDCK 05000305
 P PDR

A033
 1/0