

REGULATOR INFORMATION DISTRIBUTION SYSTEM (RIDS)

ACCESSION NBR: 8405170010 DOC. DATE: 84/05/14 NOTARIZED: NO DOCKET #
 FACIL: 50-305 Kewaunee Nuclear Power Plant, Wisconsin Public Service 05000305
 AUTH. NAME AUTHOR AFFILIATION
 GIESLER, C.W. Wisconsin Public Service Corp.
 RECIPIENT NAME RECIPIENT AFFILIATION
 VARGA, S.A. Operating Reactors Branch 1

SUBJECT: Advises that commitments to replace six shield bldg ventilation sys damper operators & relocate local pushbottom switches completed prior to 1984 refueling outage, per 840316 ltr.

DISTRIBUTION CODE: A048S COPIES RECEIVED: LTR 1 ENCL 0 SIZE: 2
 TITLE: OR/Licensing Submittal: Equipment Qualification

NOTES:

	RECIPIENT ID CODE/NAME		COPIES L TTR ENCL		RECIPIENT ID CODE/NAME		COPIES L TTR ENCL
	NRR ORB1 BC	12	1	0	GROTENHUIS, M	01	1
INTERNAL:	ELD/HDS3	12	1	1	GC	13	1
	IE FILE	09	1	1	NRR KARSCH, R		1
	NRR/DE/EQB	07	2	2	NRR/DL DIR	14	1
	NRR/DI/ORAB	06	1	1	NRR/DSI/AEB		1
	<u>REC FILE</u>	04	1	1	RGN3		1
EXTERNAL:	ACRS	15	8	8	LPDR	03	1
	NRC PDR	02	1	1	NSIC	05	1
	NTIS	31	1	1			

TOTAL NUMBER OF COPIES REQUIRED: L TTR 25 ENCL 24

WISCONSIN PUBLIC SERVICE CORPORATION



P.O. Box 1200, Green Bay, Wisconsin 54305

May 14, 1984

Director of Nuclear Reactor Regulation
 Attention: Mr. S. A. Varga, Chief
 Operating Reactors Branch No. 1
 Division of Licensing
 U.S. Nuclear Regulatory Commission
 Washington, D.C. 20555

Dear Mr. Varga:

Docket 50-305
 Operating License DPR-43
 Kewaunee Nuclear Power Plant
 Environmental Qualification of Electrical Equipment Important to
 Safety at Kewaunee Nuclear Power Plant: May 4, 1984, Telephone
 Conversation with NRC Staff

- References:
1. Letter to S. A. Varga of NRC from C. W. Giesler of WPSC dated March 16, 1984
 2. Telephone conversation of May 4, 1984, between Neighbors/Shemanski of NRC and Sauer/Schmieman/Thorgersen of WPSC

In a letter transmitting to you minutes of a January 20, 1984 meeting between your staff and Wisconsin Public Service Corporation engineers, concerning the resolution of a Safety Evaluation Report for environmental qualification of electrical equipment important to safety at the Kewaunee Nuclear Power Plant (Reference 1), we committed (Reference 1, paragraph number 4, pages 6 and 7) to perform the following plant modifications during our 1984 refueling outage: replacing six shield building ventilation system damper operators, relocating local pushbutton switches for the Deaerated Drains Tank Emergency Pumps, and replacing the containment vacuum breaker solenoid valves.

Confirming our telephone conversation (Reference 2), this work was performed prior to the completion of the outage.

8405170010 840514
 PDR ADOCK 05000305
 P PDR

A048
/10

Mr. S. A. Varga
May 14, 1984
Page 2

Very truly yours,.



Carl W. Giesler
Vice President - Power Production

EAS/js

cc - Mr. Robert Nelson, US NRC