February 13, 1985 DISTRIBUTION Docket No. 50-305 Docket File LPDR ORB#1 Rdg OELD Mr. D. C. Hintz ACRS 10 Manager - Nuclear Power Wisconsin Public Service Corporation EJordan PMcKee Post Office Box 19002 Green Bay, Wisconsin 54307-9002 DDilanni

Dear Mr. Hintz:

Ś

At the January 10, 1985 meeting at NRC to discuss upper plenum injection (UPI), we were asked to provide additional UPI test data as soon as it could be made available. Accordingly, I am providing you a copy of

NRC PDR Gray File

HThompson

MFairtile

DLangford

CParrish

JPartlow

JAERI-M-84-221, Effects of Upper Plenum Injection on Thermal-Hydodynamic Behavior Under Refill and Reflood Phases, December 1984.

This report was given to your representatives at a February 4, 1985 meeting with NRC. This report describes the effects of UPI as measured on the Slab Core Test Facility (SCTF) operated by the Japan Atomic Energy Research Institute (JAERI). It contains SCTF test data which show the (1) adding UPI to a cold leg injection (CLI) system caused the post-LOCA maximum core temperature to decrease from 1195°K to 1158°K and (2) subcooling of the UPI water caused a further decrease to 1119°K (per pages 24-27). However, (3) the corresponding time to bottom of core recovery (BOCREC) (equivalent to the beginning of reflood) increased substantially from 19 seconds to 80 and 81 seconds (per pages 47 and 30) and (4) downward flow of subcooled UPI liquid into the core was apparently intermittent (per pages 6, 37 and 47).

The SCTF-UPI data is to directly applicable to the existing Westinghouse two loop UPI plants because the SCTF-UPI test used both accumulators and pumps to provide both UPI and CLI, with the UPI flow about equal to the CLI flow (per page 24). Additionally, the UPI nozzle was at the bottom of the upper plenum (per page 24) rather than the level of the hot legs. Nevertheless, the SCTF tests had important features representative of a full size 1100 MWe Westinghouse PWR, e.g., full height heater rods and full radial width of a core. Also, the tests document phenomena which can be used to develop and /or test a UPI model, e.g., hot leg flow reversal (pages 15 and 53-54), fluid temperature variations in the upper plenum and upper core (pages 38-40) and horizontal pressure variations at three heights inside the core (pages 42-43).

Besides providing JAERI-M-84-221, we will provide proprietary "Quick Look" Reports (QLRs) on UPI tests at JAERI's Cylindrical Core Test Facility (CCTF) as follows: (1) QLRs on CCTF UPI tests 57 and 59 were provided previously; (2) a QLR on the no-single failure UPI test 72 will probably be available

8502280389 850213 PDR ADOCK 05000305 PDR PDR Mr. D. C. Hintz

٦

February 13, 1985

in February or March; and (3) draft QLRs on asymmetric UPI tests 76 and 78 will probability be available in March. We suggest you provide copies of the enclosure and of the QLRs to those fuel vendors assisting you in UPI model development.

An NRC-JAERI discussion of the UPI tests will be held in the Bethesda, Maryland area for two days about March 12-14, 1985. The NRC Office of Nuclear Regulatory Research (RES) expects to arrange for UPI licensees and their designated fuel vendor representatives to observe those discussions and to participate with JAERI representatives in round-table technical discussions of UPI phenomena. We anticipate that we will be able to keep the discussions from becoming unwieldy if we limit each UPI licensee to designating one employee observer, one employee participant, one vendor observer and one vendor participant, with a maximum of one observer and one participant present from any given fuel vendor.

Please let us know if you intend to send an employee observer, an employee technical participant, a vendor observer and/or a vendor technical participant so that we can set up the meeting with JAERI and the NRC. Please respond by phone by February 20, 1985 to Dr. David Langford on 301-492-9403.

Sincerely,

/s/SVarga

Steven A. Varga, Chief Operating Reactors Branch #1 Division of Licensing £

Enclosure: As stated

cc w/enclosure: See next page

ORB#1:DLMBJ #1:DL MFairtile;ps 2/7/85 BELORB #3:DL ORB#3:DL DDilanni JMiller 2/**12**/85 2/12/85

Mr. D. C. Hintz Wisconsin Public Service Corporation

cc: Steven E. Keane, Esquire Foley and Lardner 777 East Wisconsin Avenue Milwaukee, Wisconsin 53202

> Stanley LaCrosse, Chairman Town of Carlton Route 1 Kewaunee, Wisconsin 54216

Mr. Donald L. Quistroff, Chairman Kewaunee County Board Kewaunee County Courthouse Kewaunee, Wisconsin 54216

Chairman Public Service Commission of Wisconsin Hill Farms State Office Building Madison, Wisconsin 53702

Attorney General 114 East, State Capitol Madison, Wisconson 53702

U.S. Nuclear Regulatory Commission Resident Inspectors Office Route #1, Box 999 Kewaunee, Wisconsin 54216

Regional Radiation Representative EPA Region V 230 South Dearborn Street Chicago, Illinois 60604

James G. Keppler Regional Administrator - Region III U.S. Nuclear Regulatory Commission 799 Roosevelt Road Glen Ellyn, Illinois 60137

Mr. Robert S. Cullen Chief Engineer Wisconsin Public Service Commission P.O. Box 7854 Madison, Wisconsin 53707 Kewaunee Nuclear Power Plant