

REGULATOR INFORMATION DISTRIBUTION SYSTEM (RIDS)

ACCESSION NBR:8007280685 DOC.DATE: 80/07/22 NOTARIZED: NO DOCKET #
 FACIL:50-305 Kewaunee Nuclear Power Plant, Wisconsin Public Service 05000305
 AUTH.NAME AUTHOR AFFILIATION
 NALEPKA,D.S. Wisconsin Public Service Corp.
 RECIP.NAME RECIPIENT AFFILIATION
 Region 3, Chicago, Office of the Director

SUBJECT: LER 80-028/03L-0:on 800623,during hot shutdown,condensate storage tank was twice drawn below 75,000 gallons through normal water usage for plant startup.Caused by normal high water usage during startup following refueling.

DISTRIBUTION CODE: A002S COPIES RECEIVED:LTR L ENCL 1 SIZE: 1+1
 TITLE: Incident Reports

NOTES:I&E:3 copies all material. 05000305

ACTION:	RECIPIENT ID CODE/NAME	COPIES LTR ENCL	RECIPIENT ID CODE/NAME	COPIES LTR ENCL
	VARGA,S. 05	1 1	LICCIARDO,R. 06	2 2
INTERNAL:	A/D COMP&STRUCT	1 1	A/D ENV TECH	1 1
	A/D MATL & QUAL	1 1	A/D OP REACTORS	1 1
	A/D PLANT SYS	1 1	A/D RAD PROT	1 1
	A/D SFTY ASSESS	1 1	A/D TECHNOLOGY	1 1
	ACC EVAL BR	1 1	AEOD	10 10
	AUX SYS BR	1 1	CHEM ENG BR	1 1
	CONT SYS BR	1 1	CORE PERF BR	1 1
	D/DIR,HUM FAC S	1 1	DIR,ENGINEERING	1 1
	DIR,HUM FAC SFY	1 1	DIR,SYS INTEG	1 1
	EFF TR SYS BR	1 1	EMERG PREP	1 1
	EQUIP QUAL BR	1 1	GEOSCIENCES	1 1
	HUM FACT ENG BR	1 1	HYD/GEO BR	1 1
	I&C SYS BR	1 1	I&E 09	2 2
	JORDAN,E./IE	1 1	LIC GUID BR	1 1
	LIC QUAL BR	1 1	MATL ENG BR	1 1
	MECH ENG BR	1 1	MPA 11	3 3
	NRC PDR 02	1 1	OP EX EVAL BR	3 3
	OR ASSESS BR	1 1	POWER SYS BR	1 1
	PROC/TST REV BR	1 1	QA BR	1 1
	RAD ASSESS BR	1 1	REACT SYS BR	1 1
	<u>REG FILE</u> 01	1 1	REL & RISK A BR	1 1
	SFTY PROG EVAL	1 1	SIT ANAL BR	1 1
	STRUCT ENG BR	1 1	SYS INTERAC BR	1 1
EXTERNAL:	ACRS	16 16	LPDR 03	1 1
	NSIC 04	1 1	TERA:DOUG MAY	1 1

JUL 30 1980

TOTAL NUMBER OF COPIES REQUIRED: LTR 85 ENCL 85

NO/I 4 60

LICENSEE EVENT REPORT

CONTROL BLOCK: _____ (PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)

01 | W | I | K | N | P | 1 | 2 | 0 | 0 | - | 0 | 0 | 0 | 0 | 0 | - | 0 | 0 | 3 | 4 | 1 | 1 | 1 | 1 | 4 | _____ | 5
7 8 9 14 15 25 26 30 57 CAT 58

CON'T
01 | REPORT SOURCE | L | 6 | 0 | 5 | 0 | 0 | 0 | 3 | 0 | 5 | 7 | 0 | 6 | 2 | 3 | 8 | 0 | 8 | 0 | 7 | 2 | 3 | 8 | 0 | 9
7 8 60 61 68 69 74 75 80

EVENT DESCRIPTION AND PROBABLE CONSEQUENCES (10)

02 | While the plant was being maintained at hot shutdown following refueling, the
03 | condensate storage tank (CST) was twice drawn below 75,000 gallons through normal
04 | water usage for plant startup. This placed the facility under LCO TS 3.4.a.4.
05 | The service water supply was available and the demineralizers were operating and
06 | returned level above 75,000 gallons; therefore, there was no effect on plant
07 | operation or public safety.

08 | _____ 80

09 | SYSTEM CODE: W F (11) CAUSE CODE: X (12) CAUSE SUBCODE: Z (13) COMPONENT CODE: A C C U M U (14) COMP. SUBCODE: Z (15) VALVE SUBCODE: Z (16)
7 8 9 10 11 12 13 18 19 20

(17) LER/RO REPORT NUMBER: 8 0 (21) 22 (23) SEQUENTIAL REPORT NO.: 0 2 8 (24) 26 (27) OCCURRENCE CODE: 0 3 (28) 29 (30) REPORT TYPE: L (31) 32 REVISION NO.: 0 (32) 32

ACTION TAKEN: X (18) 33 FUTURE ACTION: Z (19) 34 EFFECT ON PLANT: Z (20) 35 SHUTDOWN METHOD: Z (21) 36 HOURS: 0 0 0 0 (22) 37 40 ATTACHMENT SUBMITTED: N (23) 41 NPRD-4 FORM SUB.: N (24) 42 PRIME COMP. SUPPLIER: A (25) 43 COMPONENT MANUFACTURER: G 0 5 5 (26) 44 47

CAUSE DESCRIPTION AND CORRECTIVE ACTIONS (27)

10 | This condition is possible following refueling due to high water usage during
11 | startup. All systems operated normally and CST level was returned to normal as
12 | soon as possible. No further corrective action is necessary.

13 | _____

14 | _____ 80

15 | FACILITY STATUS: G (28) 8 9 % POWER: 0 0 0 (29) 10 12 OTHER STATUS: Hot Shutdown (30) 13 METHOD OF DISCOVERY: A (31) 45 DISCOVERY DESCRIPTION: Operator Observation (32) 46

16 | ACTIVITY RELEASED: Z (33) 8 9 CONTENT OF RELEASE: Z (34) 10 AMOUNT OF ACTIVITY: NA (35) 44 LOCATION OF RELEASE: NA (36) 45

17 | PERSONNEL EXPOSURES NUMBER: 0 0 0 (37) 8 9 TYPE: Z (38) 11 DESCRIPTION: NA (39) 13

18 | PERSONNEL INJURIES NUMBER: 0 0 0 (40) 8 9 DESCRIPTION: NA (41) 11

19 | LOSS OF OR DAMAGE TO FACILITY TYPE: Z (42) 8 9 DESCRIPTION: NA (43) 11

20 | PUBLICITY ISSUED: N (44) 8 9 DESCRIPTION: NA (45) 10

800 728 0685