

REGULATORY INFORMATION DISTRIBUTION SYSTEM (RIDS)

ACCESSION NBR: 8012100324 DOC. DATE: 80/12/05 NOTARIZED: NO DOCKET #  
 FACIL: 50-305 Kewaunee Nuclear Power Plant, Wisconsin Public Service 05000305  
 AUTH. NAME: AUTHOR AFFILIATION  
 MATHEWS, E. R. Wisconsin Public Service Corp.  
 RECIP. NAME: RECIPIENT AFFILIATION  
 Office of Management and Program Analysis

SUBJECT: Forwards monthly operating rept for Nov 1980.

DISTRIBUTION CODE: A008S COPIES RECEIVED: LTR L ENCL L SIZE: 2+3  
 TITLE: Annual, Semi-Annual & Monthly Operating Reports (OL Stage)

NOTES: I&E: 3 copies all material. 05000305

	RECIPIENT ID CODE/NAME		COPIES LTR ENCL		RECIPIENT ID CODE/NAME		COPIES LTR ENCL
ACTION:	VARGA, S.	04	7	7			
INTERNAL:	AEOD		1	1	D/DIR, HUM FAC07		1 1
	I&E	06	2	2	MPA 13		2 2
	NRC PDR	02	1	1	OP EX EVAL BR09		1 1
	OR ASSESS BR	10	1	1	<u>REG FILE</u> 01		1 1
EXTERNAL:	ACRS	11	1	1	BROOKHAVEN 12		1 1
	LPDR	03	1	1	NSIC 05		1 1

DEC 11 1980

MR

TOTAL NUMBER OF COPIES REQUIRED: LTR 24 ENCL 24  
~~24~~ ~~24~~

L.J.

WISCONSIN PUBLIC SERVICE CORPORATION



P.O. Box 1200, Green Bay, Wisconsin 54305

December 5, 1980

DISTRIBUTION  
SERVICES UNIT

DEC 9 PM 12 47

US NRC  
COMMUNICATIONS  
DIVISION

Director  
Office of Management Information &  
Program Control  
U. S. Nuclear Regulatory Commission  
Washington, D. C. 20555

Gentlemen:

Docket 50-305  
Operating License DPR-43  
Kewaunee Nuclear Power Plant  
Monthly Operating Report

The narrative "Summary of Operating Experience" and completed forms covering plant and component availability for the Kewaunee Nuclear Power Plant for November, 1980, are enclosed.

Very truly yours,

E. R. Mathews, Vice President  
Power Supply & Engineering

snf

Enc.

cc - Mr. J. G. Keppler, Reg Dir  
US NRC - Region III  
Mr. Ted Cintula  
US NRC - Maryland National Bank Bldg  
Mr. Robert Nelson, NRC Resident Inspector  
RR #1, Box 999, Kewaunee, WI 54216

A008  
s  
//

8012100 324

R

KEWAUNEE NUCLEAR POWER PLANT  
SUMMARY OF OPERATING EXPERIENCE  
NOVEMBER, 1980

OPERATIONS: On November 27 the unit load was decreased for the monthly turbine stop valve test.

MAINTENANCE: Replaced a failed solenoid valve on a SV damper.

Replaced a failed relay in the starting circuit of a service water pump.

Repaired a leaking service water line at a component cooling heat exchanger.

Replaced a sheave on a charging pump.