

# ACCELERATED DISTRIBUTION DEMONSTRATION SYSTEM

## REGULATORY INFORMATION DISTRIBUTION SYSTEM (RIDS)

ACCESSION NBR:8901180314 DOC.DATE: 88/06/09 NOTARIZED: YES DOCKET #  
 FACIL:50-305 Kewaunee Nuclear Power Plant, Wisconsin Public Servic 05000305  
 AUTH.NAME AUTHOR AFFILIATION  
 HINTZ,D.C. Wisconsin Public Service Corp.  
 RECIP.NAME RECIPIENT AFFILIATION  
 DAVIS,A.B. Region 3, Ofc of the Director

SUBJECT: Responds to NRC Bulletin 88-003, "Inadequate Latch  
 Engagement in HFA Type Latching Relays Mfg by GE."

DISTRIBUTION CODE: IE11D COPIES RECEIVED:LTR 1 ENCL 0 SIZE: 1  
 TITLE: Bulletin Response (50 DKT)

### NOTES:

	RECIPIENT ID CODE/NAME	COPIES LTTR ENCL	RECIPIENT ID CODE/NAME	COPIES LTTR ENCL
	PD3-3 LA	1 0	PD3-3 PD	1 1
	GIITTER,J	1 1		
INTERNAL:	AEOD/DOA	1 1	AEOD/DSP/TPAB	1 1
	NRR ALEXION,T	1 1	NRR/DEST/ADE 8H	1 1
	NRR/DEST/ADS 7E	1 1	NRR/DEST/MEB 9H	1 1
	NRR/DOEA/EAB 11	1 1	NRR/DOEA/GCB 11	1 1
	NRR/DREP/EPB 10	1 1	NRR/PMAS/ILRB12	1 1
	NUDOCS-ABSTRACT	1 1	<u>REG FILE</u> 02	1 1
	RES/DSIR/EIB	1 1	RGN3 FILE 01	1 1
EXTERNAL:	LPDR	1 1	NRC PDR	1 1
	NSIC	1 1		

NOTE TO ALL "RIDS" RECIPIENTS:

PLEASE HELP US TO REDUCE WASTE! CONTACT THE DOCUMENT CONTROL DESK,  
 ROOM P1-37 (EXT. 20079) TO ELIMINATE YOUR NAME FROM DISTRIBUTION  
 LISTS FOR DOCUMENTS YOU DON'T NEED!

TOTAL NUMBER OF COPIES REQUIRED: LTTR 20 ENCL 19

A/01 cc



**WISCONSIN PUBLIC SERVICE CORPORATION**

600 North Adams • P.O. Box 19002 • Green Bay, WI 54307-9002

June 9, 1988

10 CFR 50.54(f)

Mr. A. Bert Davis, Regional Administrator  
Region III  
U.S. Nuclear Regulatory Commission  
799 Roosevelt Road  
Glen Ellyn, IL 60137

Dear Mr. Davis:

Docket 50-305  
Operating License DPR-43  
Kewaunee Nuclear Power Plant  
Response to NRC Bulletin No. 88-03

NRC Bulletin No. 88-03 entitled "Inadequate Latch Engagement In HFA Type Latching Relays Manufactured By General Electric (GE) Company" was transmitted to Wisconsin Public Service Corporation (WPSC) by letter dated March 10, 1988.

The subject bulletin requested our response as to whether the Kewaunee Nuclear Power Plant (KNPP) has HFA type latching relays in any Class 1E (safety-related) systems or spare HFA type latching relays. Based on a record search and discussions with plant maintenance and substation personnel, we have concluded that HFA type latching relays manufactured by the General Electric Company are not used at KNPP or in KNPP's substation. Therefore this bulletin is not applicable to KNPP.

Sincerely,

D. C. Hintz  
Vice President - Nuclear Power

DR/jms

cc - US NRC Document Control Desk  
Mr. Robert Nelson, US NRC

Subscribed and Sworn to  
Before Me This 9th Day  
of June 1988

Notary Public, State of Wisconsin

My Commission Expires:  
June 23, 1991