

ACCELERATED DISTRIBUTION DEMONSTRATION SYSTEM

REGULATORY INFORMATION DISTRIBUTION SYSTEM (RIDS)

ACCESSION NBR:8903100286 DOC.DATE: 89/03/01 NOTARIZED: NO DOCKET #
 FACIL:50-305 Kewaunee Nuclear Power Plant, Wisconsin Public Servic 05000305
 AUTH.NAME AUTHOR AFFILIATION
 STEINHARDT,C.R. Wisconsin Public Service Corp.
 RECIP.NAME RECIPIENT AFFILIATION
 Document Control Branch (Document Control Desk)

SUBJECT: Discusses clarification to scope of NRC Bulletin 88-010.

DISTRIBUTION CODE: IE11D COPIES RECEIVED: LTR 1 ENCL 1 SIZE: 2
 TITLE: Bulletin Response (50 DKT)

NOTES:

	RECIPIENT		COPIES			RECIPIENT		COPIES	
	ID CODE/NAME		LTR	ENCL		ID CODE/NAME		LTR	ENCL
	PD3-3 LA		1	0		PD3-3 PD		1	1
	GIITTER,J		1	1					
INTERNAL:	AEOD/DOA		1	1		AEOD/DSP/TPAB		1	1
	NRR/DEST/ADE 8H		1	1		NRR/DEST/ADS 7E		1	1
	NRR/DEST/MEB 9H		1	1		NRR/DOEA/EAB 11		1	1
	NRR/DOEA/GCB 11		1	1		NRR/DREP/EPB 10		1	1
	NRR/PMAS/ILRB12		1	1		NUDOCS-ABSTRACT		1	1
	REG FILE 02		1	1		RES/DSIR/EIB		1	1
	RGN3 FILE 01		1	1					
EXTERNAL:	LPDR		1	1		NRC PDR		1	1
	NSIC		1	1					

NOTE TO ALL "RIDS" RECIPIENTS:

PLEASE HELP US TO REDUCE WASTE! CONTACT THE DOCUMENT CONTROL DESK,
 ROOM P1-37 (EXT. 20079) TO ELIMINATE YOUR NAME FROM DISTRIBUTION
 LISTS FOR DOCUMENTS YOU DON'T NEED!

TOTAL NUMBER OF COPIES REQUIRED: LTR 19 ENCL 18

A/OI
cc

R
I
D
S
/
A
D
D
S

R
I
D
S
/
A
D
D
S



WISCONSIN PUBLIC SERVICE CORPORATION

600 North Adams • P.O. Box 19002 • Green Bay, WI 54307-9002

March 1, 1989

U. S. Nuclear Regulatory Commission
ATTN: Document Control Desk
Washington, D.C. 20555

Gentlemen:

Docket 50-305
Operating License DPR-43
Kewaunee Nuclear Power Plant
Clarification to Scope of NRC Bulletin 88-10

NRC Bulletin 88-10 entitled "Nonconforming Molded-Case Circuit Breakers" requires licensees to verify the traceability of circuit breakers purchased prior to August 1, 1988 which are being maintained as stored spares for safety related applications. Based on the results of the traceability effort additional actions are specified in the bulletin.

Wisconsin Public Service Corporation has been rigorously performing documentation searches to support this bulletin. During the establishment of our plan for responding to the bulletin some questions regarding the scope of the bulletin activities have surfaced. To receive clarification on the bulletin scope, Mr. David S. Nalepka and Mr. David L. Masarik of my staff contacted Mr. Joseph Giitter and Mr. Paul Gill of the NRC staff on January 10, 1989.

Based on the telecon on January 10, 1989 the following interpretations were discussed and concurred with:


1. Although the bulletin states that all non-traceable warehouse stock breakers must be tested, an alternative to testing does exist. The breakers determined to be non-traceable can be removed from safety related stock and considered as a test failed breaker without testing.
2. The intent of the bulletin is to identify those breakers that may have been purchased from a supplier other than the manufacturer. It is recognized that the potential for procuring these breakers from a supplier other than the circuit breaker manufacturer (CBM) is greatest when order is in a small quantity (i.e. repair/replacement components). For larger quantity orders,

IE 11
11

such as those that occur during original construction, there is reasonable assurance that the breakers were purchased directly from the CBN or are traceable to the CBM. Therefore, if a breaker was purchased under an original construction purchase order, reasonable assurance exists that the breaker was supplied by CBM and is therefore acceptable. With this understanding, tracing a breaker to an original plant construction purchase order is adequate without requiring further tracing of these breakers to the CBM.

WPSC is continuing to implement the actions required by NRC Bulletin 88-10 and we expect to submit the written report required in the bulletin by the April 1, 1989 due date. Based on the telecon of January 10, 1989, our program is being implemented utilizing the clarifications summarized above.

Sincerely,



C. R. Steinhardt
Manager - Nuclear Power

DR/jms

cc - Mr. Robert Nelson, US NRC
US NRC, Region III