

ACCELERATED DISTRIBUTION DEMONSTRATION SYSTEM

REGULATORY INFORMATION DISTRIBUTION SYSTEM (RIDS)

ACCESSION NBR:9005230087 DOC.DATE: 90/05/16 NOTARIZED: NO DOCKET #
 FACIL:50-305 Kewaunee Nuclear Power Plant, Wisconsin Public Servic 05000305
 AUTH.NAME AUTHOR AFFILIATION
 EVERS,K.H. Wisconsin Public Service Corp.
 RECIP.NAME RECIPIENT AFFILIATION
 Document Control Branch (Document Control Desk)

SUBJECT: Provides summary of NRC Bulletin 88-008, Suppl 3 insps.

DISTRIBUTION CODE: IE16D COPIES RECEIVED: LTR 1 ENCL 0 SIZE: 1
 TITLE: Bulletin Response 88-08 - Thermal Stress in Piping to RCS.

NOTES:

	RECIPIENT ID CODE/NAME	COPIES LTTR ENCL	RECIPIENT ID CODE/NAME	COPIES LTTR ENCL
	PD3-3 LA	1 0	PD3-3 PD	1 1
	DAVIS, MIKE	1 1		
INTERNAL:	AEOD/DOA	1 1	AEOD/DSP/TPAB	1 1
	NRR HARTZMAN, M	1 1	NRR HUM, M	1 1
	NRR MOZAFARI, B	1 1	NRR/DET/EMEB9H3	1 1
	NRR/DOEA/OEAB11	1 1	NRR/DOEA/OGCB11	1 1
	NRR/DREP/PEPB9D	1 1	NRR/DST/8E2	1 1
	NRR/PMAS/ILRB12	1 1	REG FILE 02	1 1
	RES/DSIR/EIB	1 1	RGN3 FILE 01	1 1
EXTERNAL:	LPDR	1 1	NRC PDR	1 1
	NSIC	1 1		

NOTE TO ALL "RIDS" RECIPIENTS:

PLEASE HELP US TO REDUCE WASTE! CONTACT THE DOCUMENT CONTROL DESK,
 ROOM PI-37 (EXT. 20079) TO ELIMINATE YOUR NAME FROM DISTRIBUTION
 LISTS FOR DOCUMENTS YOU DON'T NEED!

TOTAL NUMBER OF COPIES REQUIRED: LTTR 20 ENCL 19

*A10-1
cert*



WISCONSIN PUBLIC SERVICE CORPORATION

600 North Adams • P.O. Box 19002 • Green Bay, WI 54307-9002

May 16, 1990

U.S Nuclear Regulatory Commission
Attn: Document Control Desk
Washington, D.C. 20555

Gentlemen:

Docket 50-305
Operating License DPR-43
Kewaunee Nuclear Power Plant
Summary of Bulletin 88-08 Supplement 3 Inspections

Reference 1) Letter from Mr. C. R. Steinhardt (WPSC) to Document Control Desk
dated August 31, 1989, Response to Bulletin 88-08 Supplement 3

In response to Bulletin 88-08 Supplement 3 (reference 1) Wisconsin Public Service Corporation (WPSC) committed to inspect 3 welds on the Kewaunee Nuclear Power Plant's (KNPP) Residual Heat Removal (RHR) suction lines. The inspections were scheduled for and completed during the 1990 refueling outage.

The KNPP refueling outage ended on April 17, 1990. In accordance with the requirements of Bulletin 88-08 this letter is being submitted to report the results of these inspections.

The three affected welds (2 on the A loop, 1 on the B loop) were ultrasonically inspected using 0°, 45° and 60° beam transducers. These examinations found no recordable indications. All three welds were also subjected to a liquid penetrant examination. No recordable indications were noted during the surface examinations. As no recordable indications were found as a result of these examinations, the inspection frequency will remain as stated in reference 1.

If you have any further questions regarding this response please contact me or a member of my staff.

Sincerely,

A handwritten signature in dark ink, appearing to read "K. H. Evers", with a stylized flourish at the end.

K. H. Evers
Manager - Nuclear Power

DCL/mjm
cc - Mr. Patrick Castleman, US NRC
US NRC, Region III

9005230087 900516
PDR ADDCK 05000305
Q PDC

TE/6
1/0