

ACCELERATED DISTRIBUTION DEMONSTRATION SYSTEM

REGULATORY INFORMATION DISTRIBUTION SYSTEM (RIDS)

ACCESSION NBR: 9204070270 DOC. DATE: 92/04/03 NOTARIZED: YES DOCKET #
 FACIL: 50-305 Kewaunee Nuclear Power Plant, Wisconsin Public Service 05000305
 AUTH. NAME AUTHOR AFFILIATION
 STEINHARDT, C.R. Wisconsin Public Service Corp.
 RECIP. NAME RECIPIENT AFFILIATION
 Document Control Branch (Document Control Desk)

SUBJECT: Submits results of NDE during 1992 outage to demonstrate continued integrity of pressurizer auxiliary spray line. Informs that no indications found & actions complete, per Bulletin 88-008, Suppl 3.

DISTRIBUTION CODE: IE16D COPIES RECEIVED: LTR 1 ENCL 0 SIZE: 1
 TITLE: Bulletin Response 88-08 - Thermal Stress in Piping to RCS.

NOTES:

| | RECIPIENT | | COPIES | | | RECIPIENT | | COPIES | |
|-----------|-----------------|--|--------|------|--|-----------------|--|--------|------|
| | ID CODE/NAME | | LTR | ENCL | | ID CODE/NAME | | LTR | ENCL |
| | PD3-3 LA | | 1 | 0 | | PD3-3 PD | | 1 | 1 |
| | HANSEN, A. | | 1 | | | | | | |
| INTERNAL: | AEOD/DOA | | 1 | 1 | | NRR HARTZMAN, M | | 1 | 1 |
| | NRR HUM, M | | 1 | 1 | | NRR MOZAFARI, B | | 1 | 1 |
| | NRR/DET/EMEB 7E | | 1 | 1 | | NRR/DOEA/OEAB11 | | 1 | 1 |
| | NRR/DOEA/OGCB11 | | 1 | 1 | | NRR/DREP/PEPB9D | | 1 | 1 |
| | NRR/DST/ 8E2 | | 1 | 1 | | NRR/PMAS/ILRB12 | | 1 | 1 |
| | REG FILE 02 | | 1 | 1 | | RES/DSIR/EIB | | 1 | 1 |
| | RG3 FILE 01 | | 1 | | | | | | |
| EXTERNAL: | NRC PDR | | 1 | 1 | | NSIC | | 1 | 1 |

NOTE TO ALL "RIDS" RECIPIENTS:

PLEASE HELP US TO REDUCE WASTE! CONTACT THE DOCUMENT CONTROL DESK, ROOM P1-37 (EXT. 20079) TO ELIMINATE YOUR NAME FROM DISTRIBUTION LISTS FOR DOCUMENTS YOU DON'T NEED!

TOTAL NUMBER OF COPIES REQUIRED: LTR 18 ENCL 17 0

WPSC (414) 433-1598
TELECOPIER (414) 433-5544



EASYLINK 62891993

WISCONSIN PUBLIC SERVICE CORPORATION

800 North Adams • P.O. Box 19002 • Green Bay, WI 54307-9002

April 3, 1992

U.S. Nuclear Regulatory Commission
Attn: Document Control Desk
Washington, D.C. 20555

Gentlemen:

Docket 50-305
Operating License DPR-43
Kewaunee Nuclear Power Plant
Summary of Bulletin 88-08 Supplement 3 Inspection

Reference: 1) Letter from Mr. C. R. Steinhardt (WPSC) to Document Control Desk (NRC) dated March 10, 1992, Response to Bulletin 88-08 Supplement 3.

In reference 1, Wisconsin Public Service Corporation (WPSC) committed to perform a nondestructive examination during the 1992 outage to demonstrate the continued integrity of the pressurizer auxiliary spray line. The purpose of this letter is to report the results of that examination. Consistent with reporting requirement 2 of Bulletin 88-08, WPSC hereby confirms that these actions have been completed.

On March 11, 1992 a section of pipe approximately six inches in length, located downstream and adjacent to check valve CVC-16, was ultrasonically examined. The examination included scanning 100% of the pipe circumference using 0°, 45° and 60° transducers. This examination confirmed the integrity of the auxiliary spray pipe in that no indications were found.

If you have any further questions regarding this response please contact me or a member of my staff.

Sincerely,

C. R. Steinhardt
Senior Vice President - Nuclear Power

RLF/jms

cc - US NRC - Region III
Mr. Patrick Castleman, US NRC

Subscribed and Sworn to
Before Me This 3rd Day
of April 1992

Notary Public, State of Wisconsin

My Commission Expires:

June 18, 1995

IE16
110

9204070270 920403
PDR ADOCK 05000305
Q PDR