

NRC DISTRIBUTION FOR PART 50 DOCKET MATERIAL

FILE NUMBER

TO: Mr. A. Schwencer

FROM: Wisconsin Public Service Corp.  
Green Bay, Wisconsin 54305  
E. W. James

DATE OF DOCUMENT  
03-21-77

DATE RECEIVED  
03-25-77

LETTER  
 ORIGINAL  
 COPY

NOTORIZED  
 UNCLASSIFIED

PROP

INPUT FORM

NUMBER OF COPIES RECEIVED  
**1 signed**

DESCRIPTION

Ltr. Ref. our 03-17-77 ltr...Trans The  
Following:

( 1 page )

**DO NOT REMOVE**

PLANT NAME: KEWAUNEE

jem

**ACKNOWLEDGED**

ENCLOSURE

Consists of requested information  
regarding, Steam Generators and Secondary  
System water chemistry...

( 2 pages )

SAFETY

FOR ACTION/INFORMATION

ENVIRO

ASSIGNED AD:		ASSIGNED AD:
BRANCH CHIEF:	<i>Schwencer (5)</i>	BRANCH CHIEF:
PROJECT MANAGER:	<i>Neighbors</i>	PROJECT MANAGER:
LIC. ASST.:	<i>Sheppard</i>	LIC. ASST.:

INTERNAL DISTRIBUTION

REG FILE	SYSTEMS SAFETY	PLANT SYSTEMS	SITE SAFETY & ENVIRO ANALYSIS
NRC PDR	HEINEMAN	TEDESCO	DENTON & MULLER
I & E (2)	SCHROEDER	BENAROYA	
OELD		LAINAS	
GOSSICK & STAFF	ENGINEERING	IPPOLITO	ENVIRO TECH.
MIPC	MACARRY	KIRKWOOD	ERNST
CASE	BOSNAK		BALLARD
HANAUER	SIHWEIL	OPERATING REACTORS	YOUNGBLOOD
HARLESS	PAWLICKI	STELLO	
			SITE TECH.
PROJECT MANAGEMENT	REACTOR SAFETY	OPERATING TECH.	GAMMILL
BOYD	ROSS	EISENHUT	STEPP
P. COLLINS	NOVAK	SHAO	HULMAN
HOUSTON	ROSZTOCZY	BAER	
PETERSON	CHECK	BUTLER	SITE ANALYSIS
MELTZ		GRIMES	VOLLMER
HELTEMES	AT & I		BUNCH
SKOVHOLT	SALTZMAN		J. COLLINS
	RUTBERG		KREGER

EXTERNAL DISTRIBUTION

CONTROL NUMBER

LPDR: <i>Kewanee, WI</i>	NAT. LAB:	BROOKHAVEN NAT. LAB.	<p><b>770870203</b></p> <p>MAY 69</p>
TIC:	REG V. IE	ULRIKSON (ORNL)	
NSIC:	LA PDR		
ASLB:	CONSULTANTS:		
ACRS / 6 CYS HOLDING / SENT	<i>As CAT B</i>		

WISCONSIN PUBLIC SERVICE CORPORATION



P.O. Box 1200, Green Bay, Wisconsin 54305

March 21, 1977

**REGULATORY DOCKET FILE COPY**

Office of Nuclear Reactor Regulation  
U. S. Nuclear Regulatory Commission  
Washington, D. C. 20555

ATTN: Mr. A. Schwencer, Chief  
Operating Reactors Branch No. 1



Gentlemen:

REF: Docket 50-305  
Operating License DPR-43

On March 17, 1977, we were requested by Mr. Neighbors of your staff to supply information pertaining to our Steam Generators and Secondary System water chemistry. On March 21, 1977, we telecopied the requested completed questionnaire to your office. Please find attached a copy of that completed questionnaire.

Very truly yours,

A handwritten signature in cursive script that reads "E. W. James".

E. W. James  
Senior Vice President  
Power Supply & Engineering

EWJ:sna  
Attach.

770870203

Steam Generator Information Request, NRC March 17, 1977

Utility: Wisconsin Public Service Corporation  
Plant Name: Kewaunee Nuclear Power Plant  
Docket: DPR-43

a. Significant Operating History

1. O L date December 21, 1973
2. Full power operation Mid June 1974
3. Major periods of down time (non-refueling)  
September 19, 1974 to October 18, 1974 - Steam Generator  
Preservice inspection and change to AVT chemistry

b. Materials of construction for major secondary system components

1. S.G. Tubes: Inconel ASME-SB-163
2. S.G. Tube Sheet: Steel ASME-SA-508 clad on primary  
side with Inconel
3. S.G. Tube Support Plates: Steel ASTM-A285
4. Condenser Tubes: Admiralty or 304 Stainless Steel
5. Secondary Piping: Carbon steel
- Feedwater Heaters: Copper nickel annealed
- Condensate Heaters: Admiralty or copper nickel annealed

c. Operational history of secondary water treatment

1. Period of use of phosphates: During August of 1973, hot functional tests were performed which included 20 days of hot operation followed by five months of wet layup. Hot operations were performed from February 1974 to September 1974 during unit startup and four months of full power operation.
2. Period of use of AVT: October 1974 to present
3. Period of condensate demineralization: None
4. Other: None

d. Condenser cooling water - Typical chemical composition: Lake Michigan is the water source data of water quality presented in the "Environmental Report Operating License Stage" Tables 2.3-4 and 2.3-5. The following presents typical water quality data from these tables:

% O <sub>2</sub> saturation	-	85%	
pH	-	8.0	
Specific conductance $\mu$ mhos/cm	-	268	
Total alkalinity as CaCO <sub>3</sub>	-	120 mg/l	
Total dissolved solids	-	170 mg/l	
Mg	-	12 mg/l	
Ca	-	35 mg/l	
Na	-	4.0 mg/l	

e. History of significant condenser tube leakage:

1. Date discovered: December 1974 and January 1975 through remainder of first cycle to February 1976
2. How discovered: Water chemistry monitoring Na, Ca, Mg
3. Leakage associated: 10 gal/day

f. Denting history:

1. Date discovered: None

g. Steam Generator tube plugging history

1. Dates: None
2. Number of tubes: Zero

h. Operating restrictions imposed on the plant due to degraded S.G. conditions: None

RECEIVED 5/18/80

RECEIVED DOCUMENT  
PROCESSING UNIT

1977 MAR 26 AM 8 30