

R. Boyd, Assistant Director for Reactor Projects
THRU: S. Levine, Assistant Director for
Reactor Technology, DRL
V. Moore, Chief
Instrumentation and Power Technology Branch, DRL

FEB 13 1968

WISCONSIN PUBLIC SERVICE CORPORATION, KEWAUNEE NUCLEAR POWER PLANT,
DOCKET #50-305

I&PTB:DRL:JVB - RT-404

This memorandum is to confirm questions concerning electric power for Kewaunee which were given informally to Ray G. Smith and have been discussed with the applicant. The response to these questions is required before we can evaluate the Kewaunee electrical system. The following questions were asked in the technical meeting of February 2, 1968, by Mr. J. V. Burgess:

1. Please include your evaluation of the possible trip of the unit, and its effect on the system.
2. Describe the provisions to interlock circuit breakers for diesel generators so that both cannot be closed to the same bus at the same time.
3. Please confirm that batteries will be in two separate rooms.

cc: S. Levine
D. Knuth
R. Smith
V. Moore
O. Parr
J. Burgess

Distribution:
Suppl.
DRL Reading
AD/RT Reading
I&PTB Reading

OFFICE ▶	DRL	DRL	DRL			
SURNAME ▶	J Burgess/plm	VMoore	SLevine			
DATE ▶	2/12/68	2/12/68	2/13/68			