

[7590-01]

[Docket No. 50-305]

**WISCONSIN PUBLIC SERVICE CORP., ET AL.****Issuance of Amendment to Facility Operating License**

The U.S. Nuclear Regulatory Commission (the Commission) has issued Amendment No. 18 to Facility Operating License No. DPR-43 issued to Wisconsin Public Service Corp., Wisconsin Power & Light Co., and Madison Gas & Electric Co. which revised Technical Specifications for operation of the Kewaunee Nuclear Power Plant located in Kewaunee, Wis. The amendment is effective within 30 days of the date of issuance.

The amendment to the Technical Specification establishes, (1) Provisions for steam generator tube inspection that are consistent with the guidance contained in Regulatory Guide 1.83, Revision 1, dated July 1975, with the exception of deviations determined by the staff to enhance the overall inspection program, (2) provisions for monitoring secondary water chemistry, and (3) a new limit on reactor coolant to secondary leakage.

The application for the amendment complies with the standards and requirements of the Atomic Energy Act of 1954, as amended (the Act), and the Commission's rules and regulations. The Commission has made appropriate findings as required by the Act and the Commission's rules and regulations in 10 CFR Chapter I, which are set forth in the license amendment. Prior public notice of this amendment was not required since the amendment does not involve a significant hazards consideration.

The Commission has determined that the issuance of this amendment will not result in any significant environmental impact and that pursuant to 10 CFR § 51.5(d)(4) an environmental impact statement or negative declaration and environmental impact appraisal need not be prepared in connection with the issuance of this amendment.

For further details with respect to this action, see (1) the application for amendment dated November 15, 1976, as supplemented September 6, 1977, (2) Amendment No. 18 to Facility Operating License No. DPR-43, and (3) the Commission's related Safety Evaluation. All of these items are available for public inspection at the Commission's Public Document Room, 1717 H Street NW., Washington, D.C. 20555, and at the Kewaunee Public Library, 314 Milwaukee Street, Kewaunee, Wis. 54216. A copy of items (2) and (3) may be obtained upon request addressed to the U.S. Nuclear Regulatory Commission, Washington, D.C. 20555, Attention: Director, Division of Operating Reactors.

Dated at Bethesda, Md., this 31st day of January 1978.

For the Nuclear Regulatory Commission.

A. SCHWENCER,  
*Chief, Operating Reactors  
Branch No. 1, Division of Operating Reactors.*

[FR Doc. 78-5012 Filed 2-24-78; 8:45 am]

[7590-01]

[Docket No. 50-305]

**WISCONSIN PUBLIC SERVICE CORP., ET AL.****Issuance of Amendment to Facility Operating License**

The U.S. Nuclear Regulatory Commission (the Commission) has issued Amendment No. 19 to Facility Operating License No. DPR-43 issued to Wisconsin Public Service Corp., Wisconsin Power & Light Co., and Madison Gas & Electric Co. (the licensee) which revised Technical Specifications for operation of the Kewaunee Nuclear Power Plant located in Kewaunee, Wis. The amendment is effective as of the date of issuance.

The amendment revises the Technical Specifications to: (1) provide updated organizational charts of the licensee's corporate nuclear staff and the Kewaunee plant, (2) redefine the composition of the Nuclear Safety Review and Audit Committee, (3) delete the requirements for an Annual Operating Report, (4) make minor changes to reporting requirements for radioactive effluent releases and (5) delete section 6.12 of the Technical Specifications titled Respiratory Protection Program.

The application for the amendment complies with the standards and requirements of the Atomic Energy Act of 1954, as amended (the Act), and the Commission's rules and regulations. The Commission has made appropriate findings as required by the Act and the Commission's rules and regulations in 10 CFR Chapter I, which are set forth in the license amendment. Prior public notice of this amendment does not involve a significant hazards consideration.

The Commission has determined that the issuance of this amendment will not result in any significant environmental impact and that pursuant to 10 CFR § 51.5(d)(4) an environmental impact statement or negative declaration and environmental impact appraisal need not be prepared in connection with the issuance of this amendment.

For further details with respect to this action, see (1) the application for amendment dated October 28, 1977, (2) Amendment No. 19 to Facility Operating License No. DPR-43, and (3)

the Commission's related Safety Evaluation. All of these items are available for public inspection at the Commission's Public Document Room, 1717 H Street NW., Washington, D.C. 20555, and at the Kewaunee Public Library, 314 Milwaukee Street, Kewaunee, Wis. 54216. A copy of items (2) and (3) may be obtained upon request addressed to the U.S. Nuclear Regulatory Commission, Washington, D.C. 20555, Attention: Director, Division of Operating Reactors.

Dated at Bethesda, Md., this 25th day of January 1978.

For the Nuclear Regulatory Commission.

A. SCHWENCER,  
*Chief, Operating Reactors  
Branch No. 1, Division of Operating Reactors.*

[FR Doc. 78-5011 Filed 2-24-78; 8:45 am]

[7590-01]

**REGULATORY GUIDE****Issuance and Availability**

The Nuclear Regulatory Commission has issued a guide in its Regulatory Guide Series. This series has been developed to describe and make available to the public methods acceptable to the NRC staff of implementing specific parts of the Commission's regulations and, in some cases, to delineate techniques used by the staff in evaluating specific problems or postulated accidents and to provide guidance to applicants concerning certain of the information needed by the staff in its review of applications for permits and licenses.

Regulatory Guide 1.122, Revision 1, "Development of Floor Design Response Spectra for Seismic Design of Floor-Supported Equipment or Components," describes methods acceptable to the NRC staff for developing two horizontal and one vertical floor design response spectra at various floors or other equipment-support locations of interest from the time-history motions resulting from the dynamic analysis of the supporting structure. This guide, the last in a series of guides that delineate current procedures for applying the vibratory ground motion to design, was revised as the result of public comment and additional staff review.

Comments and suggestions in connection with (1) items for inclusion in guides currently being developed, or (2) improvements in all published guides are encouraged at any time. Comments should be sent to the Secretary of the Commission, U.S. Nuclear Regulatory Commission, Washington, D.C. 20555, Attention: Docketing and Service Branch.

Regulatory guides are available for inspection at the Commission's Public

mz