

**NRC DISTRIBUTION FOR PART 50 DOCKET MATERIAL  
(TEMPORARY FORM)**

CONTROL NO: 4122

FILE: Enviro

FROM: Wisconsin Public Service Corp Greenbay, Wiscon C.R. Luoma			DATE OF DOC 4-10-75	DATE REC'D 4-16-75	LTR xx	TWX	RPT	OTHER
TO: Mr. Duane Boyd			ORIG no	CC 1	OTHER	SENT AEC PDR <u>xxxx</u> SENT LOCAL PDR <u>xxx</u>		
CLASS	UNCLASS xxxx	PROP. INFO	INPUT	NO CYS REC'D 1		DOCKET NO: 50-305		

**DESCRIPTION:**

Ltr reporting Environmental Abnormal Occurrence  
ETSR#75-2 on 4-5-75 concerning failure  
to record intake and discharge temperatures  
every 15 minutes during a power decrease of  
25% or greater .....

**ENCLOSURES:**

**PLANT NAME:**

Kewaunee

**FOR ACTION/INFORMATION**

4-17-75 JGB

BUTLER (L) W/ Copies	SCHWENCER (L) W/ Copies	ZIEMANN (L) W/ Copies	REGAN (E) W/ Copies
CLARK (L) W/ Copies	STOLZ (L) W/ Copies	DICKER (E) W/ Copies	LEAR (L) W/ Copies
PARR (L) W/ Copies	VASSALLO (L) W/ Copies	KNIGHTON (E) W/ Copies	SPELS W/ Copies
KNIEL (L) W/ Copies	PURPLE (L) W/ Copies	YOUNGBLOOD (E) W/ Copies	W/ Copies

**INTERNAL DISTRIBUTION**

<del>REG FILE</del> NRC PDR OGC, ROOM P-506A GOSSICK/STAFF CASE GIAMBUSSO BOYD MOORE (L) DEYOUNG (L) SKOVHOLT (L) GOLLER (L) (Ltr) P. COLLINS DENISE <del>REG OPR</del> FILE & REGION (2) T.R. WILSON STEELE	TECH REVIEW SCHROEDER MACCARY KNIGHT PAWLICKI SHAO STELLO HOUSTON NOVAK ROSS IPPOLITO TEDESCO LONG LAINAS BENAROYA VOLLMER	DENTON GRIMES GAMMILL KASTNER BALLARD SPANGLER  ENVIRO MULLER DICKER KNIGHTON YOUNGBLOOD REGAN PROJECT LDR <del>OESTMANN</del> HARLESS	LIC ASST R. DIGGS (L) H. GEARIN (L) E. GOULBOURNE (L) P. KREUTZER (E) J. LEE (L) M. MAIGRET (L) S. REED (E) M. SERVICE (L) S. SHEPPARD (L) <i>HR</i> M. SLATER (E) <i>HR</i> H. SMITH (L) S. TEETS (L) G. WILLIAMS (E) V. WILSON (L) R. INGRAM (L)	A/T IND. BRAITMAN SALTZMAN MELTZ  PLANS MCDONALD CHAPMAN DUBE (Ltr) E. COUPE PETERSON HARTFIELD (2) KLECKER EISENHUT WIGGINTON  <i>HANAUER</i>
--	---	---	---	--

**EXTERNAL DISTRIBUTION**

1 - LOCAL PDR <u>Kewaunee, Wisconsin</u>	1 - NATIONAL LABS <i>ANL</i>	1 - PDR-SAN/LA/NY
1 - TIC (ABERNATHY) <i>11/21/75</i>	1 - W. PENNINGTON, Rm E-201 GT	1 - BROOKHAVEN NAT LAB
1 - NSIC (BUCHANAN)	1 - CONSULTANTS	1 - G. ULRIKSON, ORNL
1 - ASLB	NEWMARK/BLUME/AGBABIAN	1 - AGMED (RUTH GUSSMAN) Rm B-127 GT
1 - Newton Anderson		1 - J. D. RUNKLES, Rm E-201 GT
- ACRS HOLDING/SENT		

TELEGRAM

April 10, 1975

Mr. Duane Boyd  
Resident Inspector - U.S. Nuclear Regulatory Commission  
Directorate of Regulatory Operations - Region III  
Two Rivers Municipal Hospital  
Two Rivers, Wisconsin

SUBJECT: Docket 50-305  
OPERATING LICENSE: DPR-43  
REPORTABLE INCIDENT - Environmental Technical Specifications

In accordance with the Requirements of Environmental Technical Specifications (Appendix B) Paragraph 5.4.b and 3.1.3, we submit the following:

Report Number: 50-305/ETSR75-2

Occurrence Date: April 5, 1975

Facility: Kewaunee Nuclear Power Plant  
Kewaunee, Wisconsin

Identification of Occurrence:

Failure to record intake and discharge temperatures every 15 minutes during a power decrease of 25% or greater

Condition Prior to Occurrence:

Reactor Critical - 39% Power      o  
Normal Operating Temperature - 547 F  
Normal Operating Pressure - 2235 PSIG

Description of Occurrence:

Load on unit was being decreased prior to coming off line to perform repairs on the EH controller on the turbine. During the decrease in load data on the EH controller operating parameters was being recorded. The load was decreased greater than 25% and during this period temperatures were recorded every 30 minutes.

  
C. R. Luoma

4122