

JUN 27 1975

Docket No. 50-305

Wisconsin Public Service Corporation
ATTN: Mr. E. W. James
Senior Vice President
P. O. Box 1200
Green Bay, Wisconsin 54305

Gentlemen:

DISTRIBUTION:

Docket File
NRC PDR HDenton
Local PDR RBallard
EP-1 Reading WKnapp
NRR Reading OELD
AGiambusso MSlater
KRGoller JAllen, IE
RPurple (Region III)
JNeighbors
DMuller
GKnighton
MJOestmann
LHiggenbotham
OIE (3)

Based on a Kewaunee Monitoring Inspection Report (50-305/75-1) of January 14 - 16, 1975 inspection, it came to our attention that wastes from the water softener, turbine building sumps, the condenser hotwell and overflow from the settling pond are not limited, nor is monitoring through the Environmental Technical Specification required. We understand that releases from the condenser hotwell, in particular, totaled 1.1 million gallons in 1974, compared with the 1.6 million gallons from the waste neutralizer tank. Amendment No. 3, issued on March 20, 1975, to the Facility Operating License DPR-43 included limitations on the discharges from the waste neutralizer tank.

On April 17, 1975, a discussion of the unmonitored releases took place between your staff and NRC staff. Based on this discussion, we recommend that you review the Environmental Technical Specifications, and based on your findings, submit a proposed technical specification change which will include monitoring and recording the amount and concentrations and/or pH of these discharges. In addition, include the additional revision to other specifications you desire, including reporting requirements based on Regulatory Guide 1.16, as revised.

We request that you submit to us within fourteen (14) days of receipt of this letter your schedule as to submission of changes to the ETS. If you have any questions regarding this request, please contact M. J. Oestmann, Environmental Project Manager (301 443-6951).

Original signed by
George W. Knighton

George W. Knighton, Chief
Environmental Projects Branch No. 1
Division of Reactor Licensing

cc: See next page

Emw
(21)

OFFICE ➤	RI:EP-1 <i>into</i>	RI:EP-1 <i>into</i>				
SURNAME ➤	MJOestmann:sh	GWKnighton				
DATE ➤	6/26/75	6/ /75				

JUN 27 1975

- 2 -

Mr. Carl Giesler
Superintendent of Nuclear Power
Wisconsin Public Service Corporation
P. O. Box 1200
Green Bay, Wisconsin 54305

Steven E. Keane, Esq.
Foley, Sammond and Lardner
735 North Water Street
Milwaukee, Wisconsin 53202

Bruce W. Churchill, Esq.
Shaw, Pittman, Potts & Trowbridge
910 17th Street, NW.
Washington, D. C. 20006

Mr. Arden Koehler
Chairman, Town of Carlton
Route 1
Kewaunee, Wisconsin 54216

Mr. Donald E. Quistorff
Chairman, Kewaunee County Board
Kewaunee County Courthouse
Kewaunee, Wisconsin 54216

Mr. Gary Williams
Federal Activities Branch
Environmental Protection Agency
230 South Dearborn Street
Chicago, Illinois 60604

Patrick DeWane, Esq.
Attorney, Town of Two Creeks
Manitowoc, Wisconsin 54241

Mr. Neill Thomasson
ATTN: Ms. Loretto Long
Office of Radiation Programs
Room 647A East Tower Waterside Mall
Environmental Protection Agency
401 M Street, NW.
Washington, D. C. 20460

Mr. Richard D. Cudahy
Public Service Commission of
Wisconsin
Hill Farms State Office Building
Madison, Wisconsin 53702