



WISCONSIN PUBLIC SERVICE CORPORATION

600 North Adams • P.O. Box 19002 • Green Bay, WI 54307-9002

August 30, 1990

10 CFR 50.36a(a)(2)

U. S. Nuclear Regulatory Commission
ATTN: Document Control Desk
Washington, D.C. 20555

Gentlemen:

Docket 50-305
Operating License DPR-43
Kewaunee Nuclear Power Plant
Semiannual Effluent Release Report January-June 1990

Enclosed please find a copy of the Kewaunee Nuclear Power Plant Semiannual Effluent Release Report for January through June 1990. This report is submitted to meet the requirements of Technical Specification 6.9.3.b.

The June 1990 proportional composites for Gross Alpha, Strontium 89, Strontium 90 and Iron 55 were not available at the time that this report was written. WPSC's Project Manager, Mr. M. J. Davis, was notified in a telephone conversation with Ms. B. J. DeCleene (WPSC) that a supplemental report shall be submitted when these values become available.

Sincerely,

A handwritten signature in cursive script, appearing to read "K. H. Evers".

K. H. Evers
Manager - Nuclear Power

BJD/jms

Enc. *see Enviro Reports*

cc - Mr. Patrick Castleman, US NRC
US NRC, Region III

9009070140 900630
PDR ADOCK 05000305
R PDC

Handwritten initials "TEAB" with a vertical line underneath, and another set of handwritten initials to the right.

50-305 KEWAUNEE

SEMIANNUAL EFFLUENT RELEASE REPORT
JANUARY-JUNE 1990

REC'D W/LTR DTD 08/30/90...9009070140

-NOTICE-

THE ATTACHED FILES ARE OFFICIAL RECORDS OF THE RECORDS & REPORTS MANAGEMENT BRANCH. THEY HAVE BEEN CHARGED TO YOU FOR A LIMITED TIME PERIOD AND MUST BE RETURNED TO THE RECORDS & ARCHIVES SERVICES SECTION P1-122 WHITE FLINT. PLEASE DO NOT SEND DOCUMENTS CHARGED OUT THROUGH THE MAIL. REMOVAL OF ANY PAGE(S) FROM DOCUMENT FOR REPRODUCTION MUST BE REFERRED TO FILE PERSONNEL.

-NOTICE-

KEWAUNEE NUCLEAR POWER PLANT

**SEMI-ANNUAL
EFFLUENT RELEASE REPORT
JANUARY - JUNE 1990**

WISCONSIN PUBLIC SERVICE CORPORATION

WISCONSIN POWER & LIGHT COMPANY

MADISON GAS & ELECTRIC COMPANY

DOCKET 50-305

KEWAUNEE NUCLEAR POWER PLANT
SEMIANNUAL RADIOACTIVE
EFFLUENT RELEASE REPORT
JANUARY - JUNE 1990

WISCONSIN PUBLIC SERVICE CORPORATION
GREEN BAY, WISCONSIN
AUGUST 1990

TABLE OF CONTENTS

<u>SECTION</u>	<u>DESCRIPTION</u>	<u>PAGE</u>
1.0	INTROOUCION	1
1.1	Technical Specification Limits	1
2.0	GASEOUS EFFLUENTS	2
2.1	Lower Limits of Detection (LLD) for Gaseous Effluents	2
2.2	Gaseous Batch Release Statistics	4
2.3	Gaseous Effluent Data	4
	Table 2.1 Gaseous Effluents-Summation of all Releases	5
	Table 2.2 Gaseous Effluents-Elevated Release	6
	Table 2.3A Gaseous Release Total	7
	Table 2.3B Gaseous Release Continuous	11
	Table 2.3C Gaseous Release Batch	15
	Table 2.4 Dose From Gaseous Effluents	19
3.0	LIQUID EFFLUENTS	21
3.1	Lower Limits of Detection (LLD) for Liquid Effluents	21
3.2	Liquid Batch Release Statistics	23
3.3	Liquid Effluent Data	23
	Table 3.1 Liquid Effluents - Summation of all Releases	24
	Table 3.2A Liquid Effluents - Batch Releases 1st Qtr	25
	Table 3.2B Liquid Effluents - Batch Releases 2nd Qtr	27
	Table 3.3A Liquid Effluents - Continuous Releases - 1st Qtr	29
	Table 3.3B Liquid Effluents - Continuous Releases - 2nd Qtr	30
	Table 3.4 Dose From Liquid Effluents	31

TABLE OF CONTENTS

<u>SECTION</u>	<u>DESCRIPTION</u>	<u>PAGE</u>
4.0	UNPLANNED RELEASES	33
5.0	METEOROLOGICAL DATA	33
6.0	SOLID WASTE DISPOSAL	33
	Table 6.1 Solid Waste and Irradiated Fuel Shipments	34
7.0	PROGRAM REVISIONS	38
8.0	REPORTABLE OCCURRENCES	38

1.0 INTRODUCTION

This report is being submitted in accordance with the requirements of Kewaunee Technical Specifications, Section 6.9.3.b. It includes data from all effluent releases made from January through June 1990. The report contains summaries of the gaseous and liquid releases made to the environment including the quantity, characterization, time duration and calculated radiation dose at the site boundary resulting from these releases. The report also includes a summation of solid waste disposal, revisions to the Process Control Program and the Offsite Dose Calculation Manual, and addresses the cumulative meteorological data.

1.1 Technical Specification Limits

Specifications are set to insure that offsite doses are maintained as low as reasonably achievable while still allowing for practical and dependable operation of the Kewaunee Plant.

The Kewaunee Offsite Dose Calculation Manual (ODCM) is used in conjunction with Section 7 of the Technical Specifications. The ODCM describes the methodology and parameters used in:

1. The calculation of radioactive liquid and gaseous effluent monitoring instrumentation alarm/trip setpoints.
2. The calculation of radioactive liquid and gaseous concentrations, dose rates and cumulative quarterly and annual doses. The ODCM methodology is acceptable for use in demonstrating compliance with 10 CFR 20.106; 10 CFR 50, Appendix I; and 40 CFR 190.

2.0 GASEOUS EFFLUENTS

2.1 Lower Limits of Detection (LLD) for Gaseous Effluents

Gaseous radioactive effluents are released in both the continuous mode and the batch mode. The auxiliary building stack is sampled continuously for particulates, halogens and Strontium by an "off-line" sample train. This stack is also grab-sampled daily for gaseous gamma emitters. Batch releases are sampled prior to release for principal gaseous and particulate gamma emitters, halogens and tritium.

- *** The proportional composites for Gross Alpha, Strontium 89, and Strontium 90 were not available at the time that this report was written. When these values are available, applicable revisions shall be submitted.

The required LLD's for gaseous radioanalyses, as listed in Table 8.4 of the Kewaunee Technical Specifications, are:

<u>Analysis</u>	<u>LLD (uCi/ml)</u>
Gaseous Gamma Emitters	1.00 E-04
Iodine 131	3.00 E-12
Particulate Gamma Emitters	1.00 E-11
Particulate Gross Alpha	1.00 E-11
Strontium 89, 90	1.00 E-11
Noble Gases, Gross Beta or Gamma	1.00 E-06

The nominal "a priori" LLD values are shown below.

<u>Isotope</u>	<u>a priori LLD (uCi/ml)</u>
a. Gaseous emissions:	
Kr-87	2.19 E-8
Kr-88	2.76 E-8
Xe-133	2.64 E-8
Xe-133m	6.53 E-8
Xe-135	7.97 E-9
Xe-138	3.16 E-8

b. Particulate emissions:

Mn-54	3.04 E-14
Fe-59	9.00 E-14
Co-58	4.06 E-14
Co-60	1.12 E-13
Zn-65	6.41 E-14
Mo-99	2.00 E-14
Cs-134	3.38 E-14
Cs-137	5.89 E-14
Ce-141	2.99 E-14
Ce-144	1.18 E-13

c. Other identifiable gamma emitters:

Ar-41	1.21 E-8
Kr-85	3.69 E-6
Kr-85m	7.14 E-9
Kr-89	2.50 E-7
Xe-127	7.72 E-9
Xe-131m	2.92 E-7
Xe-135m	1.71 E-8
Xe-137	9.67 E-8
I-131	1.97 E-14

d. Composite particulate samples:

Sr-89	1 E-14
Sr-90	1 E-14
Gross Alpha	6.00 E-15

These "a priori" LLDs represent the capabilities of the counting systems in use, not an after the fact "a posteriori" limit for a particular measurement.

2.2 Gaseous Batch Release Statistics

The following is a summation of all gaseous batch releases made during the first half of 1990.

Number of batch releases	14
Total time for all batch releases (Sec) . .	3.57 E+5
Maximum time for one batch release (Sec) . .	8.64 E+4
Average time for a batch release (Sec) . . .	2.55 E+4
Minimum time for a batch release (Sec) . . .	1.62 E+3

2.3 Gaseous Effluent Data

The following Table 2.1 presents a quarterly summation of the total activity released and average release rates of four categories of gaseous effluents. Table 2.2 lists the quarterly sums of individual gaseous radionuclides released by continuous and batch modes. Table 2.3 is essentially the same data, but is presented as monthly summations. Table 2.4 presents the dose limits for gaseous effluents for the 1st and 2nd quarters, and the calculated doses this year from gaseous effluents.

TABLE 2.1
Semiannual Radioactive Effluent Release Report 1990
Gaseous Effluents-Summation of all Releases

	<u>1st Quarter</u>	<u>2nd Quarter</u>
<u>Fission and Activation Gases</u>		
Total Activity Released (Ci)	1.51 E+0	6.44 E-1
Average Release Rate (uCi/Sec)	1.94 E-1	8.19 E-2
<u>Iodines</u>		
Total Activity Released (Ci)	1.16 E-6	9.07 E-10
Average Release Rate (uCi/Sec)	1.49 E-7	1.15 E-10
<u>Particulates</u>		
Total Activity Released (Ci)	1.24 E-3	3.12 E-4
Average Release Rate (uCi/Sec)	1.59 E-4	3.97 E-5
Gross Alpha Released (Ci)	5.96 E-4	1.67 E-4
<u>Tritium</u>		
Total Activity Released (Ci)	1.73 E+0	3.40 E+0
Average Release Rate (uCi/Sec)	2.22 E-1	4.33 E-1

TABLE 2.2
Semiannual Radioactive Effluent Release Report 1990
Gaseous Effluents-Elevated Release

<u>Nuclides Released (Ci)</u>	<u>Continuous Mode</u>		<u>Batch Mode</u>	
	<u>1st Qtr</u>	<u>2nd Qtr</u>	<u>1st Qtr</u>	<u>2nd Qtr</u>
<u>Fission Gases</u>				
Ar-41	-0-	-0-	9.15 E-1	2.60 E-2
Kr-85	-0-	-0-	3.40 E-2	-0-
Xe-131m	-0-	5.32 E-1	-0-	-0-
Xe-133	-0-	8.50 E-2	5.33 E-1	6.15 E-4
Xe-133m	-0-	-0-	4.88 E-5	-0-
Xe-135	-0-	-0-	2.84 E-2	-0-
Xe-135m	-0-	-0-	4.34 E-6	-0-
Unidentified	-0-	-0-	-0-	-0-
Total for Period	-0-	6.17 E-1	1.51 E+0	2.66 E-2
<u>Iodines</u>				
I-131	1.15 E-6	-0-	1.00 E-9	9.07 E-10
I-132	-0-	-0-	3.29 E-9	-0-
I-133	-0-	-0-	1.72 E-9	-0-
Total for Period	1.15 E-6	-0-	6.01 E-9	9.07 E-10
<u>Particulates</u>				
Co-58	7.28 E-7	5.69 E-7	-0-	-0-
Co-60	3.87 E-6	1.96 E-6	-0-	-0-
Rb-88	-0-	-0-	1.38 E-7	-0-
Sr-89	-0-	-0-	-0-	-0-
Sr-90	-0-	-0-	-0-	-0-
Nb-95	1.06 E-6	-0-	-0-	-0-
Sn-113	6.40 E-8	-0-	-0-	-0-
Cs-137	1.14 E-7	1.51 E-7	-0-	-0-
Unidentified	1.04 E-7	7.97 E-6	1.23 E-3	3.01 E-4
Total for Period	5.94 E-6	1.06 E-5	1.24 E-3	3.01 E-4

TABLE 2.3A
Semiannual Radioactive Effluent Release Report 1990
1st Quarter Gaseous Release
Total of all Releases

Noble Gases (Curies)

<u>Isotope</u>	<u>January</u>	<u>February</u>	<u>March</u>	<u>Total</u>
Ar-41	-0-	-0-	9.15 E-1	9.15 E-1
Kr-85	-0-	-0-	3.40 E-2	3.40 E-2
Xe-131m	-0-	-0-	-0-	-0-
Xe-133	-0-	-0-	5.33 E-1	5.33 E-1
Xe-133m	-0-	-0-	4.88 E-5	4.88 E-5
Xe-135	-0-	-0-	2.84 E-2	2.84 E-2
Xe-135m	-0-	-0-	4.34 E-6	4.34 E-6
Unidentified	-0-	-0-	-0-	-0-
Total	-0-	-0-	1.51 E+0	1.51 E+0

Particulates (Curies)

<u>Isotope</u>	<u>January</u>	<u>February</u>	<u>March</u>	<u>Total</u>
Co-58	-0-	-0-	7.28 E-7	7.28 E-7
Co-60	-0-	9.80 E-7	2.89 E-6	3.87 E-6
Rb-88	-0-	-0-	1.38 E-7	1.38 E-7
Sr-89	-0-	-0-	-0-	-0-
Sr-90	-0-	-0-	-0-	-0-
Nb-95	-0-	-0-	1.06 E-6	1.06 E-6
Sn-113	-0-	-0-	6.40 E-8	6.40 E-8
Cs-137	-0-	-0-	1.14 E-7	1.14 E-7
Unidentified	2.20 E-4	2.75 E-4	7.40 E-4	1.23 E-3
Total	2.20 E-4	2.76 E-4	7.45 E-4	1.24 E-3

Halogens (Curies)

<u>Isotope</u>	<u>January</u>	<u>February</u>	<u>March</u>	<u>Total</u>
I-131	-0-	-0-	1.15 E-6	1.15 E-6
I-132	-0-	-0-	3.29 E-9	3.29 E-9
I-133	-0-	-0-	1.72 E-9	1.72 E-9
Total	-0-	-0-	1.16 E-6	1.16 E-6

TABLE 2.3A (con't)
 Semiannual Radioactive Effluent Release Report 1990
 1st Quarter Gaseous Release
 Total of all Releases

Summary

	<u>January</u>	<u>February</u>	<u>March</u>	<u>Total</u>
Total Noble Gases (Ci)	-0-	-0-	1.51 E+0	1.51 E+0
Total Halogens (Ci)	-0-	-0-	1.16 E-6	1.16 E-6
Total Particulate Gross Beta-Gamma (Ci)	2.20 E-4	2.76 E-4	7.45 E-4	1.24 E-3
Total Particulate Gross Beta-Gamma Half-Lives >8 Days (Ci)	-0-	9.80 E-7	4.86 E-6	5.84 E-6
Total Tritium (Ci)	9.18 E-1	3.85 E-1	4.28 E-1	1.73 E+0
Total Particulate Gross Alpha (Ci)	1.13 E-4	1.19 E-4	3.64 E-4	5.96 E-4
Maximum Noble Gas Release Rate (uCi/Sec)	≤8.45 E-1	≤7.99 E-1	≤2.34 E+1	-

TABLE 2.3A (con't)
 Semiannual Radioactive Effluent Release Report 1990
 2nd Quarter Gaseous Release
 Total of all Releases

Noble Gases (Curies)

<u>Isotope</u>	<u>April</u>	<u>May</u>	<u>June</u>	<u>Total</u>
Ar-41	2.60 E-2	-0-	-0-	2.60 E-2
Kr-85	-0-	-0-	-0-	-0-
Xe-131m	-0-	-0-	5.32 E-1	5.32 E-1
Xe-133	6.15 E-4	-0-	8.50 E-2	8.56 E-2
Xe-133m	-0-	-0-	-0-	-0-
Xe-135	-0-	-0-	-0-	-0-
Xe-135m	-0-	-0-	-0-	-0-
Unidentified	-0-	-0-	-0-	-0-
Total	2.66 E-2	-0-	6.17 E-1	6.44 E-1

Particulates (Curies)

<u>Isotope</u>	<u>April</u>	<u>May</u>	<u>June</u>	<u>Total</u>
Co-58	3.97 E-7	1.72 E-7	-0-	5.69 E-7
Co-60	6.24 E-7	1.02 E-6	3.18 E-7	1.96 E-6
Rb-88	-0-	-0-	-0-	-0-
-89	-0-	-0-	***	-0-
-90	-0-	-0-	***	-0-
Nb-95	-0-	-0-	-0-	-0-
Sn-113	-0-	-0-	-0-	-0-
Cs-137	1.51 E-7	-0-	-0-	1.51 E-7
Unidentified	1.02 E-4	1.78 E-4	2.96 E-5	3.09 E-4
Total	1.03 E-4	1.79 E-4	2.99 E-5	3.12 E-4

Halogens (Curies)

<u>Isotope</u>	<u>April</u>	<u>May</u>	<u>June</u>	<u>Total</u>
I-131	9.07 E-10	-0-	-0-	9.07 E-10
I-132	-0-	-0-	-0-	-0-
I-133	-0-	-0-	-0-	-0-
Total	9.07 E-10	-0-	-0-	9.07 E-10

TABLE 2.3A (con't)
 Semiannual Radioactive Effluent Release Report 1990
 2nd Quarter Gaseous Release
 Total of all Releases

Summary

	<u>April</u>	<u>May</u>	<u>June</u>	<u>Total</u>
Total Noble Gases (Ci)	2.66 E-2	-0-	6.17 E-1	6.44 E-1
Total Halogens (Ci)	9.07 E-10	-0-	-0-	9.07 E-10
Total Particulate Gross Beta-Gamma (Ci)	1.03 E-4	1.79 E-4	2.99 E-5	3.12 E-4
Total Particulate Gross Beta-Gamma Half-Lives >8 Days (Ci)	1.17 E-6	1.19 E-6	3.18 E-7	2.68 E-6
Total Tritium (Ci)	1.48 E+0	1.57 E+0	3.54 E-1	3.40 E+0
Total Particulate Gross Alpha (Ci)	5.22 E-5	9.83 E-5	1.62 E-5	1.67 E-4
Maximum Noble Gas Release Rate (uCi/Sec)	≤1.18 E+1	≤1.15 E+0	≤1.11 E+0	-

TABLE 2.38
Semiannual Radioactive Effluent Release Report 1990
1st Quarter Gaseous Release
Continuous Mode Only

Noble Gases (Curies)

<u>Isotope</u>	<u>January</u>	<u>February</u>	<u>March</u>	<u>Total</u>
Ar-41	-0-	-0-	-0-	-0-
Kr-85	-0-	-0-	-0-	-0-
Xe-131m	-0-	-0-	-0-	-0-
Xe-133	-0-	-0-	-0-	-0-
Xe-133m	-0-	-0-	-0-	-0-
Xe-135	-0-	-0-	-0-	-0-
Xe-135m	-0-	-0-	-0-	-0-
Unidentified	-0-	-0-	-0-	-0-
Total	-0-	-0-	-0-	-0-

Particulates (Curies)

<u>Isotope</u>	<u>January</u>	<u>February</u>	<u>March</u>	<u>Total</u>
Co-58	-0-	-0-	7.28 E-7	7.28 E-7
Co-60	-0-	9.80 E-7	2.89 E-6	3.87 E-6
Rb-88	-0-	-0-	-0-	-0-
Sr-89	-0-	-0-	-0-	-0-
Sr-90	-0-	-0-	-0-	-0-
Nb-95	-0-	-0-	1.06 E-6	1.06 E-6
Sn-113	-0-	-0-	6.40 E-8	6.40 E-8
Cs-137	-0-	-0-	1.14 E-7	1.14 E-7
Unidentified	1.04 E-7	-0-	-0-	1.04 E-7
Total	1.04 E-7	9.80 E-7	4.86 E-6	5.94 E-6

Halogens (Curies)

<u>Isotope</u>	<u>January</u>	<u>February</u>	<u>March</u>	<u>Total</u>
I-131	-0-	-0-	1.15 E-6	1.15 E-6
I-132	-0-	-0-	-0-	-0-
I-133	-0-	-0-	-0-	-0-
Total	-0-	-0-	1.15 E-6	1.15 E-6

TABLE 2.3B (con't)
 Semiannual Radioactive Effluent Release Report 1990
 1st Quarter Gaseous Release
 Continuous Mode Only

Summary

	<u>January</u>	<u>February</u>	<u>March</u>	<u>Total</u>
Total Noble Gases (Ci)	-0-	-0-	-0-	-0-
Total Halogens (Ci)	-0-	-0-	1.15 E-6	1.15 E-6
Total Particulate Gross Beta-Gamma (Ci)	1.04 E-7	9.80 E-7	4.86 E-6	5.94 E-6
Total Particulate Gross Beta-Gamma Half-Lives >8 Days (Ci)	-0-	9.80 E-7	4.86 E-6	5.84 E-6
Total Tritium (Ci)	9.18 E-1	3.84 E-1	4.12 E-1	1.71 E+0
Total Particulate Gross Alpha (Ci)	9.90 E-8	7.10 E-8	1.48 E-6	1.65 E-6
Maximum Noble Gas Release Rate (uCi/Sec)	≤7.29 E-1	≤7.29 E-1	≤9.95 E-1	-

TABLE 2.3B (con't)
 Semiannual Radioactive Effluent Release Report 1990
 2nd Quarter Gaseous Release
 Continuous Mode Only

Noble Gases (Curies)

<u>Isotope</u>	<u>April</u>	<u>May</u>	<u>June</u>	<u>Total</u>
Ar-41	-0-	-0-	-0-	-0-
Kr-85	-0-	-0-	-0-	-0-
Xe-131m	-0-	-0-	5.32 E-1	5.32 E-1
Xe-133	-0-	-0-	8.50 E-2	8.50 E-2
Xe-133m	-0-	-0-	-0-	-0-
Xe-135	-0-	-0-	-0-	-0-
Xe-135m	-0-	-0-	-0-	-0-
Unidentified	-0-	-0-	-0-	-0-
Total	-0-	-0-	6.17 E-1	6.17 E-1

Particulates (Curies)

<u>Isotope</u>	<u>April</u>	<u>May</u>	<u>June</u>	<u>Total</u>
Co-58	3.97 E-7	1.72 E-7	-0-	5.69 E-7
Co-60	6.24 E-7	1.02 E-6	3.18 E-7	1.96 E-6
Rb-88	-0-	-0-	-0-	-0-
Sr-89	-0-	-0-	***	-0-
Sr-90	-0-	-0-	***	-0-
Nb-95	-0-	-0-	-0-	-0-
Sn-113	-0-	-0-	-0-	-0-
Cs-137	1.51 E-7	-0-	-0-	1.51 E-7
Unidentified	7.97 E-6	-0-	-0-	7.97 E-6
Total	9.14 E-6	1.19 E-6	3.18 E-7	1.06 E-5

Halogens (Curies)

<u>Isotope</u>	<u>April</u>	<u>May</u>	<u>June</u>	<u>Total</u>
I-131	-0-	-0-	-0-	-0-
I-132	-0-	-0-	-0-	-0-
I-133	-0-	-0-	-0-	-0-
Total	-0-	-0-	-0-	-0-

TABLE 2.3B (con't)
 Semiannual Radioactive Effluent Release Report 1990
 2nd Quarter Gaseous Release
 Continuous Mode Only

Summary

	<u>April</u>	<u>May</u>	<u>June</u>	<u>Total</u>
Total Noble Gases (Ci)	-0-	-0-	6.17 E-1	6.17 E-1
Total Halogens (Ci)	-0-	-0-	-0-	-0-
Total Particulate Gross Beta-Gamma (Ci)	9.14 E-6	1.19 E-6	3.18 E-7	1.06 E-5
Total Particulate Gross Beta-Gamma Half-Lives >8 Days (Ci)	1.17 E-6	1.19 E-6	3.18 E-7	2.68 E-6
Total Tritium (Ci)	1.48 E+0	1.57 E+0	3.47 E-1	3.40 E+0
Total Particulate Gross Alpha (Ci)	5.03 E-6	3.70 E-8	1.16 E-7	5.18 E-6
Maximum Noble Gas Release Rate (uCi/Sec)	≤9.10 E-1	≤1.01 E+0	9.84 E-1	-

TABLE 2.3C
Semiannual Radioactive Effluent Release Report 1990
1st Quarter Gaseous Release
Batch Mode Only

Noble Gases (Curies)

<u>Isotope</u>	<u>January</u>	<u>February</u>	<u>March</u>	<u>Total</u>
Ar-41	-0-	-0-	9.15 E-1	9.15 E-1
Kr-85	-0-	-0-	3.40 E-2	3.40 E-2
Xe-131m	-0-	-0-	-0-	-0-
Xe-133	-0-	-0-	5.33 E-1	5.33 E-1
Xe-133m	-0-	-0-	4.88 E-5	4.88 E-5
Xe-135	-0-	-0-	2.84 E-2	2.84 E-2
Xe-135m	-0-	-0-	4.34 E-6	4.34 E-6
Unidentified	-0-	-0-	-0-	-0-
Total	-0-	-0-	1.51 E+0	1.51 E+0

Particulates (Curies)

<u>Isotope</u>	<u>January</u>	<u>February</u>	<u>March</u>	<u>Total</u>
Co-58	-0-	-0-	-0-	-0-
Co-60	-0-	-0-	-0-	-0-
Rb-88	-0-	-0-	1.38 E-7	1.38 E-7
Sr-89	-0-	-0-	-0-	-0-
Sr-90	-0-	-0-	-0-	-0-
Nb-95	-0-	-0-	-0-	-0-
Sn-113	-0-	-0-	-0-	-0-
Cs-137	-0-	-0-	-0-	-0-
Unidentified	2.20 E-4	2.75 E-4	7.40 E-4	1.23 E-3
Total	2.20 E-4	2.75 E-4	7.40 E-4	1.24 E-3

Halogens (Curies)

<u>Isotope</u>	<u>January</u>	<u>February</u>	<u>March</u>	<u>Total</u>
I-131	-0-	-0-	1.00 E-9	1.00 E-9
I-132	-0-	-0-	3.29 E-9	3.29 E-9
I-133	-0-	-0-	1.72 E-9	1.72 E-9
Total	-0-	-0-	6.01 E-9	6.01 E-9

TABLE 2.3C (con't)
 Semiannual Radioactive Effluent Release Report 1990
 1st Quarter Gaseous Release
 Batch Mode Only

Summary

	<u>January</u>	<u>February</u>	<u>March</u>	<u>Total</u>
Total Noble Gases (Ci)	-0-	-0-	1.51 E+0	1.51 E+0
Total Halogens (Ci)	-0-	-0-	6.01 E-9	6.01 E-9
Total Particulate Gross Beta-Gamma (Ci)	2.20 E-4	2.75 E-4	7.40 E-4	1.24 E-3
Total Particulate Gross Beta-Gamma Half-Lives >8 Days (Ci)	-0-	-0-	-0-	-0-
Total Tritium (Ci)	-0-	1.03 E-3	1.61 E-2	1.71 E-2
Total Particulate Gross Alpha (Ci)	1.13 E-4	1.19 E-4	3.63 E-4	5.95 E-4
Maximum Noble Gas Release Rate (uCi/Sec)	<u>≤</u> 1.16 E-1	<u>≤</u> 6.98 E-2	2.24 E+1	-

TABLE 2.3C (con't)
 Semiannual Radioactive Effluent Release Report 1990
 2nd Quarter Gaseous Release
 Batch Mode Only

Noble Gases (Curies)

<u>Isotope</u>	<u>April</u>	<u>May</u>	<u>June</u>	<u>Total</u>
Ar-41	2.60 E-2	-0-	-0-	2.60 E-2
Kr-85	-0-	-0-	-0-	-0-
Xe-131m	-0-	-0-	-0-	-0-
Xe-133	6.15 E-4	-0-	-0-	6.15 E-4
Xe-133m	-0-	-0-	-0-	-0-
Xe-135	-0-	-0-	-0-	-0-
Xe-135m	-0-	-0-	-0-	-0-
Unidentified	-0-	-0-	-0-	-0-
Total	2.66 E-2	-0-	-0-	2.66 E-2

Particulates (Curies)

<u>Isotope</u>	<u>April</u>	<u>May</u>	<u>June</u>	<u>Total</u>
Po-58	-0-	-0-	-0-	-0-
Po-60	-0-	-0-	-0-	-0-
Rb-88	-0-	-0-	-0-	-0-
Sr-89	-0-	-0-	-0-	-0-
Sr-90	-0-	-0-	-0-	-0-
Nb-95	-0-	-0-	-0-	-0-
Sn-113	-0-	-0-	-0-	-0-
Cs-137	-0-	-0-	-0-	-0-
Unidentified	9.37 E-5	1.78 E-4	2.96 E-5	3.01 E-4
Total	9.37 E-5	1.78 E-4	2.96 E-5	3.01 E-4

Halogens (Curies)

<u>Isotope</u>	<u>April</u>	<u>May</u>	<u>June</u>	<u>Total</u>
I-131	9.07 E-10	-0-	-0-	9.07 E-10
I-132	-0-	-0-	-0-	-0-
I-133	-0-	-0-	-0-	-0-
Total	9.07 E-10	-0-	-0-	9.07 E-10

TABLE 2.3C (con't)
 Semiannual Radioactive Effluent Release Report 1990
 2nd Quarter Gaseous Release
 Batch Mode Only

Summary

	<u>April</u>	<u>May</u>	<u>June</u>	<u>Total</u>
Total Noble Gases (Ci)	2.66 E-2	-0-	-0-	2.66 E-2
Total Halogens (Ci)	9.07 E-10	-0-	-0-	9.07 E-10
Total Particulate Gross Beta-Gamma (Ci)	9.37 E-5	1.78 E-4	2.96 E-5	3.01 E-4
Total Particulate Gross Beta-Gamma Half-Lives >8 Days (Ci)	-0-	-0-	-0-	-0-
Total Tritium (Ci)	1.31 E-3	-0-	7.18 E-3	8.49 E-3
Total Particulate Gross Alpha (Ci)	4.72 E-5	9.83 E-5	1.61 E-5	1.62 E-4
Maximum Noble Gas Release Rate (uCi/Sec)	1.10 E+1	≤1.40 E-1	≤1.23 E-1	-

TABLE 2.4
Semiannual Radioactive Effluent Release Report 1990
Dose From Gaseous Effluents

The offsite dose limits from radioactive materials in gaseous effluents are specified in Section 7 of the Kewaunee Technical Specifications and can be summarized as follows:

	<u>Whole Body Gamma</u>	<u>Skin Beta</u>	<u>Organ</u>
Quarterly	5 mRad	10 mRad	7.5 mRem
Annual	10 mRad	20 mRad	15.0 mRem

The total release of gaseous effluents during the first six months of 1990 was within Technical Specification limits. The following offsite doses were calculated using equations 2.7, 2.8 and 2.11 from the Kewaunee ODCM. Calculated offsite doses versus quarterly Technical Specification limits are shown below:

	<u>1st Qtr</u>	<u>2nd Qtr</u>
1. Gamma-Whole Body		
Specification (mRads)	5.00 E+0	5.00 E+0
Actual Dose (mRads)	9.98 E-4	1.29 E-5
% of Specification	1.99 E-2	2.58 E-4
2. Beta-Skin		
Specification (mRads)	1.00 E+1	1.00 E+1
Actual Dose (mRads)	4.21 E-4	8.34 E-5
% of Specification	4.21 E-3	8.34 E-4
3. Ingestion Pathways-Organ		
Specification (mRem)	7.50 E+0	7.50 E+0
Actual Dose (mRem)	5.63 E-4	7.28 E-4
% of Specification	7.50 E-3	9.70 E-3

TABLE 2.4 (cont.)
Semiannual Radioactive Effluent Release Report 1990
Dose From Gaseous Effluents

In addition, the cumulative annual offsite doses through the end of June versus the annual Technical Specification limits were:

	<u>Annual</u>
1. Gamma-Whole Body	
Specification (mRads)	1.00 E+1
Actual Dose (mRads)	1.01 E-3
% of Specification	1.01 E-2
2. Beta-Skin	
Specification (mRads)	2.00 E+1
Actual Dose (mRads)	5.05 E-4
% of Specification	2.52 E-3
3. Ingestion Pathways-Organ	
Specification (mRem)	1.50 E+1
Actual Dose (mRem)	1.29 E-3
% of Specification	8.60 E-3

3.0 LIQUID EFFLUENTS

3.1 Lower Limits of Detection (LLD) for Liquid Effluents

Liquid radioactive effluents are released as both batch releases and continuous releases. Each batch is sampled prior to release and analyzed for gamma emitters and tritium. A fraction of each sample is retained for a monthly proportional composite for Gross Alpha, Strontium 89, Strontium 90 and Iron 55.

*** The proportional composites for Gross Alpha, Strontium 89, Strontium 90 and Iron 55 were not available at the time that this report was written. When these values are available, applicable revisions shall be submitted.

The LLD's for liquid batch release radioanalyses, as listed in Table 8.3 of the Kewaunee Technical Specifications, are:

<u>Analysis</u>	<u>LLD (uCi/ml)</u>
Principal Gamma Emitters	1.00 E-06
Iodine 131	1.00 E-06
Tritium	1.00 E-05
Gross Alpha	5.00 E-07
Strontium 89, 90	5.00 E-08
Iron 55	1.00 E-06

The actual obtained "a priori" LLD values for batch releases are shown below.

<u>Isotope</u>	<u>a priori LLD (uCi/ml)</u>
Mn-54	8.30 E-8
Fe-59	1.83 E-7
Co-58	1.41 E-7
Co-60	2.41 E-7
Zn-65	2.06 E-7
Mo-99	5.48 E-8
Cs-134	9.35 E-8
Cs-137	8.10 E-8
Ce-141	9.31 E-8
Ce-144	4.25 E-7
I-131	7.50 E-8
H-3	4.06 E-6
Sr-89	1 E-8
Sr-90	1 E-8
Gross Alpha	1 E-9
Fe-55	3 E-8

Continuous liquid releases are grab sampled weekly and analyzed for gamma emitters. A fraction of each weekly sample is retained for a monthly proportional composite which is then analyzed for Tritium, Gross Alpha, Strontium 89, Strontium 90 and Iron 55.

The LLD's for liquid continuous release radioanalyses, as listed in Table 8.3 of the Kewaunee Technical Specifications, are:

<u>Analysis</u>	<u>LLD (uCi/ml)</u>
Principal Gamma Emitters	5.00 E-07
Iodine 131	1.00 E-06
Tritium	1.00 E-05
Gross Alpha	5.00 E-07
Strontium 89, 90	5.00 E-08
Iron 55	1.00 E-06

The actual obtained "a priori" LLD values for continuous releases are shown below.

<u>Isotope</u>	<u>a priori LLD (uCi/ml)</u>
Mn-54	3.09 E-8
Fe-59	7.48 E-8
Co-58	3.33 E-8
Co-60	5.68 E-8
Zn-65	6.87 E-8
Mo-99	2.86 E-8
Cs-134	1.56 E-8
Cs-137	1.35 E-8
Ce-141	4.30 E-8
Ce-144	1.96 E-7
I-131	1.98 E-8
H-3	4.06 E-6
Sr-89	1 E-8
Sr-90	1 E-8
Gross Alpha	1 E-9
Fe-55	3 E-8

3.2 Liquid Batch Release Statistics

The following is a summation of all liquid batch releases made during the first half of 1990.

<u>Type of Release</u>	<u>Number of Releases</u>	<u>Gallons Released</u>
Laundry	252	231,990.4
Boron Recycle	31	202,151
Miscellaneous Sources	16	145,156.3

Total time for all batch releases 25,731 Min.

Maximum time for one batch release 1085 Min.

Minimum time for one batch release 18 Min.

Average time for a batch release 86.1 Min.

3.3 Liquid Effluent Data

The following Table 3.1 presents a quarterly summation of the total activity released and average concentration for all liquid effluents. It also presents the gross alpha activity released, volume of waste released and volume of dilution water used. Tables 3.2 and 3.3 are monthly summations of the same information in Table 3.1. Table 3.2 contains the quantity of the individual isotopes released to the unrestricted area for batch releases. Table 3.3 presents a monthly summation of gross radioactivity, tritium, gross alpha and isotopic activity for the secondary blowdown and leakage releases. It also presents the monthly total volume for these releases and dilution volumes. Table 3.4 presents the doses from liquid effluents for the 1st and 2nd quarter and the calculated doses this year from liquid effluents.

TABLE 3.1
Semiannual Radioactive Effluent Release Report 1990
Liquid Effluents - Summation of all Releases

	<u>1st Qtr</u>	<u>2nd Qtr</u>	<u>Total</u>
<u>Fission and Activation Products</u>			
Total Release (Excluding H3 and Dissolved Gases) (Ci)	5.68 E-2	1.19 E-1	1.76 E-1
Average Concentration (uCi/ml)	6.28 E-9	7.95 E-9	
<u>Tritium</u>			
Total Release (Ci)	1.09 E+2	6.09 E+1	1.70 E+2
Average Concentration (uCi/ml)	1.22 E-5	4.19 E-6	
Percent of Tech Spec Limit (3.0 E-3 uCi/ml) (%)	4.07 E-1	1.40 E-1	
<u>Dissolved Gases</u>			
Total Release (Ci)	-0-	-0-	-0-
Average Concentration (uCi/ml)	-0-	-0-	
Percent of Tech Spec Limit (2.0 E-4 uCi/ml) (%)	-0-	-0-	
<u>Gross Alpha Activity</u>			
Total Release (Ci)	≤4.31 E-5	≤2.06 E-5	≤6.37 E-5
<u>Volume of Waste Released</u> (Batch Releases)			
(Liters)	1.19 E+6	1.05 E+6	2.24 E+6
<u>Volume of Dilution Water</u> (Batch Releases)			
(Liters)	8.95 E+9	1.45 E+10	2.35 E+10

TABLE 3.2A
Semiannual Effluent Radioactive Release Report 1990
Liquid Effluents - Batch Releases

<u>Liquid Releases</u>	<u>January</u>	<u>February</u>	<u>March</u>	<u>Total</u>
<u>Gross Radioactivity</u>				
Total Release (Excluding Tritium and Dissolved Gases) (Ci)	1.92 E-3	7.87 E-4	5.34 E-2	5.61 E-2
Average Concentration (uCi/ml)	8.69 E-10	4.10 E-10	1.11 E-8	
<u>Tritium</u>				
Total Release (Ci)	7.07 E+1	1.81 E+1	2.03 E+1	1.09 E+2
Average Concentration (uCi/ml)	3.20 E-5	9.43 E-6	4.21 E-6	
<u>Dissolved Noble Gases</u>				
Total Release (Ci)	-0-	-0-	-0-	-0-
Average Concentration (uCi/ml)	-0-	-0-	-0-	
<u>Gross Alpha Activity</u>				
Total Release (Ci)	<7.01 E-6	<2.00 E-7	<1.40 E-6	≤ 8.61 E-6
Average Concentration (uCi/ml)	≤3.17 E-12	≤1.04 E-13	≤2.90 E-13	
<u>Volume of Waste Released</u>				
(Liters)	2.85 E+5	2.00 E+5	7.01 E+5	1.19 E+6
<u>Volume of Dilution Water</u>				
(Liters)	2.21 E+9	1.92 E+9	4.82 E+9	8.95 E+9

TABLE 3.2A (con't)
Semiannual Radioactive Effluent Release Report 1990
Liquid Effluents - Batch Releases

	<u>January</u>	<u>February</u>	<u>March</u>	<u>Total</u>
<u>Isotopes Released</u>				
(Curies)				
Sr-89	-0-	-0-	-0-	-0-
Sr-90	-0-	-0-	-0-	-0-
Fe-55	1.25 E-3	2.17 E-4	1.25 E-3	2.72 E-3
Fe-59	-0-	-0-	3.88 E-4	3.88 E-4
Co-58	1.75 E-4	1.05 E-4	3.49 E-2	3.52 E-2
Co-60	1.85 E-4	1.80 E-4	4.37 E-3	4.74 E-3
Mn-54	-0-	-0-	7.35 E-4	7.35 E-4
Cs-134	8.24 E-5	7.55 E-5	4.25 E-4	5.83 E-4
Cs-137	1.03 E-4	1.03 E-4	4.58 E-4	6.64 E-4
Ag-110m	9.59 E-5	7.37 E-5	1.09 E-3	1.26 E-3
I-133	-0-	3.24 E-5	-0-	3.24 E-5
Sb-122	1.53 E-5	-0-	-0-	1.53 E-5
Sb-124	-0-	-0-	1.04 E-3	1.04 E-3
Sb-125	-0-	-0-	4.70 E-4	4.70 E-4
Nb-95	-0-	-0-	1.07 E-3	1.07 E-3
Cr-51	-0-	-0-	6.16 E-3	6.16 E-3
Na-24	-0-	-0-	1.53 E-5	1.53 E-5
Sn-113	-0-	-0-	3.07 E-4	3.07 E-4
Zr-95	-0-	-0-	5.99 E-4	5.99 E-4
Ni-56	-0-	-0-	1.26 E-4	1.26 E-4
W-187	1.79 E-5	-0-	-0-	1.79 E-5

TABLE 3.2B
Semiannual Radioactive Effluent Release Report 1990
Liquid Effluents - Batch Releases

<u>Liquid Releases</u>	<u>April</u>	<u>May</u>	<u>June</u>	<u>Total</u>
<u>Gross Radioactivity</u>				
Total Release (Excluding Tritium and Dissolved Gases) (Ci)	5.44 E-2	4.45 E-2	1.56 E-2	1.15 E-1
Average Concentration (uCi/ml)	1.02 E-8	9.96 E-9	3.33 E-9	
<u>Tritium</u>				
Total Release (Ci)	2.14 E+1	6.67 E+0	3.27 E+1	6.08 E+1
Average Concentration (uCi/ml)	4.03 E-6	1.49 E-6	6.97 E-6	
<u>Dissolved Noble Gases</u>				
Total Release (Ci)	-0-	-0-	-0-	-0-
Average Concentration (uCi/ml)	-0-	-0-	-0-	
<u>Gross Alpha Activity</u>				
Total Release (Ci)	<6.36 E-7	<3.73 E-7	***	≤1.01 E-6
Average Concentration (uCi/ml)	≤1.20 E-13	≤8.34 E-14	***	
<u>Volume of Waste Released</u>				
(Liters)	6.36 E+5	1.86 E+5	2.25 E+5	1.05 E+6
<u>Volume of Dilution Water</u>				
(Liters)	5.31 E+9	4.47 E+9	4.69 E+9	1.45 E+10

TABLE 3.2B (con't)
 Semiannual Radioactive Effluent Release Report 1990
 Liquid Effluents - Batch Releases

	<u>April</u>	<u>May</u>	<u>June</u>	<u>Total</u>
<u>Isotopes Released</u>				
(Curies)				
Sr-89	-0-	-0-	***	-0-
Sr-90	-0-	-0-	***	-0-
Fe-55	1.78 E-3	5.23 E-3	***	7.01 E-3
Fe-59	9.09 E-4	1.49 E-3	2.22 E-4	2.62 E-3
Co-57	-0-	4.16 E-5	-0-	4.16 E-5
Co-58	2.60 E-2	1.41 E-2	6.42 E-3	4.65 E-2
Co-60	5.78 E-3	8.10 E-3	5.19 E-3	1.91 E-2
Mn-54	6.95 E-4	6.76 E-4	2.56 E-4	1.63 E-3
Cs-134	1.09 E-4	-0-	-0-	1.09 E-4
Cs-137	1.38 E-4	-0-	-0-	1.38 E-4
Ag-110m	2.05 E-3	7.37 E-3	1.38 E-3	1.08 E-2
Sb-124	4.44 E-4	3.50 E-4	-0-	7.94 E-4
Sb-125	2.63 E-4	9.14 E-4	2.95 E-4	1.47 E-3
Nb-95	3.31 E-3	1.19 E-3	-0-	4.50 E-3
Cr-51	9.41 E-3	3.44 E-3	1.18 E-3	1.40 E-2
Sn-113	9.39 E-4	5.92 E-4	2.59 E-4	1.79 E-3
Zr-95	2.16 E-3	8.15 E-4	3.75 E-4	3.35 E-3
Ni-56	1.30 E-4	-0-	-0-	1.30 E-4
W-187	2.72 E-4	2.23 E-4	-0-	4.95 E-4
Zr-97	3.68 E-5	-0-	2.27 E-5	5.95 E-5

TABLE 3.3A
 Semiannual Radioactive Effluent Release Report 1990
 Liquid Effluents - Continuous Releases

<u>Liquid Releases</u>	<u>January</u>	<u>February</u>	<u>March</u>	<u>Total</u>
<u>Gross Radioactivity</u>				
Total Release (Excluding Tritium and Dissolved Gases) (Ci)	4.30 E-4	1.66 E-4	1.39 E-4	7.35 E-4
Average Concentration (uCi/ml)	1.28 E-11	5.44 E-12	4.12 E-12	
<u>Tritium</u>				
Total Release (Ci)	-0-	3.53 E-2	-0-	3.53 E-2
<u>Gross Alpha Activity</u>				
Total Release (Ci)	$\leq 1.01 \text{ E-5}$	$\leq 2.00 \text{ E-5}$	$\leq 4.35 \text{ E-6}$	$\leq 3.45 \text{ E-5}$
<u>Volume of Continuous Release</u>				
(Liters)	1.01 E+7	9.59 E+6	4.73 E+6	2.44 E+7
<u>Volume of Dilution Flow</u>				
(Liters)	3.37 E+10	3.05 E+10	3.37 E+10	9.79 E+10
<u>Isotopes Released</u>				
(Curies)				
Sr-89	-0-	-0-	-0-	-0-
Sr-90	-0-	-0-	-0-	-0-
Fe-55	-0-	-0-		
Co-58	2.90 E-4	4.91 E-5	1.12 E-4	1.12 E-4
Co-60	8.79 E-5	4.72 E-5	7.70 E-6	3.47 E-4
Mn-54	-0-	-0-	-0-	1.35 E-4
Sb-124	-0-	-0-	3.97 E-6	3.97 E-6
Sb-125	-0-	-0-	2.15 E-6	2.15 E-6
Xe-133m	5.22 E-5	5.96 E-5	1.27 E-5	1.27 E-5
			-0-	1.22 E-4

Note: March's volume of liquid waste released includes the gallonage from the condenser hotwell discharges released on March 3 and 4.

TABLE 3.3B
Semiannual Radioactive Effluent Release Report 1990
Liquid Effluents - Continuous Releases

<u>Liquid Releases</u>	<u>April</u>	<u>May</u>	<u>June</u>	<u>Total</u>
<u>Gross Radioactivity</u>				
Total Release (Excluding Tritium and Dissolved Gases) (Ci)	3.07 E-3	6.37 E-4	6.00 E-5	3.77 E-3
Average Concentration (uCi/ml)	9.39 E-11	1.04 E-11	9.19 E-13	
<u>Tritium</u>				
Total Release (Ci)	-0-	-0-	5.09 E-2	5.09 E-2
<u>Gross Alpha Activity</u>				
Total Release (Ci)	≤8.40 E-6	≤1.12 E-5	***	≤1.96 E-5
<u>Volume of Continuous Release</u>				
(Liters)	9.26 E+6	1.12 E+7	9.60 E+6	3.01 E+7
<u>Volume of Dilution Flow</u>				
(Liters)	3.27 E+10	6.10 E+10	6.53 E+10	1.59 E+11
<u>Isotopes Released</u>				
(Curies)				
Sr-89	-0-	-0-	***	-0-
Sr-90	-0-	-0-	***	-0-
Fe-55	1.64 E-4	3.44 E-4	***	5.08 E-4
Co-57	7.50 E-5	-0-	-0-	7.50 E-5
Co-58	1.49 E-3	2.06 E-4	6.00 E-5	1.76 E-3
Co-60	9.11 E-4	8.74 E-5	-0-	9.98 E-4
Mn-54	1.63 E-4	-0-	-0-	1.63 E-4
Ag-110m	7.04 E-6	-0-	-0-	7.04 E-6
Sb-125	2.31 E-4	-0-	-0-	2.31 E-4
Nb-95	1.61 E-5	-0-	-0-	1.61 E-5
Zr-95	1.30 E-5	-0-	-0-	1.30 E-5

Note: April's volume of liquid waste released includes the gallonage from the condenser hotwell discharges released after shutdown.

TABLE 3.4
Semiannual Radioactive Effluent Release Report 1990
Dose From Liquid Effluents

The dose to a member of the public from total liquid radioactive release for each quarter was well below the Technical Specification limits of 1.5 mRems to the body and less than or equal to 5 mRems to any organ.

Instantaneous release concentrations are limited by the individual radionuclide concentrations established in 10 CFR 20, Appendix B, for unrestricted areas. During the report period, none of the isotopes released exceeded the concentrations specified in Appendix B. The following offsite doses were calculated using equation 1.5 from the Kewaunee ODCM.

1st Quarter Dose

	<u>Total Body</u>	<u>Bone</u>	<u>Liver</u>	<u>Thyroid</u>	<u>Kidney</u>	<u>Lung</u>	<u>GI LLI</u>
Dose Total (mRem)	1.43 E-2	1.03 E-2	1.89 E-2	8.04 E-4	6.76 E-3	2.77 E-3	5.21 E-2
Quarterly Dose Limit (mRem)	1.5	5.0	5.0	5.0	5.0	5.0	5.0
Percent of Quarterly Limit (%)	0.95	0.21	0.38	0.02	0.14	0.06	1.04

TABLE 3.4 (con't)
Semiannual Radioactive Effluent Release Report 1990
Dose From Liquid Effluents

2nd Quarter Dose

	<u>Total Body</u>	<u>Bone</u>	<u>Liver</u>	<u>Thyroid</u>	<u>Kidney</u>	<u>Lung</u>	<u>GI LLI</u>
Dose Total (mRem)	3.16 E-3	1.96 E-3	4.00 E-3	3.15 E-4	1.46 E-3	7.04 E-4	1.35 E-1
Quarterly Dose Limit (mRem)	1.5	5.0	5.0	5.0	5.0	5.0	5.0
Percent of Quarterly Limit (%)	0.21	0.04	0.08	0.01	0.03	0.01	2.70

Calculated Doses This Year

	<u>Total Body</u>	<u>Bone</u>	<u>Liver</u>	<u>Thyroid</u>	<u>Kidney</u>	<u>Lung</u>	<u>GI LLI</u>
Dose Total (mRem)	1.74 E-2	1.23 E-2	2.29 E-2	1.12 E-3	8.22 E-3	3.48 E-3	1.87 E-1
Yearly Dose Limit (mRem)	3	10	10	10	10	10	10
Percent of Yearly Limit (%)	0.58	0.12	0.23	0.01	0.08	0.03	1.87

4.0 UNPLANNED RELEASES

No unplanned releases were made from the Kewaunee Plant during the report period.

5.0 METEOROLOGICAL DATA

Meteorological data for the first six months of 1990 is retained on file at the Kewaunee Nuclear Power Plant. The data on file includes a continuous strip chart recording and a 15-minute interval listing of wind speed, wind direction and atmospheric stability. This is more conservative than the requirements of Technical Specification 6.9.3.b (1)(b).

6.0 SOLID WASTE DISPOSAL

Table 6.1 is a summation of solid wastes shipped for the first half of 1990. Presented are the types of wastes, major nuclide composition, disposition of the wastes and shipping containers used. The external volume of the containers employed is: 158 ft³ - High Integrity Container (HIC); 7.5 ft³ - DOT 17H drums; and 98 ft³ - LSA boxes.

A composite sample from the 1990 dewatered resin shipments was analyzed by a contractor for transuranic nuclides. The results showed an average transuranic concentration of 1.10 E-2 nanocuries/gram, well within the disposal site limit of 10 nanocuries/gram.

Table 6.1 contains the radionuclide content (curies) and percent abundance for each rad waste type. The following radionuclides are included in Table 6.1 as a reporting requirement of 10 CFR 20.311, 10 CFR 61, and Barnwell burial site criteria on radioactive shipment manifests:

- C-14
- Nb-94
- TRU
- Cm-242
- Ni-63
- Ni-59
- Sr-90
- Tc-99 LLD value 3.0 E-5 uCi/g
- I-129 LLD value 1.7 E-5 uCi/g
- H-3 LLD value 3.2 E-5 uCi/g

Isotopes denoted by an asterisk (*) in Table 6.1 are correlated values.

TABLE 6.1
Semiannual Radioactive Effluent Release Report 1990
Solid Waste and Irradiated Fuel Shipments

A. Solid Waste Shipped Off-Site for Burial or Disposal
(Not Irradiated Fuel - Cu.M is actual waste volume not burial volume)

1. Type of Waste	Unit	January - June
a. Dewatered resin Container: HIC	Cu.M C1	8.95 E+0 1.39 E+2
b. Dry compressible contaminated waste Container: DOT 17H Drums	Cu.M C1	2.44 E+1 7.77 E-1
c. Non-compressible contaminated scrap Container: LSA Boxes	Cu.M C1	8.33 E+0 4.33 E-1
d. Contaminated filter elements Container: HIC	Cu.M C1	4.48 E+0 2.12 E+1
e. Asbestos Container: Sealand	Cu.M C1	3.32 E+1 2.26 E-1

2. Estimate of Major Nuclide by Composition
(By Type of Waste)

	%	C1
a. Mn-54	2.16 E+0	3.00 E+0
Co-57	1.88 E-1	2.62 E-1
Co-58	1.53 E+1	2.12 E+1
Co-60	4.59 E+1	6.38 E+1
Cs-134	7.63 E+0	1.06 E+1
Cs-137	5.78 E+0	8.04 E+0
Sb-125	7.91 E-1	1.10 E+0
*Fe-55	3.18 E+0	4.42 E+0
*C-14	1.18 E-1	1.64 E-1
*Tc-99	1.26 E-4	1.75 E-4
Nb-94	3.42 E-2	4.76 E-2
*TRU	6.30 E-3	8.76 E-3
*Pu-241	1.25 E-2	1.74 E-2
*Ni-63	1.86 E+1	2.59 E+1

TABLE 6.1 (con't)
 Semiannual Radioactive Effluent Release Report 1990
 Solid Waste and Irradiated Fuel Shipments

	%	C1
b. Mn-54	9.29 E-1	7.22 E-3
Co-57	9.64 E-2	7.49 E-4
Co-58	1.51 E+1	1.17 E-1
Co-60	2.15 E+1	1.67 E-1
Zr-95	1.28 E-1	9.93 E-4
Nb-95	3.11 E-1	2.42 E-3
Sn-113	1.71 E-1	1.33 E-3
Sb-125	2.90 E-1	2.25 E-3
Cs-134	1.61 E-1	1.25 E-3
Cs-137	1.71 E-1	1.33 E-3
*Ni-63	1.19 E+1	9.22 E-2
*TRU	7.37 E-3	5.73 E-5
*Pu-241	2.02 E+0	1.57 E-2
*Cm-242	6.63 E-4	5.15 E-6
*Fe-55	4.72 E+1	3.67 E-1
c. Mn-54	9.31 E-1	4.03 E-3
Co-57	9.65 E-2	4.18 E-4
Co-58	1.50 E+1	6.50 E-2
Co-60	2.15 E+1	9.31 E-2
Zr-95	1.28 E-1	5.54 E-4
Nb-95	3.12 E-1	1.35 E-3
Cs-134	1.61 E-1	6.97 E-4
Cs-137	1.72 E-1	7.45 E-4
Sb-125	2.91 E-1	1.26 E-3
Sn-113	1.72 E-1	7.45 E-4
*Fe-55	4.73 E+1	2.05 E-1
*TRU	7.39 E-3	3.20 E-5
*Pu-241	2.03 E+0	8.79 E-3
*Cm-242	6.65 E-4	2.88 E-6
*Ni-63	1.19 E+1	5.15 E-2

TABLE 6.1 (con't)
 Semiannual Radioactive Effluent Release Report 1990
 Solid Waste and Irradiated Fuel Shipments

	%	C1
d. Mn-54	4.03 E-1	8.54 E-2
Co-57	4.31 E-2	9.13 E-3
Co-58	6.18 E-1	1.31 E-1
Co-60	5.85 E+1	1.24 E+1
Nb-95	1.92 E-2	4.07 E-3
Ag-110m	1.07 E-1	2.26 E-2
Cs-134	1.20 E-1	2.55 E-2
Cs-137	5.24 E-1	1.11 E-1
Sb-125	3.69 E-1	7.83 E-2
Sn-113	3.36 E-2	7.12 E-3
*Fe-55	8.68 E-1	1.84 E-1
*Tc-99	8.63 E-4	1.83 E-4
Nb-94	1.12 E-1	2.38 E-2
*TRU	1.62 E-3	3.44 E-4
*Pu-241	1.47 E-2	3.11 E-3
*Ni-63	3.82 E+1	8.09 E+0
*Sr-90	5.00 E-3	1.06 E-3
e. Mn-54	5.88 E-1	1.33 E-3
Co-60	1.92 E+1	4.35 E-2
Zn-65	1.42 E-1	3.20 E-4
Ag-110m	4.04 E-2	9.12 E-5
Sb-125	6.06 E-2	1.37 E-4
Cs-137	1.42 E-1	3.21 E-4
*C-14	1.35 E-1	3.05 E-4
*Ni-63	1.92 E+1	4.35 E-2
*Tc-99	2.81 E-2	6.36 E-5
*Sr-90	2.25 E-3	5.09 E-6
*TRU	3.32 E-3	7.51 E-6
*Pu-241	4.78 E-2	1.08 E-4
*Cm-242	9.34 E-4	2.11 E-6
*Fe-55	6.02 E+1	1.36 E-1

3. Solid Waste Disposition

a. <u>Date of Shipment</u>	<u>Mode of Transportation</u>	<u>Destination</u>
04/19/90	CNSI 14-190H Cask	Barnwell, SC
05/03/90	CNSI 14-190H Cask	Barnwell, SC
05/17/90	CNSI 14-190H Cask	Barnwell, SC
05/30/90	Containers on Flatbed Trailers (for processing prior to disposal at Barnwell, SC)	Oak Ridge, TN
05/31/90	Containers on Flatbed Trailers (for processing prior to disposal at Barnwell, SC)	Oak Ridge, TN
06/28/90	CNSI Conventional Van	Barnwell, SC

b. Irradiated Fuel Shipments

No irradiated fuel shipments were made from the Kewaunee Nuclear Power Plant during the first six months of 1990.

7.0 PROGRAM REVISIONS

In accordance with Technical Specifications 6.9.3.b (1)(e), 6.17.2.a, 6.18.2.a and 6.19.1.a, the revisions to the Process Control Program, Offsite Dose Calculation Manual and radioactive waste systems are listed below.

7.1 Process Control Program

The Kewaunee Nuclear Power Plant Process Control Program was revised on 12/19/89. All changes were editorial in nature, no technical changes were made.

7.2 Offsite Dose Calculation Manual

The Offsite Dose Calculation Manual (ODCM) has not been revised during this report period.

7.3 Major Changes to the Radioactive Liquid, Gaseous and Solid Waste Treatment Systems

Major changes to the radioactive liquid, gaseous or solid waste systems are submitted in the annual Updated Final Safety Analysis Report consistent with Technical Specification 6.19.

8.0 REPORTABLE OCCURRENCES

At 0350 on March 12, 1990, with the plant in a refueling shutdown, it was determined that the Service Water Monitor (R-20) had been removed from service for more than 12 hours without appropriate action taken as required in Table 7.1 of the Technical Specifications. A grab sample was immediately taken and analyzed at 0409, March 12, with subsequent samples then taken every 12 hours.

The monitor was taken out of service at 1403 on March 11 due to moisture problems and at the time it was thought that it would be returned to service within 12 hours. However, the Chemistry Group was not informed of that fact, and a total of 14.1 hours elapsed since R-20 was taken out of service, 2.1 hours beyond the specification for implementing manual sampling actions.

It is reasonable to conclude that there was no activity released from the plant during this time since R-20 indicated normal background levels prior to being taken out of service and the 0409 sample on March 12 showed no detectable activity. R-20 was repaired and returned to service at 1230 on March 14, 1990.

Corrective actions to prevent this from happening again are to notify the Chemistry Group each time a similar monitor is removed from service. This will provide an independent means for scheduling the required actions, even if it is expected that the monitor will be out of service for less than 12 hours. This occurrence has been documented on KNPP Incident Report 90-036.