

## CHAPTER 4

### REACTOR

#### 4.1 Summary Description

This chapter describes the mechanical components of the reactor and reactor core, including the fuel rods and fuel assemblies, the nuclear design, and the thermal-hydraulic design.

The reactor contains a matrix of fuel rods assembled into mechanically identical fuel assemblies along with control and structural elements. The assemblies, containing various fuel enrichments, are configured into the core arrangement located and supported by the reactor internals. The reactor internals also direct the flow of the coolant past the fuel rods. The coolant and moderator are light water at a normal operating pressure of 2250 psia. The fuel, internals, and coolant are contained within a heavy walled reactor pressure vessel. An AP1000 fuel assembly consists of 264 fuel rods in a 17x17 square array. The center position in the fuel assembly has a guide thimble that is reserved for in-core instrumentation. The remaining 24 positions in the fuel assembly have guide thimbles. The guide thimbles are joined to the top and bottom nozzles of the fuel assembly and provide the supporting structure for the fuel grids.

The fuel grids consist of an egg-crate arrangement of interlocked straps that maintain lateral spacing between the rods. The grid straps have spring fingers and dimples that grip and support the fuel rods. The intermediate mixing vane grids also have coolant mixing vanes. In addition, there are four intermediate flow mixing (IFM) grids. The IFM grid straps contain support dimples and coolant mixing vanes only. The top and bottom grids and protective grid do not contain mixing vanes.

The AP1000 fuel assemblies are similar to the 17x17 Robust and 17x17 XL Robust fuel assemblies. The 17x17 Robust fuel assemblies have an active fuel length of 12 feet and three intermediate flow mixing grids in the top mixing vane grid spans. The 17x17 XL Robust fuel assemblies have an active fuel length of 14 feet with no intermediate flow mixing grids. The AP1000 fuel assemblies are the same as the 17x17 XL Robust fuel assemblies except that they have four intermediate flow mixing grids in the top mixing vane grid spans.

There is substantial operating experience with the 17x17 Robust and 17x17 XL Robust fuel assemblies. The 17x17 Robust fuel assemblies are described in References 1, 2 and 3. The 17x17 XL Robust fuel assemblies are described in References 4 and 5.

The XL Robust fuel assembly evolved from the previous VANTAGE+, VANTAGE 5 and VANTAGE 5 HYBRID designs. The XL Robust fuel assembly is based on the substantial design and operating experience with those designs. The design is described and evaluated in References 2, 3, 6 through 10.

A number of proven design features have been incorporated in the AP1000 fuel assembly design. The AP1000 fuel assembly design includes: low pressure drop intermediate grids, four intermediate flow mixing (IFM) grids, a reconstitutable Westinghouse integral nozzle (WIN), and extended burnup capability. The bottom nozzle is a debris filter bottom nozzle (DFBN) that

minimizes the potential for fuel damage due to debris in the reactor coolant. The AP1000 fuel assembly design also includes a protective grid for enhanced debris resistance.

The fuel rods consist of enriched uranium, in the form of cylindrical pellets of uranium dioxide, contained in ZIRLO™ (Reference 8) tubing. The tubing is plugged and seal welded at the ends to encapsulate the fuel. An axial blanket comprised of fuel pellets with reduced enrichment may be placed at each end of the enriched fuel pellet stack to reduce the neutron leakage and to improve fuel utilization.

Other types of fuel rods may be used to varying degrees within some fuel assemblies. One type uses an integral fuel burnable absorber (IFBA) containing a thin boride coating on the surface of the fuel pellets. Another type uses fuel pellets containing gadolinium oxide mixed with uranium oxide. The boride-coated fuel pellets and gadolinium oxide/uranium oxide fuel pellets provide a burnable absorber integral to the fuel.

Fuel rods are pressurized internally with helium during fabrication to reduce clad creepdown during operation and thereby prevent clad flattening. The fuel rods in the AP1000 fuel assemblies contain additional gas space below the fuel pellets, compared to the 17x17 Robust, 17x17 XL Robust and other previous fuel assembly designs to allow for increased fission gas production due to high fuel burnups.

Depending on the position of the assembly in the core, the guide thimbles are used for rod cluster control assemblies (RCCAs), gray rod cluster assemblies (GRCAs), neutron source assemblies, non-integral discrete burnable absorber (BA) assemblies, or thimble plugs.

For the initial core design, discrete burnable absorbers (BAs) and integral fuel burnable absorbers are used. Discrete burnable absorber designs, integral fuel burnable absorber designs (including both IFBAs and gadolinium oxide/uranium oxide BAs) or combinations may be used in subsequent reloads.

The bottom nozzle is a box-like structure that serves as the lower structural element of the fuel assembly and directs the coolant flow distribution to the assembly. The size of flow passages through the bottom nozzle limits the size of debris that can enter the fuel assembly. The top nozzle assembly serves as the upper structural element of the fuel assembly and provides a partial protective housing for the rod cluster control assembly or other components.

The rod cluster control assemblies consist of 24 absorber rods fastened at the top end to a common hub, or spider assembly. Each absorber rod consists of an alloy of silver-indium-cadmium, which is clad in stainless steel. The rod cluster control assemblies are used to control relatively rapid changes in reactivity and to control the axial power distribution.

The gray rod cluster assemblies consist of 24 rodlets fastened at the top end to a common hub or spider. Geometrically, the gray rod cluster assembly is the same as a rod cluster control assembly except that 12 of the 24 rodlets are fabricated of stainless steel, while the remaining 12 are silver-indium-cadmium (of a reduced diameter as compared to the RCCA absorber) with stainless steel clad.

The gray rod cluster assemblies are used in load follow maneuvering. The assemblies provide a mechanical shim reactivity mechanism to minimize the need for changes to the concentration of soluble boron.

The reactor core is cooled and moderated by light water at a pressure of 2250 psia. Soluble boron in the moderator/coolant serves as a neutron absorber. The concentration of boron is varied to control reactivity changes that occur relatively slowly, including the effects of fuel burnup. Burnable absorbers are also employed in the initial cycle to limit the amount of soluble boron required and, thereby maintain the desired negative reactivity coefficients.

The nuclear design analyses establish the core locations for control rods and burnable absorbers. The analyses define design parameters, such as fuel enrichments and boron concentration in the coolant.

The nuclear design establishes that the reactor core and the reactor control system satisfy design criteria, even if the rod cluster control assembly of the highest reactivity worth is in the fully withdrawn position.

The core has inherent stability against diametral and azimuthal power oscillations. Axial power oscillations, which may be induced by load changes, and resultant transient xenon may be suppressed by the use of the rod cluster control assemblies.

The control rod drive mechanisms used to withdraw and insert the rod cluster control assemblies and the gray rod cluster assemblies are described in subsection 3.9.4.

The thermal-hydraulic design analyses establish that adequate heat transfer is provided between the fuel clad and the reactor coolant. The thermal design takes into account local variations in dimensions, power generation, flow distribution, and mixing. The mixing vanes incorporated in the fuel assembly spacer grid design and the fuel assembly intermediate flow mixers induce additional flow mixing between the various flow channels within a fuel assembly, as well as between adjacent assemblies.

The reactor internals direct the flow of coolant to and from the fuel assemblies and are described in subsection 3.9.5.

The performance of the core is monitored by fixed neutron detectors outside the core, fixed neutron detectors within the core, and thermocouples at the outlet of selected fuel assemblies. The ex-core nuclear instrumentation provides input to automatic control functions.

Table 4.1-1 presents a summary of the principal nuclear, thermal-hydraulic, and mechanical design parameters of the AP1000 fuel. A comparison is provided to the fuel design used in AP1000, AP600 and in a licensed Westinghouse-designed plant using XL Robust fuel. For the comparison with a plant containing XL Robust fuel, a 193 fuel assembly plant is used, since no domestic, Westinghouse-designed 157 fuel assembly plants use 17x17 XL Robust fuel.

Table 4.1-2 tabulates the analytical techniques employed in the core design. The design basis must be met using these analytical techniques. Enhancements may be made to these techniques provided that the changes are bounded by NRC-approved methods, models, or criteria. In

addition, application of the process described in WCAP-12488-A, (Reference 9) allows the Combined License holder to make fuel mechanical changes. Table 4.1-3 tabulates the mechanical loading conditions considered for the core internals and components. Specific or limiting loads considered for design purposes of the various components are listed as follows: fuel assemblies in subsection 4.2.1.5; control rods (RCCAs and GRCAs), burnable absorber rods, and neutron source rods, in subsection 4.2.1.6. The dynamic analyses, input forcing functions, and response loadings for the control rod drive system and reactor vessel internals are presented in subsections 3.9.4 and 3.9.5.

#### 4.1.1 Principal Design Requirements

The fuel and rod control rod mechanism are designed so the performance and safety criteria described in Chapter 4 and Chapter 15 are met. *[The mechanical design and physical arrangement of the reactor components, together with the corrective actions of the reactor control, protection, and emergency cooling systems (when applicable) are designed to achieve these criteria, referred to as Principal Design Requirements:]*

- *Fuel damage, defined as penetration of the fuel cladding, is predicted not to occur during normal operation and anticipated operational transients.*
- *Materials used in the fuel assembly and in-core control components are selected to be compatible in a pressurized water reactor environment.*
- *For normal operation and anticipated transient conditions, the minimum DNBR calculated using the WRB-2M correlation is greater than or equal to 1.14.*
- *Fuel melting will not occur at the overpower limit for Condition I or II events.*
- *The maximum fuel rod cladding temperature following a loss-of-coolant accident is calculated to be less than 2200°F.*
- *For normal operation and anticipated transient conditions, the calculated core average linear power, including densification effects, is less than or equal to 5.718 kw/ft for the initial fuel cycle.*
- *For normal operation and anticipated transient conditions, the calculated total heat flux hot channel factor,  $F_Q$ , is less than or equal to 2.60 for the initial fuel cycle.*
- *Calculated rod worths provide sufficient reactivity to account for the power defect from full power to zero power and provide the required shutdown margin, with allowance for the worst stuck rod.*
- *Calculations of the accidental withdrawal of two control banks using the maximum reactivity change rate predict that the peak linear heat rate and DNBR limits are met.*
- *The maximum rod control cluster assembly and gray rod speed (or travel rate) is 45 inches per minute.*

- *The control rod drive mechanisms are hydrotested after manufacture at a minimum of 125 percent of system design pressure.*
- *For the initial fuel cycle, the fuel rod temperature coefficient is calculated to be negative for power operating conditions.*
- *For the initial fuel cycle, the moderator temperature coefficient is calculated to be negative for power operating conditions.]\**

#### 4.1.2 Combined License Information

This section contains no requirement for additional information to be provided in support of Combined License.

#### 4.1.3 References

1. Letter from N. J. Liparulo (Westinghouse) to J. E. Lyons (NRC), "Transmittal of Response to NRC Request for Information on Wolf Creek Fuel Design Modifications," NSD-NRC-97-5189, June 30, 1997.
2. Letter from N. J. Liparulo (Westinghouse) to R. C. Jones (NRC), "Transmittal of Presentation Material for NRC/Westinghouse Fuel Design Change Meeting on April 15, 1996," NSD-NRC-96-4964, April 22, 1996.
3. Letter from Westinghouse to NRC, "Fuel Criteria Evaluation Process Notification for the 17x17 Robust Fuel Assembly with IFM Grid Design," NSD-NRC-98-5796, October 13, 1998.
4. Letter from H. A. Sepp (Westinghouse) to T. E. Collins (NRC), "Notification of FCEP Application for WRB-1 and WRB-2 Applicability to the 17x17 Modified LPD Grid Design for Robust Fuel Assembly Application," NSD-NRC-98-5618, March 25, 1998.
5. Letter from H. A. Sepp (Westinghouse) to T. E. Collins (NRC), "Fuel Criteria Evaluation Process Notification for the Revised Guide Thimble Dashpot Design for the 17x17 XL Robust Fuel Assembly Design," NSD-NRC-98-5722, June 23, 1998.
6. Davidson, S. L., and Kramer, W. R., (Ed.), "Reference Core Report Vantage 5 Fuel Assembly," WCAP-10444-P-A (Proprietary), September 1985 and WCAP-10445-A (Non-Proprietary), December 1983.
7. Davidson, S. L., (Ed.), "VANTAGE 5H Fuel Assembly," Addendum 2-A, WCAP-10444-P-A (Proprietary) and WCAP-10445-NP-A (Non-Proprietary), February 1989.
8. Davidson, S. L., and Nuhfer, D. L., (Ed.), "VANTAGE+ Fuel Assembly Reference Core Report," WCAP-12610-P-A (Proprietary) and WCAP-14342-A (Non-Proprietary), April 1995.

---

\*NRC Staff approval is required prior to implementing a change in this information; see DCD Introduction Section 3.5.

9. [Davidson, S. L. (Ed.), “Fuel Criteria Evaluation Process,” WCAP-12488-A (Proprietary) and WCAP-14204-A (Non-Proprietary), October 1994.]\*
10. Letter, Peralta, J. D. (NRC) to Maurer, B. F. (Westinghouse), “Approval for Increase in Licensing Burnup Limit to 62,000 MWD/MTU (TAC No. MD1486),” May 25, 2006.

---

\*NRC Staff approval is required prior to implementing a change in this information; see DCD Introduction Section 3.5.

Table 4.1-1 (Sheet 1 of 3)			
REACTOR DESIGN COMPARISON TABLE			
Thermal and Hydraulic Design Parameters	AP1000	AP600	Typical XL Plant
Reactor core heat output (MWt)	3400	1933	3800
Reactor core heat output ( $10^6$ Btu/hr)	11,601	6596	12,969
Heat generated in fuel (%)	97.4	97.4	97.4
System pressure, nominal (psia)	2250	2250	2250
System pressure, minimum steady-state (psia)	2190	2200	2204
Minimum departure from nuclear boiling (DNBR) for design transients			
Typical flow channel	$>1.25^{(d)}$ , $>1.22^{(d)}$	$>1.23$	$>1.26$
Thimble (cold wall) flow channel	$>1.25^{(d)}$ , $>1.21^{(d)}$	$>1.22$	$>1.24$
Departure from nucleate boiling (DNB) correlation <sup>(b)</sup>	WRB-2M <sup>(b)</sup>	WRB-2	WRB-1 <sup>(a)</sup>
<b>Coolant Flow<sup>(c)</sup></b>			
Total vessel thermal design flow rate ( $10^6$ lbm/hr)	113.5	72.9	145.0
Effective flow rate for heat transfer ( $10^6$ lbm/hr)	106.8	66.3	132.7
Effective flow area for heat transfer (ft <sup>2</sup> )	41.8	38.5	51.1
Average velocity along fuel rods (ft/s)	15.8	10.6	16.6
Average mass velocity ( $10^6$ lbm/hr-ft <sup>2</sup> )	2.55	1.72	2.60
<b>Coolant Temperature<sup>(c)(e)</sup></b>			
Nominal inlet (°F)	535.0	532.8	561.2
Average rise in vessel (°F)	77.2	69.6	63.6
Average rise in core (°F)	81.4	75.8	68.7
Average in core (°F)	578.1	572.6	597.8
Average in vessel (°F)	573.6	567.6	593.0
<b>Heat Transfer</b>			
Active heat transfer surface area (ft <sup>2</sup> )	56,700	44,884	69,700
Avg. heat flux (BTU/hr-ft <sup>2</sup> )	199,300	143,000	181,200
Maximum heat flux for normal operation (BTU/hr-ft <sup>2</sup> ) <sup>(f)</sup>	518,200	372,226	489,200
Average linear power (kW/ft) <sup>(g)</sup>	5.72	4.11	5.20
Peak linear power for normal operation (kW/ft) <sup>(f)(g)</sup>	14.9	10.7	14.0
Peak linear power (kW/ft) <sup>(f)(h)</sup> (Resulting from overpower transients/operator errors, assuming a maximum overpower of 118%)	$\leq 22.45$	22.5	$\leq 22.45$

Table 4.1-1 (Sheet 2 of 3)			
REACTOR DESIGN COMPARISON TABLE			
Thermal and Hydraulic Design Parameters	AP1000	AP600	Typical XL Plant
Heat flux hot channel factor ( $F_Q$ )	2.60	2.60	2.70
Peak fuel center line temperature ( $^{\circ}\text{F}$ ) (For prevention of center-line melt)	4700	4700	4700
Fuel assembly design	17x17 XL Robust Fuel	17x17	17x17 XL Robust Fuel/ No IFM
Number of fuel assemblies	157	145	193
Uranium dioxide rods per assembly	264	264	264
Rod pitch (in.)	0.496	0.496	0.496
Overall dimensions (in.)	8.426 x 8.426	8.426 x 8.426	8.426 x 8.426
Fuel weight, as uranium dioxide (lb)	211,588	167,360	261,000
Clad weight (lb)	43,105	35,555	63,200
Number of grids per assembly Top and bottom - (Ni-Cr-Fe Alloy 718) Intermediate	2 <sup>(i)</sup> 8 ZIRLO <sup>TM</sup>	2 <sup>(i)</sup> 7 Zircaloy-4 or 7 ZIRLO <sup>TM</sup>	2 8 ZIRLO <sup>TM</sup>
Intermediate flow mixing	4 ZIRLO <sup>TM</sup>	4 Zircaloy-4 or 5 ZIRLO <sup>TM</sup>	0
Protective Grid - (Ni-Cr-Fe Alloy 718)	1	1	1
Loading technique, first cycle	3 region nonuniform	3 region nonuniform	3 region nonuniform
<b>Fuel Rods</b>			
Number	41,448	38,280	50,952
Outside diameter (in.)	0.374	0.374	0.374
Diametral gap (non-IFBA) (in.)	0.0065	0.0065	0.0065
Clad thickness (in.)	0.0225	0.0225	0.0225
Clad material	ZIRLO <sup>TM</sup>	Zircaloy-4 or ZIRLO <sup>TM</sup>	Zircaloy-4/ ZIRLO <sup>TM</sup>
<b>Fuel Pellets</b>			
Material	UO <sub>2</sub> sintered	UO <sub>2</sub> sintered	UO <sub>2</sub> sintered
Density (% of theoretical)	95.5	95	95
Diameter (in.)	0.3225	0.3225	0.3225
Length (in.)	0.387	0.387	0.387



Table 4.1-1 (Sheet 3 of 3)			
REACTOR DESIGN COMPARISON TABLE			
Rod Cluster Control Assemblies	AP1000	AP600	Typical XL Plant
<b>Neutron Absorber</b>			
RCCA GRCA	24 Ag-In-Cd rodlets 12 304 SS rodlets 12 Ag-In-Cd rodlets	24 Ag-In-Cd rodlets 20 304 SS rodlets 4 Ag-In-Cd rodlets	24 Hafnium or Ag-In-Cd
Cladding material	Type 304 SS, cold-worked	Type 304 SS, cold-worked	Type 304 SS, cold-worked
Clad thickness, (Ag-In-Cd)	0.0185	0.0185	0.0185
Number of clusters	53 RCCAs 16 GRCA	45 RCCAs 16 GRCA	57 RCCAs 0 GRCA
<b>Core Structure</b>			
Core barrel, ID/OD (in.)	133.75/137.75	133.75/137.75	148.0/152.5
Thermal shield	Neutron Panel	None	Neutron Panel
Baffle thickness (in.)	Core Shroud	Radial reflector	0.875
<b>Structure Characteristics</b>			
Core diameter, equivalent (in.)	119.7	115.0	132.7
Core height, cold, active fuel (in.)	168.0	144.0	168.0
<b>Fuel Enrichment First Cycle (Weight Percent)</b>			
Region 1	2.35	1.90	Typical
Region 2	3.40	2.80	3.8 to 4.4
Region 3	4.45	3.70	(5.0 Max)

**Notes:**

- WRB-2M will be used in future reloads.
- See subsection 4.4.2.2.1 for the use of the W-3, WRB-2 and WRB-2M correlations.
- Flow rates and temperatures are based on 10 percent steam generator tube plugging for the AP600 and AP1000 designs.
- 1.25 applies to core and axial offset limits; 1.22 and 1.21 apply to all other RTDP transients.
- Coolant temperatures based on thermal design flow (for AP600 and AP1000).
- Based on  $F_Q$  of 2.60 for AP600 and AP1000.
- Based on densified active fuel length. The value for AP1000 is rounded to 5.72 kW/ft.
- See subsection 4.3.2.2.6.
- The top grid will be fabricated of nickel-chromium-iron Alloy 718.

Table 4.1-2 (Sheet 1 of 2)

**ANALYTICAL TECHNIQUES IN CORE DESIGN**

<b>Analysis</b>	<b>Technique</b>	<b>Computer Code</b>	<b>Subsection Referenced</b>
Mechanical design of core internals loads, deflections, and stress analysis	Static and dynamic modeling	BLOWDOWN code, FORCE, finite element structural analysis code, and others	3.7.2.1 3.9.2 3.9.3
Fuel rod design Fuel performance characteristics (such as, temperature, internal pressure, and clad stress)	Semi-empirical thermal model of fuel rod with considerations such as fuel density changes, heat transfer, and fission gas release.	Westinghouse fuel rod design model	4.2.1.1 4.2.3.2 4.2.3.3 4.3.3.1 4.4.2.11
Nuclear design Cross-sections and group constants  X-Y and X-Y-Z power distributions, fuel depletion, critical boron concentrations, X-Y and X-Y-Z xenon distributions, reactivity coefficients  Axial power distributions, control rod worths, and axial xenon distribution  Fuel rod power Effective resonance temperature  Criticality of reactor and fuel assemblies	Microscopic data; macroscopic constants for homogenized core regions  2-group diffusion theory, 2-group nodal theory  1-D, 2-group diffusion theory  Integral transport theory Monte Carlo weighing function  3-D, Monte Carlo theory	Modified ENDF/B library with PHOENIX-P  ANC (2-D or 3-D)  APOLLO  LASER REPAD  AMPX system of codes, KENO-Va	4.3.3.2  4.3.3.3  4.3.3.3  4.3.3.1 4.3.3.1  4.3.2.6
Vessel irradiation	Multigroup spatial dependent transport theory	DOT	4.3.2.8
Thermal-hydraulic design steady state	Subchannel analysis of local fluid conditions in rod bundles, including inertial and cross-flow resistance terms; solution progresses from core-wide to hot assembly to hot channel.	VIPRE-01	4.4.4.5.2

Table 4.1-2 (Sheet 2 of 2)

**ANALYTICAL TECHNIQUES IN CORE DESIGN**

<b>Analysis</b>	<b>Technique</b>	<b>Computer Code</b>	<b>Subsection Referenced</b>
Transient departure from nucleate boiling	Subchannel analysis of local fluid conditions in rod bundles during transients by including accumulation terms in conservation equations; solution progresses from core-wide to hot assembly to hot channel.	VIPRE-01	4.4.4.5.4

Table 4.1-3

**DESIGN LOADING CONDITIONS FOR REACTOR CORE COMPONENTS**

- Fuel assembly weight and core component weights (burnable absorbers, sources, RCCA, GRCA)
- Fuel assembly spring forces and core component spring forces
- Internals weight
- Control rod trip (equivalent static load)
- Differential pressure
- Spring preloads
- Coolant flow forces (static)
- Temperature gradients
- Thermal expansion
- Interference between components
- Vibration (mechanically or hydraulically induced)
- Operational transients listed in Table 3.9.1-1
- Pump overspeed
- Seismic loads (safe shutdown earthquake)
- Blowdown forces (due to pipe rupture)