
NRC FORM 195	U.S. NUCLEAR REGULATORY COMMISSION			DOCKETNUMBER 50-305	
	T 50 DOCKET MATERIAL			FILE NUMBER INCIDENT REPORT	
TO: J.G. KEPPLER		FROM: WISCONSIN PUBLIC SVC. CORP. GREEN BAY, WISCONSIN			DATE OF DOCUMENT 2/17/77
					DATE RECEIVED 3/3/77
		PROP		INPUT FORM	NUMBER OF COPIES RECEIVED
COPY					1 SIGNED CY. RECEIVED)
LTR. TRANS THE FOLLOWING			77 (ENSEF FVENT REPOR	I FOR R.O.∦ 77-4, ON 1/17/ URCE RANGE DETECTORS ···
do not re		77 C		I FOR R.O.# 77-5, ON 1/17/ CHARGING PUMP FAILING TO	
PLANT NAME: KEWAUNEE		(1P)	LICENSEE EVENT REPORT FOR R.O.# 77-6, ON 1/17/ 77 CONCERNING BLOWDOWN ISOLATION VALVE BT-3A BEING ATTEMPTED TO BE CLOSED (1 SIGNED CY. RECEIVED)		
		(1r)	(3P) NOTE:		XPOSURE IS INVOLVED
		· ·			TO KREGER/J. COLLINS
BRANCH CHIEF:	T	FOR ACTION/	NFORM	IATION	SAB 3/8/77
W/3 CYS FOR ACTION	SCHWENCE	SR			
LIC. ASCT::	SHEPPARI)			
W/ CYS					
ACRS 16 CYS XXXXXXXXXXXXXXXXXXXXXXXXXXXXXXXXXXX	ENT CAT	"B"			·
	<u></u>	INTERNAL D	ISTRIB	ITION	
REG FILE					
NRC PDR					
I & E (2)				·	
MIPC SCHROEDER/IPPOLITO					
HOUSTON					
NOVAK/CHECK					
GRIMES					
CASE					
BUTLER HANAUER					
TEDESCO/MACCARY	+			· · · · · · · · · · · · · · · · · · ·	
EISENHUT					
BAER					
SHAO VOLLMER/BUNCH					
KREGER/J. COLLINS					
d * DDD -	EXTERNAL	DISTRIBUTION	r		CONTRODNUMBER
LPDR: KEWAUNEE, WIS.					-1 U
NSIC:					
					2244
					<u>l´</u>





Darkam

WISCONSIN PUBLIC SERVICE CORPORATION



P.O. Box 1200, Green Bay, Wisconsin 54305

February 17, 1977



Operating License DPR-43 Reportable Occurrences RO 77-4, RO 77-5 and RO 77-6

In accordance with the requirements of Technical Specifications,

Section 6.9, the attached Licensee Event Reports for reportable occurrences

RO 77-4, RO 77-5 and RO 77-6 are submitted.

Very truly yours,

E. W. James Senior Vice President Power Supply & Engineering

EWJ:sna
Attach.
cc - Dir, Office of Inspection & Enforcement
 US NRC, Washington, D. C. 20555
Dir, Office of Management Info & Program Control
 US NRC, Washington, D. C. 20555

2244

	ION)
LICENSEE LICENSE LICENSE LICENSE EVENT NAME LICENSE NUMBER 1 1 1 1 1 1 0 1 W I K N P 1 0 0 0 0 0 0 4 1 1 1 1 9 9 7 B 9 14 15 25 26 30 31 32	
CATEGORY REPORT TYPE REPORT SOURCE DDCKET NUMBER EVENT DATE REPORT DATE 01 CON'T 1 1 7 7 0 2 1 7 7 7 8 57 58 59 60 61 68 69 74 75	7 80
EVENT DESCRIPTION [O]2 As the reactor was being brought to the hot shutdown condition, the source range de-	
7 8 9 03 tectors were re-energized. Channel N31 failed to respond. The protective circuitry	80
7 89 04 for that channel was not available, but the redundant channel remained operable.	80
7 8 9 05 (RO 77-4)	в0
7 B 9 06 L 7 B 9 PENS	80
PRIME CODE COMPONENT CODE COMPONENT CODE COMPONENT SUPPLER COMPONENT MANUFACTURER VIOLATION 0 7 8 9 10 11 12 17 43 44 47 48	00
CAUSE DESCRIPTION OB The source range preamplifier and detector had failed. The preamplifier was re-	I
7 8 9 Og paired and the detector was replaced and the channel operated properly.	80
	08
7 8 9 FACILITY METHOD OF STATUS % POWER OTHER STATUS DISCOVERY OISCOVERY DESCRIPTION	80
11 G 0 0 HOT A NA 7 8 9 10 12 13 44 45 46	80
FORM OF ACTIVITY CONTENT RELEASED AMDUNT OF ACTIVITY LOCATION OF RELEASE 12 2 2 NA NA 7 8 9 10 11 44 45	80
PERSONNEL EXPOSURES NUMBER 13 000 13 7 8 9 11 12 13 12 13 12 13]
PERSONNEL INJURIES NUMBER DESCRIPTION 14 0 0 0 NA 7 5 9 11 12	60
OFFSITE CONSEQUENCES	
LOSS OR DAMAGE TO FACILITY TYPE DESCRIPTION 16 Z NA	
7 B 9 10 PUBLICITY	80
17 NA 7 8 9	80
ADDITIONAL FACTORS Image: This is considered an isolated incident and no further action is deemed necessary 7 8	80
19 at this time.]
7 89 NAME: Mark L. Marchi PHONE: 414/432-3311 GPO 881.	80

LICENSEE EVENT REPORT	
	¥)
LICENSEE NAME LICENSEE NAME 0 0 - 0 0 0 0 - 0 0 4 1 1 1 1 9 9 7 8 9 14 15 25 26 30 31 32	
CATEGORY REPORT TYPE REPORT SOURCE DOCKET NUMBER EVENT DATE REPORT DATE 01 CON'T 1 1 7 7 0 2 1 7 7 7 8 57 58 59 60 61 68 69 74 75 60	7] 30
EVENT DESCRIPTION [0]2 1A charging pump failed to increase speed. The 1C charging pump was already out of	J
7 8 9 03 service for repair. Continued operation is allowed by Tech Specs with one operable	30
old charging pump for 24 hours. The unit was in hot shutdown less than one hour later.	30
05 (RO 77-5)	
้ โดง	 50
SYSTEM CAUSE COMPONENT CODE COMPONENT SUPPLIER COMPONENT MANUFACTURER VIOLATION 0 7 8 9 10 11 12 17 43 44 47 48	
CAUSE DESCRIPTION The pump would not change speed due to a broken shifting lever assembly. The	
09 pneumatic actuator and shifting lever assembly were replaced and the pump functioned	
10 normally.	
FACILITY STATUS % POWER OTHER STATUS METHOD OF DISCOVERY DISCOVERY DISCOVERY 1 1 0 0 NA A NA	
PERSONNEL EXPOSURES NUMBER TYPE 0 0 0 0 Z NA 7 8 9 11 12 13 E	
PERSONNEL INJURIES NUMBER DESCRIPTION 14 0 0 0 NA 7 8 9 11 12 E	 80
OFFSITE CONSEQUENCES	
7 8 9 10 E	.] 80
ADDITIONAL FACTORS Image: Im	 60
19 Lat this time.	
7 89 NAME:Mark L. MarchiPHONE: 414/432-3311	10

	<u>(</u> M0
LICENSEE NAME LICENSE LICENSE NUMBER $0 \ 1 \ W \ I \ K \ N \ P \ 1 \ 0 \ 0 \ - \ 0 \ 0 \ 0 \ 0 \ 0 \ 0 \ - \ 0 \ 0$	
CATEGORY REPORT TYPE REPORT SOURCE DOCKET NUMBER EVENT DATE REPORT DATE 0 1 1 7 7 0 2 1 7 7 7 8 57 58 59 60 61 68 69 74 75	7
EVENT OESCRIPTION	1
7 8 9 03 to be closed. The valve failed to close completely. The redundant isolation valve	80
7 8 9 04 was operable and was shut from the control room. (RO 77-6)	80
	08
7 8 9 06 [7 8 9	80
SYSTEM CAUSE COMPONENT COMPONENT COMPONENT COMPONENT COMPONENT COMPONENT COMPONENT COMPONENT MANUFACTURER VIOLATION 0 7 S D E V A L V E X A E 0 9 5 N 7 B 9 10 11 12 17 43 44 47 48	
CAUSE DESCRIPTION 08 The valve was turning hard and torqued out early. The packing was loosened and the	
7 8 9 09 valve was greased. Subsequent surveillance testing has shown that the valve has	80
⁷ ⁸ ⁹ functioned properly.	80
7 8 9 FACILITY STATUS % POWER OTHER STATUS 11 D 0 0 12 13 44 45 46	
FORM OF ACTIVITY CONTENT RELEASED OF RELEASE AMOUNT OF ACTIVITY LOCATION OF RELEASE 7 B 9 10 11 44 45	80
PERSONNEL EXPOSURES NUMBER TYPE DESCRIPTION 7 8 9 11 12 13	80
PERSONNEL INJURIES NUMBER DESCRIPTION 14 0 0 0 NA 7 8 9 11 12	80
OFFSITE CONSEQUENCES	80
LOSS OR DAMAGE TO FACILITY TYPE DESCRIPTION 16 Z NA 7 8 9 10	80
PUBLICITY 17 NA 7 8 9	80
ADDITIONAL FACTORS 18 This is considered an isolated incident and no further action is deemed necessary 7 8	80
19 at this time.	Ţ
7 89 NAME: Mark L. Marchi PHONE: 414/432-3311 GP9 881.	80