

| MEMO ROUTE SLIP Form AEC-93 (Rev. May 14, 1947) AECM 0240 | | See me about this. | For concurrence. | For action. | |
|---|----------------|--|--|------------------|--|
| | | Note and return. | For signature. | For information. | |
| TO (Name and unit) RO Chief, FS&EB RO:HQ (4) Licesning (4) DR Central Files Region I | | INITIALS | REMARKS Wisconsin Public Service Corporation Kewaunee 50-305 | | |
| | | DATE | | | |
| TO (Name and unit) Region II PDR Local PDR NSIC TIC | | INITIALS | REMARKS | | |
| | | DATE | | | |
| TO (Name and unit) OGC, Beth, P-506A R. Renfrow, GC (2) F. Rizzo, RO:HQ | | INITIALS | REMARKS | | |
| | | DATE | | | |
| FROM (Name and unit) G. Fiorelli RO:III | | REMARKS Attached is licensee's reply dated August 15, 1974, to RO Bulletin 74-9. | | | |
| | | | | | |
| PHONE NO. | DATE 9-6-74 | | | | |

USE OTHER SIDE FOR ADDITIONAL REMARKS

GPO : 1971 O - 445-469

LB

WISCONSIN PUBLIC SERVICE CORPORATION



P.O. Box 1200, Green Bay, Wisconsin 54305

August 15, 1974

Mr. James G. Keppler
Regional Director
Atomic Energy Commission
Region III
799 Roosevelt Road
Glen Ellyn, Illinois 60137

Dear Mr. Keppler:

In response to your letter of August 9, 1974, we have reviewed the Kewaunee Nuclear Plant electrical equipment. There are no General Electric 4KV circuit breakers as described in DRO Bulletin No. 74-9 installed in Class IE systems of the Kewaunee Plant.

Sincerely,

A handwritten signature in cursive script, appearing to read "E. W. James".

E. W. James
Senior Vice President
Power Generation & Engineering

EWJ:bam

AUG 19 1974