

# MEMO ROUTE SLIP

Form AEC-93 (Rev. May 14, 1947) AECM 0240

See me about this.

For concurrence.

For action.

Note and return.

For signature.

For information.

TO (Name and unit)

RO Chief, FS&EB  
RO:HQ (4)  
Licensing (4)  
DR Central Files  
Region I

INITIALS

DATE

REMARKS

Wisconsin Public Service Corporation  
Kewaunee 50-305

TO (Name and unit)

Region II  
PDR  
Local PDR  
NSIC  
DTIE

INITIALS

DATE

REMARKS

TO (Name and unit)

OGC, Beth, P-506A  
R. Renfrow, GC  
F. Rizzo, RO:HQ

INITIALS

DATE

REMARKS

FROM (Name and unit)

G. Fiorelli  
RO:III

REMARKS

Attached is a copy of licensee's reply dated August 12, 1974,  
to RO Bulletin 74-8.

PHONE NO.

DATE

8-14-74

USE OTHER SIDE FOR ADDITIONAL REMARKS

GPO : 1971 O - 445-489

26

WISCONSIN PUBLIC SERVICE CORPORATION



P.O. Box 1200, Green Bay, Wisconsin 54305

August 12, 1974

Mr. J. G. Keppler  
Regional Director  
Atomic Energy Commission  
Region III  
799 Roosevelt Road  
Glen Ellyn, Illinois 60137

Dear Mr. Keppler:

In response to your letter of August 2, 1974 and DRO Bulletin No. 74-8, we have reviewed the electrical equipment at the Kewaunee Nuclear Plant. We do not have ITE molded case, Type HE-3 circuit breakers installed on any class IE equipment.

Sincerely,

A handwritten signature in cursive script, appearing to read "E. W. James".

E. W. James  
Senior Vice President  
Power Generation & Engineering

EWJ:bam

AUG 14 1974