

**AEC DISTRIBUTION FOR PART 50 DOCKET MATERIAL
(TEMPORARY FORM)**

CONTROL NO: 1068

FILE:

FROM: Wisconsin Public Service Corp. Glen Ellyn Illinois 60137 C. W. Giesler			DATE OF DOC 2-8-74	DATE REC'D 2-11-74	LTR	MEMO	RPT	OTHER TWX
TO: J. F. O'Leary			ORIG 1	CC	OTHER	SENT AEC PDR <u>X</u> SENT LOCAL PDR <u>X</u>		
CLASS	UNCLASS XXX	PROP INFO	INPUT	NO CYS REC'D 1	DOCKET NO: <u>50-305</u>			

DESCRIPTION:

TWX reporting an abnormal occurrence on 2-8-74, regarding a liquid leak from a hair line crack in the 3/8 inch diameter tubing on the flow meter for the charging system.....

ENCLOSURES:

**DO NOT REMOVE
ACKNOWLEDGED**

PLANT NAME: Kewaunee

FOR ACTION/INFORMATION

2-11-74 GC

BUTLER(L)	SCHWENCER(L)	ZIEMANN(L)	REGAN(E)
W/ Copies	W/ Copies	W/ 1 Copies <i>info</i>	W/ Copies
CLARK(L)	STOLZ(L)	DICKER(E)	
W/ Copies	W/ Copies	W/ Copies	W/ Copies
GOLLER(L)	VASSALLO(L)	KNIGHTON(E)	
W/ Copies	W/ Copies	W/ Copies	W/ Copies
✓KNIEL(L)	SCHEMEL(L)	YOUNGBLOOD(E)	
W/ 7 Copies	W/ Copies	W/ Copies	W/ Copies

INTERNAL DISTRIBUTION

<u>REG FILE</u>	<u>TECH REVIEW</u>	<u>DENTON</u>	<u>LIC ASST</u>	<u>A/T IND</u>
✓AEC PDR	✓HENDRIE	GRIMES		BRAITMAN
✓OGC, ROOM P-506A	SCHROEDER	GAMMILL	DIGGS (L)	SALTZMAN
✓MUNTZING/STAFF	✓MACCARY	KASTNER	GEARIN (L)	B. HURT
✓EASE	✓KNIGHT	BALLARD	GOULBOURNE (L)	<u>PLANS</u>
GIAMBUSSO	✓PAWLICKI	SPANGLER	LEE (L)	MCDONALD
BOYD	✓SHAO		MAIGRET (L)	DUBE w/Input
✓MOORE (L)(BWR)	✓STELLO	<u>ENVIRO</u>	✓SERVICE (L)	<u>INFO</u>
DEYOUNG(L)(PWR)	✓HOUSTON	MULLER	SHEPPARD (E)	C. MILES
SKOVHOLT (L)	✓NOVAK	DICKER	SMITH (L)	✓B. KING (RO)
P. COLLINS	✓ROSS	KNIGHTON	TEETS (L)	
DENISE	✓IPPOLITO	YOUNGBLOOD	WADE (E)	
<u>REG OPR</u>	✓TEDESCO	REGAN	WILLIAMS (E)	
FILE & REGION(3)	✓LONG	PROJECT LDR	WILSON (L)	
✓MORRIS	✓LAINAS		S. REED (L)	
✓STEELE	✓BENAROYA	<u>HARLESS</u>		
	✓VOLLMER			

EXTERNAL DISTRIBUTION

✓1 - LOCAL PDR Kewaunee, Wis.	(1)(2)(10)-NATIONAL LAB'S	1-PDR-SAN/LA/NY
✓1 - DTIE(ABERNATHY)	1-ASLBP(E/W Bldg, Rm 529)	1-GERALD LELLOUCHE
✓1 - NSIC(BUCHANAN)	1-W. PENNINGTON, Rm E-201 GT	BROOKHAVEN NAT. LAB
1 - ASLB(YORE/SAYRE/ WOODARD/"H" ST.	1-CONSULTANT'S	1-AGMED(Ruth Gussman)
✓16 - CYS ACRS XXXXXX SENT TO LIC. ASST.	NEWMARK/BLUME/AGBABIAN	RM-B-127, GT.
2-11-74 SERVICE	1-GERALD ULRIKSON...ORNL	1-RD..MULLER..F-309 GT

Regulatory Docket File

WESTERN UNION INCOMING
WESTERN UNION INCOMING

BETH
008

USAEC HQS GTWN
TLXB007 WAC188(1808)(1-039943A039)PD 02/08/74 1806


ICS IPMGUMA GRB
01071 GREEN BAY WIS 02-08 446P CDT

1974 FEB 8 PM 8 56

PMS MR J F OLEARY, DIRECTOR
DIRECTORATE OF LICENSING

U.S. ATOMIC ENERGY COMM
T W X UNIT

OFFICE OF REGULATION
US ATOMIC ENERGY COMMISSION
WASHINGTON DC 20545



DOCKET 50-305 OPERATING LICENSE DPR-43
REPORT NUMBER: 50-305/74-1

THIS IS TO REPORT A LIQUID LEAK FROM A HAIR LINE CRACK IN THE
3/8 INCH DIAMETER TUBING, ON THE FLOW METER FOR THE CHARGING SYSTEM.
IT IS A POSSIBLE ABNORMAL OCCURRENCE UNDER OUR TECH SPEC DEFINITION
IA1 (E) AND CONFIRMS OUR PHONE CALL TO YUR
MR CECIL JONES

CHECK VALVES ISOLATE THIS LEAK AUTOMATICALLY FROM MAIN COOLANT
BACK FLOW. THIS UNIT HAS NOT BEEN CRITICAL TO THIS DATE AND THERE
IS NO PUBLIC SAFETY IMPLICATION ASSOCIATED WITH THIS
OCCURRENCE

CARL W GIESLER
SUPERINTENDENT NUCLEAR POWER

CC: MR JAMES G KEPPLER
REGIONAL DIRECTOR
DIRECTORATE OF REGULATORY OPERATIONS REGION 111
US ATOMIC ENERGY COMM
799 ROOSEVELT RD
GLEN ELLYN ILLINOIS 60137
NNNN



USAEC HQS GTWN
827P EDT
WU WSH

WESTERN UNION INCOMING

WESTERN UNION INCOMING

1068