

## REGULATORY INFORMATION DISTRIBUTION SYSTEM (RIDS)

ACCESSION NBR: 7901300106 DOC. DATE: 79/01/24 NOTARIZED: NO DOCKET #  
 FACIL: 50-305 Kewaunee Nuclear Power Plant, Wisconsin Power & Light 05000305  
 AUTH. NAME AUTHOR AFFILIATION  
 RUITER, G.H. Wisconsin Public Service Corp.  
 RECIP. NAME RECIPIENT AFFILIATION  
 Region 3, Chicago, Office of the Director

SUBJECT: LER 78-037/03L-0 on 781226: during full power operation, 1 of  
 2 reactor trip breakers would not trip. Shaft of trip breaker  
 under voltage relay was sticking, which prevented breaker  
 trip. UV relay shaft was cleaned & lubricated.

DISTRIBUTION CODE: A002S COPIES RECEIVED: LTR 1 ENCL 1 SIZE: 1+2  
 TITLE: INCIDENT REPORTS

NOTES: I & E - 3 CYS ALL MATL. LAWRENCE (OELD) - 1 CY ALL MATL.

	RECIPIENT ID CODE/NAME	COPIES LTTR ENCL	RECIPIENT ID CODE/NAME	COPIES LTTR ENCL
ACTION:	05 BC ORB #1	4 4		
INTERNAL:	01 REG FILE	1 1	02 NRC PDR	1 1
	09 I&E	2 2	11 MPA	3 3
	14 TA/EDO	1 1	15 NOVAK/KNIEL	1 1
	16 EEB	1 1	17 AD FOR ENGR	1 1
	18 PLANT SYS BR	1 1	19 I&C SYS BR	1 1
	20 AD PLANT SYS	1 1	21 AD SYS/PROJ	1 1
	22 REAC SAFT BR	1 1	23 ENGR BR	1 1
	24 KREGER	1 1	25 PWR SYS BR	1 1
	26 VOLLMER	1 1	27 OPERA LIC BR	1 1
	28 ACCIDENT ANALYS	1 1	E JORDAN/IE	1 1
EXTERNAL:	03 LPDR	1 1	04 NSIC	1 1
	29 ACRS	16 16		

JAN 31 1979

TOTAL NUMBER OF COPIES REQUIRED: LTTR 45 ENCL 45

A0 4  
60